

SECTION A - PERMIT VERIFICATION

PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS S M U NA (FURTHER EXPLANATION ATTACHED no)
 DETAILS:

- 1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE Y N NA
- 2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES Y N NA
- 3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT Y N NA
- 4. ALL DISCHARGES ARE PERMITTED Y N NA

SECTION B - RECORDKEEPING AND REPORTING EVALUATION

RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT. S M U NA (FURTHER EXPLANATION ATTACHED no)
 DETAILS:

- 1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRs. Y N NA
- 2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE. S M U NA
 - a) DATES, TIME(S) AND LOCATION(S) OF SAMPLING Y N NA
 - b) NAME OF INDIVIDUAL PERFORMING SAMPLING Y N N
 - c) ANALYTICAL METHODS AND TECHNIQUES. Y N NA
 - d) RESULTS OF ANALYSES AND CALIBRATIONS. Y N NA
 - e) DATES AND TIMES OF ANALYSES. Y N NA
 - f) NAME OF PERSON(S) PERFORMING ANALYSES. Y N NA
- 3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE. S M U NA
- 4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR. S M U NE
- 5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA. Y N NA

SECTION C - OPERATIONS AND MAINTENANCE

TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED. S M U NA (FURTHER EXPLANATION ATTACHED no)
 DETAILS:

- 1. TREATMENT UNITS PROPERLY OPERATED. S M U NA
- 2. TREATMENT UNITS PROPERLY MAINTAINED. S M U NA
- 3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED. S M U NA
- 4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE. S M U NA
- 5. ALL NEEDED TREATMENT UNITS IN SERVICE. S M U NA
- 6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED. S M U NA
- 7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED. S M U NE
- 8. OPERATION AND MAINTENANCE MANUAL AVAILABLE. Y N NA
 STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED.
- PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED. Y N NE

SECTION C - OPERATIONS AND MAINTENANCE (CONT'D)

9. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR? Y N NA
 IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED? Y N NA
 HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS? Y N NA

10. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT? Y N NA
 IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT? Y N NA

SECTION D - SELF-MONITORING

PERMITTEE SELF-MONITORING MEETS PERMIT REQUIREMENTS. S M U NA (FURTHER EXPLANATION ATTACHED no).
 DETAILS:

1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT. Y N NA

2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES. Y N NA

3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT. Y N NA

4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT. Y N NA

5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT. Y N NA

6. SAMPLE COLLECTION PROCEDURES ADEQUATE Y N NA

a) SAMPLES REFRIGERATED DURING COMPOSITING. Y N NA

b) PROPER PRESERVATION TECHNIQUES USED. Y N NA

c) CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136 Y N NA

7. IF MONITORING AND ANALYSES ARE PERFORMED MORE OFTEN THAN REQUIRED BY PERMIT, ARE THE RESULTS REPORTED IN PERMITTEE'S SELF-MONITORING REPORT? Y N NA

SECTION E - FLOW MEASUREMENT

PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS. S M U NA (FURTHER EXPLANATION ATTACHED yes)
 DETAILS: see page one

1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED. Y N NA
 TYPE OF DEVICE NONE

2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED. Y N NA

3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED. Y N NA

4. CALIBRATION FREQUENCY ADEQUATE. (DATE OF LAST CALIBRATION) Y N NA
 RECORDS MAINTAINED OF CALIBRATION PROCEDURES. Y N NA
 CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE. Y N NA

5. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE. Y N NA

6. HEAD MEASURED AT PROPER LOCATION. Y N NA

7. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES. Y N NA

SECTION F - LABORATORY

PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS. S M U NA (FURTHER EXPLANATION ATTACHED no)
 DETAILS:

1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(b) FOR SLUDGES) Y N NA

SECTION F - LABORATORY (CONT'D)

- 2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED Y N NA
- 3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT. S M U NA
- 4. QUALITY CONTROL PROCEDURES ADEQUATE. S M U NA
- 5. DUPLICATE SAMPLES ARE ANALYZED, 10% OF THE TIME. Y N NA
- 6. SPIKED SAMPLES ARE ANALYZED, 10% OF THE TIME. Y N NA
- 7. COMMERCIAL LABORATORY USED. Y N NA

LAB NAME American Interplex
 LAB ADDRESS Kanis Road, Little Rock, AR
 PARAMETERS PERFORMED CBOD

SECTION G - EFFLUENT/RECEIVING WATERS OBSERVATIONS. S M U NA (FURTHER EXPLANATION ATTACHED no).

Based on visual observations only.

OUTFALL NO.	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOAT SOL.	COLOR	OTHER
001	none	none	Slight	none	none	Lt green	

Comments:

SECTION H - SLUDGE DISPOSAL

SLUDGE DISPOSAL MEETS PERMIT REQUIREMENTS. S M U NA (FURTHER EXPLANATION ATTACHED no).
 DETAILS:

- 1. SLUDGE MANAGEMENT ADEQUATE TO MAINTAIN EFFLUENT QUALITY. S M U NA
- 2. SLUDGE RECORDS MAINTAINED AS REQUIRED BY 40 CFR 503. S M U NA
- 3. FOR LAND APPLIED SLUDGE, TYPE OF LAND APPLIED TO: (e.g., FOREST, AGRICULTURAL, PUBLIC CONTACT SITE)

SECTION I - SAMPLING INSPECTION PROCEDURES (FURTHER EXPLANATION ATTACHED no).

- 1. SAMPLES OBTAINED THIS INSPECTION. Y N NA
- 2. TYPE OF SAMPLE OBTAINED
 GRAB COMPOSITE SAMPLE METHOD FREQUENCY
- 3. SAMPLES PRESERVED. Y N NA
- 4. FLOW PROPORTIONED SAMPLES OBTAINED. Y N NA
- 5. SAMPLE OBTAINED FROM FACILITY'S SAMPLING DEVICE. Y N NA
- 6. SAMPLE REPRESENTATIVE OF VOLUME AND NATURE OF DISCHARGE. Y N NA
- 7. SAMPLE SPLIT WITH PERMITTEE. Y N NA
- 8. CHAIN-OF-CUSTODY PROCEDURES EMPLOYED. Y N NA
- 9. SAMPLES COLLECTED IN ACCORDANCE WITH PERMIT. Y N NA

Mr. Glen Holmes, General Manager
El Dorado Water Utilities
P.O. Box 1587
El Dorado, AR 71731

ADEQ

ARKANSAS
Department of Environmental Quality

January 29, 2007

Mr. Glen Holmes, General Manager
El Dorado Water Utilities
P.O. Box 1587
El Dorado, AR 71731

NPDES Permit No. AR0033723

Dear Mr. Holmes:


On December 13, 2006, I performed a routine compliance inspection and a pretreatment compliance inspection of the El Dorado South Wastewater Facility in accordance with the provisions of the federal Clean Water Act, the Arkansas Water and Air Pollution Control Act and the regulations promulgated thereunder. This inspection revealed the following:

1. The pretreatment inspection reports performed by the facility for Miller Transport needs to include the verification of the self-monitoring done by Miller Transport for pH. This should be done by documenting the review of the self-monitoring data, observation of self-monitoring procedure, and verification of an approved, analytical method.
2. The facility was instructed in a pretreatment audit in May 2006, to insure that flow measurement checks are included on the pretreatment inspection reports. The facility has begun this but still should follow up to make sure this is fully implemented
3. The facility was instructed in a pretreatment audit in May 2006, to document phone calls to industrial users when violations occur. The facility still needs to implement this in the form of phone call logs.

These items require your immediate attention. Please submit a written response to these findings to the NPDES Enforcement Section of this Department. This response should contain documentation describing the course of action taken to correct each item noted. This corrective action should be completed as soon as possible, and the written response is due by February 12, 2007.

If you have any questions concerning this inspection, please feel free to contact me at (870) 862-0680.

Sincerely,



John W. Lamb, District Field Inspector
Water Division

cc: NPDES Enforcement Branch
NPDES Permits Branch

WATER DIVISION