



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Washington, D.C. 20460

NPDES Compliance Inspection Report

Form Approved
OMB No. 2040-0003

Section A: National Data System Coding

Transaction Code	NPDES	Yr/Mo/Day	Inspec. Type	Inspector	Fac. Type
1 N 2 5 3 A R 0 0 2 2 0 6 3 11 12 0 8 1 2 1 1 17 18 C 19 J 20 1					
Remarks					
A F I N 7 2 - 0 0 0 0 3					
Inspection Work Days	Facility Evaluation Rating	BI	QA	Reserved	
67 69	70 N	71 N	72 N	73	74 75 80

Section B: Facility Data

Name and Location of Facility Inspected (For industrial users discharging to POTW, also include POTW name and NPDES permit number) City of Springdale POTW 2910 Silent Grove Rd. Springdale, Arkansas	Entry Time/Date 0930 / 12-11-08	Permit Effective Date April 1, 2004
	Exit Time/Date 1440 / 12-11-08	Permit Expiration Date March 31, 2009
Name(s) of On-Site Representative(s)/Title(s)/Phone and Fax Number(s) Harold Hull, Superintendent, 479-756-3657 Jennifer Enos, Pretreatment Manager, 479-756-3657	Other Facility Data Outfall 001 36 12' 49", -94 09' 48"	
Name, Address of Responsible Official/Title/Phone and Fax Number Rene Langston, Executive Director, 479-751-5751 City of Springdale P.O. Box 769 Springdale, Arkansas 72765	Contacted Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	

Section C: Areas Evaluated During Inspection

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

Permit	Flow Measurement	Operations & Maintenance	Sampling
Records/Reports	Self-Monitoring Program	Sludge Handling/Disposal	Pollution Prevention
Facility Site Review	Compliance Schedules	Pretreatment	Multimedia
Effluent/Receiving Waters	Laboratory	Storm Water	Other:

Section D: Summary of Findings/Comments (Attach additional sheets if necessary)

This EPA-lead Permit Compliance Evaluation Inspection was conducted by David Long, USEPA, and John Fazio, ADEQ, on December 11, 2008. We were accompanied by Alison West, ADEQ Field Inspector. Permit compliance issues included:

1. Effluent auto-sampler thermometer had not been calibrated within the last 12 months;
2. Evidence of periodic flow over several sand filter weirs results in a bypass of the sand filters and allows solids to reach the chlorine contact chamber;
3. When cleaning final clarifier weirs, some solids had been discarded to the ground surface.

Although the condition listed above exists at the sand filters, TSS concentrations in the treated effluent are consistently well below permit limits.

Name(s) and Signature(s) of Inspector(s) John Fazio	Agency/Office/Telephone/Fax AR Dept. of Environmental Quality-Fayetteville 479-267-0811, ext. 16; 479-267-0819 (fax)	Date 12/22/08
Signature of Reviewer	Agency/Office/Phone and Fax Numbers	Date

