

ADEQ

ARKANSAS
Department of Environmental Quality

June 8, 2010

Darrell Phillips, Assistant General Manager
Paragould Light, Water, and Cable
P.O. Box 9
Paragould, AR 72450

RE: Paragould Light, Water and Cable WWTP – “Station B”

AFIN: 28-00060 NPDES Permit No.: AR0033766

Dear Mr. Phillips:

On May 18, 2010, at your request, I performed a compliance assistance inspection of waste water pumping “Station B” in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. Based on my observations at the time of the inspection, the current practice of drying solids (grease, plastics, rags, etc.) using the existing drying beds at Station B is acceptable provided that the drying beds continue to drain back into the collection system, there is no run-on/run-off of stormwater and all solid wastes are properly disposed of at an approved facility.

If I can be of any assistance, please contact me at walker@adeq.state.ar.us or 870-935-7221 ext.-12.

Sincerely,



Brent L. Walker
District 3 Field Inspector
Water Division

cc: Water Division Enforcement Branch
 Water Division Permits Branch



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Washington, D.C. 20460

Form Approved
OMB No. 2040-0003

NPDES Compliance Inspection Report

Section A: National Data System Coding

Transaction Code	NPDES	Yr/Mo/Day	Inspec. Type	Inspector	Fac. Type
1 N 2 5 3 A R 0 0 3 3 7 6 6 11 12 1 0 0 5 1 8 17 18 H 19 S 20 1	Remarks				
Inspection Work Days		Facility Evaluation Rating		BI QA -----Reserved-----	
67 69		70 N		71 N 72 N 73 74 75 80	

Section B: Facility Data

Name and Location of Facility Inspected (<i>For industrial users discharging to POTW, also include POTW name and NPDES permit number</i>) Paragould Light, Water and Cable WWTP 401 Grant Ln. Paragould, AR Greene Co.	Entry Time/Date 1315 5/18/2010	Permit Effective Date 2/1/2010
Name(s) of On-Site Representative(s)/Title(s)/Phone and Fax Number(s) Darrell Phillips/Assistant General Manager/870-239-7700 Lisa Ellington/Manager – Env. Services/870-239-7795 Mark Mullins/Manager – Water/Sewer Division/870-239-7764 Jim McDaniel/Collection System Supervisor	Exit Time/Date 1330 5/18/2010	Permit Expiration Date 1/31/2015
Name, Address of Responsible Official/Title/Phone and Fax Number Darrell Phillips/Assistant General Manager/870-239-7700 Paragould Light, Water and Cable P.O. Box 9 Paragould, AR 72450	Contacted Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Other Facility Data

Section C: Areas Evaluated During Inspection

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

N	Permit	N	Flow Measurement	S	Operations & Maintenance	N	Sampling
N	Records/Reports	N	Self-Monitoring Program	N	Sludge Handling/Disposal	N	Pollution Prevention
N	Facility Site Review	N	Compliance Schedules	N	Pretreatment	N	Multimedia
N	Effluent/Receiving Waters	N	Laboratory	N	Storm Water	S	Other: Solids Management

Section D: Summary of Findings/Comments (Attach additional sheets if necessary)

This compliance assistance inspection was conducted at the request of Darrell Phillips/Assistant General Manager to evaluate the removed solids management practices at pump Station B.

Based on observations at the time of the inspection, the current practice of drying solids (grease, plastics, rags, etc.) using the existing drying beds at Station B is acceptable provided that the drying beds continue to drain back into the collection system, there is no run-on/run-off of stormwater and all solid wastes are properly disposed of at an approved facility.

Name(s) and Signature(s) of Inspector(s) Brent L. Walker <i>Brent L. Walker</i>	Agency/Office/Telephone/Fax AR Dept. of Environmental Quality-Jonesboro (870) 935-7221 ext. 12/(870) 935-4715 (Fax)	Date May 28, 2010
Signature of Reviewer	Agency/Office/Phone and Fax Numbers	Date