

March 23, 2011

Ken Johnson, Manager Pine Bluff Wastewater Utility 1520 South Ohio Street Pine Bluff, Arkansas 71601-6055

RE: Wastewater Treatment System

AFIN: 35-00149 NPDES Permit No.: AR0033316

Dear Mr. Johnson:

On March 2, 2011, I conducted a routine compliance inspection of the wastewater treatment facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. At the time of inspection, the facility appeared to be in compliance with the applicable regulations.

If I can be of any assistance, please contact me at (870) 247-5155.

Loudesser

Sincerely,

Steven L. Henderson District 6 Inspector

Water Division

cc: Water Division Enforcement Branch

Water Division Permits Branch

≎ EPA									Form Approved OMB No. 2040-0003											
		UNIT	ED STA	ES ENVI	IRONME	ENTAL P	ROTECTI	ION AGE	NCY											
Washington, D.C. 20460 NPDES Compliance Inspection Report																				
	NPDE	<u> </u>	ZOIII	pna																
						Section	A: Nati	ional D	ata S	ystem Codi										
1	N 2 5 3 A R 0 0 3 3 1 6 11 12 1 1 0 3 0 2 17 18							c C	19	Inspect S	or F	ac. Type								
								Rema	rks											
	Inspection Work Days 67 69]	Facility 70	Evalua 3	tion Ra	ating	71	BI I N	72	QA N 73			74	 75	<u>:</u>	Reserved-				80
							Section	n B: Fa	cility	Data										
	ne and Location of Facility Inspected			ial user	rs disc	harging	g to PO	TW, als	o	Entry Tin			2011			Permit E	Effecti	ive Dat	e	
City	ude POTW name and NPDES permit of Pine Bluff Wastewater Utility - A	Boyd	Point T			cility				~8:30 a.n	ı.	3/2/2	2011			Septemb	er 1,	2009		
	niles from Highway 79 on Island H Island Harbor Marina Road	arboi	r Marin	a Road	Į.					Exit Time		2/2/2	011			Permit Expiration Date				
	ion 22, Township 5 South, Range 9 erson County, Arkansas	West	!							~1:00 p.n	ι.	3/2/2	011			August 31, 2014				
	ne(s) of On-Site Representative(s)/Ti						(2 (2 T			•					Oth	Other Facility Data				
	cent Miles, Laboratory Supervisor cey Carpenter, Senior Lab Technicio	,	370) 535	-0828	(870	V) 535-0	6243 Fa	ıx		_						34 16' 17.89				
	ne, Address of Responsible Official/ Johnson, Manager		Phone a		Numb	er									W^{g}	01 58' 21	17"			
Pine	e Bluff Wastewater Utility	(076)) 333-0	1003							Conta	acted	_							
	0 South Ohio Street e Bluff, Arkansas 71601-6055									Yes		No								
					Sect	tion C:	Areas l	Evalua	ted D	l uring Inspe	ection									
~		~	(S	= Satis	factory	y, M = 1	Margina	- T	Unsat	isfactory, N	= Not	Evalı	iated)		~					
S	Permit	S	┥	Measu				S	1 ^	Operations & Maintenance S			Samplin	_						
S	Records/Reports	S N	i		Ü	rogran 	n	S N	1	idge Handling/Disposal			N	Y Ondion Trevendon						
S	Facility Site Review	S	i	pliance	Scheo	dules		N	1	circument			N Multimedia S Other: Effluent Limits							
	Effluent/Receiving Waters			ratory : Sumi	mary o	of Findi	ings/Co			rm Water tach additio	onal sh	ieets i	if nec	essary		Other:	cillue	ent Lin	ints	
	A routine inspection	wa	s cor	duct	ted to	o dete	ermin	1е со	mpl	iance st	atus	wit	h th	e A	rkai	nsas W	ate	r and	l Air	
	Pollution Control Act,									_			_		_			der.	At th	e
	time of inspection, the facility appeared to be in compliance with the applicable regulations.																			
Name(s) and Signature(s) of Inspector(s)					_	cy/Offic				(0 5 0) -	15.5	105			Date		•			
S	Ten J. Hondercar Steven L. Her	<u>ide</u> rse	on_			ADEQ	_/ White	e Hall/	(870) 	247-5155/	(870) 2	47-51	185			March 3	5, 201			
Sig	nature of Reviewer		_	_		Agency/Office/Phone and Fax Numbers					Date									

ADEQ Water NPDES Inspection	AFIN: 35-00149	Permit #: AR0033316

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	☑S □M □U □NA □NE
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	☑y □n □na □ne
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	□y □n ☑na □ne
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	☑Y ☐N ☐NA ☐NE
4. ALL DISCHARGES ARE PERMITTED:	☑Y ☐N ☐NA ☐NE
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	☑S □M □U □NA □NE
DETAILS:	
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	☑Y ☐N ☐NA ☐NE
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	⊠s □m □u □na □ne
a. DATES AND TIME(S) OF SAMPLING:	☑y □n □na □ne
b. EXACT LOCATION(S) OF SAMPLING:	☑y □n □na □ne
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	☑Y □N □NA □NE
d. ANALYTICAL METHODS AND TECHNIQUES:	☑Y □N □NA □NE
e. RESULTS OF CALIBRATIONS:	☑Y □N □NA □NE
f. RESULTS OF ANALYSES:	☑y □n □na □ne
g. DATES AND TIMES OF ANALYSES:	☑y □n □na □ne
h. NAME OF PERSON(S) PERFORMING ANALYSES:	☑Y □N □NA □NE
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	Øs □m □u □na □ne
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	ØS □M □U □NA □NE
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	☑y □n □na □ne
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	☑S □M □U □NA □NE
DETAILS:	
1. TREATMENT UNITS PROPERLY OPERATED:	⊠s □m □u □na □ne
2. TREATMENT UNITS PROPERLY MAINTAINED:	⊠s □m □u □na □ne
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	⊠s □m □u □na □ne
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	⊠s □m □u □na □ne
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	⊠s □m □u □na □ne
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	⊠s □m □u □na □ne
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	⊠s □m □u □na □ne
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	□y □n ☑na □ne
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	☑Y □N □NA □NE
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	☑Y □N □NA □NE
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:	□Y ☑N □NA □NE
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	□Y □N ☑NA □NE
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	□y □n ☑na □ne
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	□Y ☑N □NA □NE
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:	□Y □N ☑NA □NE

ADEQ Water NPDES Inspection	AFIN: 35-00149	Permit #: AR0033316

SE	SECTION D: SAMPLING							
	ERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS		ØS □M □U □NA □NE					
DE	ETAILS:							
1.	SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:		☑Y □N □NA □NE					
2.	LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:		☑Y □N □NA □NE					
3.	FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:		☑Y □N □NA □NE					
4.	SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:		☑Y □N □NA □NE					
5.	SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:		☑Y □N □NA □NE					
6.	SAMPLE COLLECTION PROCEDURES ADEQUATE:		☑Y □N □NA □NE					
а	i. SAMPLES REFRIGERATED DURING COMPOSITING:		☑Y □N □NA □NE					
b	. PROPER PRESERVATION TECHNIQUES USED:		☑Y □N □NA □NE					
С	: CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:		☑Y □N □NA □NE					
7.	IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMI	₹:	□Y □N ☑NA □NE					
SE	ECTION E: FLOW MEASUREMENT							
PE	ERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS		☑S □M □U □NA □NE					
DE	ETAILS:							
1.	PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: TYPE OF DEVICE::	2' Parshall Flume	Y □N □NA □NE					
2.	FLOW MEASURED AT EACH OUTFALL AS REQUIRED:		⊠y □n □na □ne					
3.	SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINE	D:	⊠y □n □na □ne					
4.	CALIBRATION FREQUENCY ADEQUATE:		⊠y □n □na □ne					
5.	RECORDS MAINTAINED OF CALIBRATION PROCEDURES:		⊠y □n □na □ne					
6.	CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:		⊠y □n □na □ne					
7.	FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:		⊠y □n □na □ne					
8.	FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:		⊠y □n □na □ne					
9.	HEAD MEASURED AT PROPER LOCATION:		⊠y □n □na □ne					
SE	ECTION F: LABORATORY							
	ERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREME	NTS	☑S □M □U □NA □NE					
DE	ETAILS:							
1.	EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES)	:	☑y □n □na □ne					
2.	IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:		□Y □N ☑NA □NE					
3.	SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:		☑Y □N □NA □NE					
4.	QUALITY CONTROL PROCEDURES ADEQUATE:		☑Y □N □NA □NE					
5.	DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:		☑Y □N □NA □NE					
6.	SPIKED SAMPLES ARE ANALYZED ≥10% OF THE TIME:		⊠y □n □na □ne					
7.	COMMERCIAL LABORATORY USED:		☑Y □N □NA □NE					
а	a. LAB NAME: Environmental Testing & Consulting, Inc. American Interplex							
b	b. LAB ADDRESS: 2790 Whitten Road, Memphis, Tennessee 38133-4753 8600 Kanis Road, L	ittle Rock, Arkar	nsas 72204					
С	: PARAMETERS PERFORMED: Biomonitoring Nitrite plus Nitrate I	Nitrogen, Total P	Phosphorus					
8.	BIOMONITORING PROCEDURES ADEQUATE:		☑y □n □na □ne					
а	i. PROPER ORGANISMS USED:		⊠y □n □na □ne					
b). PROPER DILUTION SERIES FOLLOWED:		☑Y □N □NA □NE					
С	. PROPER TEST METHODS AND DURATION:		☑Y □N □NA □NE					
d	I. RETESTS AND/OR TRE PERFORMED AS REQUIRED:		Øy □n □na □ne					

ADEQ Water NPDES Inspection	AFIN: 35-00149	Permit #: AR0033316

			11/21/21/21		000000	2110			
			= =	= =	OBSERVATION	ONS			
BA	ASED ON	N VISUAL OBS	ERVATIONS C	DNLY				□U □NA ☑NE	
DE	ETAILS:	No Discharge)						
O	JTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER	
	001								
SE	SECTION H: SLUDGE DISPOSAL								
SL	UDGE D	DISPOSAL MEI	ETS PERMIT F	REQUIREMEN	TS		⊠s □m	□U □NA □NE	
DE	TAILS:								
1.	SLUDGE M	IANAGEMENT ADEQU	ATE TO MAINTAIN EF	FLUENT QUALITY:			⊠s	□M □U □NA □NE	
2.	SLUDGE R	ECORDS MAINTAINE	D AS REQUIRED BY 4	0 CFR 503:			□s	□M □U ☑NA □NE	
3.	FOR LAND	APPLIED SLUDGE, T	YPE OF LAND APPLIE	D TO: (E.G., FOREST	, AGRICULTURAL, PUI	BLIC CONTACT SITE):			
SE	CTION	I: SAMPLIN	G INSPECTION	ON PROCED	URES				
SA	MPLE F	RESULTS WITH	HIN PERMIT R	EQUIREMENT	ΓS		□s □m	□U □NA ☑NE	
DE	ETAILS:					<u>.</u>			
1.	SAMPLES	OBTAINED THIS INSP	ECTION:					□Y □N □NA ☑NE	
2.	TYPE OF S	AMPLE: GRAB:	□COMPOSITE: N	METHOD: FREQUE	ENCY:				
3.	SAMPLES	PRESERVED:						□Y □N □NA ☑NE	
4.	FLOW PRO	PORTIONED SAMPLE	S OBTAINED:					□y □n □na ☑ne	
5.	SAMPLE O	BTAINED FROM FACI	LITY'S SAMPLING DE\	/ICE:				□Y □N □NA ☑NE	
6.	SAMPLE R	EPRESENTATIVE OF	VOLUME AND NATUR	E OF DISCHARGE:				□Y □N □NA ☑NE	
7.	SAMPLE S	PLIT WITH PERMITTE	E:					□Y □N □NA ☑NE	
8.	CHAIN-OF-	CUSTODY PROCEDU	RES EMPLOYED:					□Y □N □NA ☑NE	
9.	SAMPLES	COLLECTED IN ACCO	RDANCE WITH PERM	IT:				□y □n □na ☑ne	
SE	CTION	J: STORM V	WATER POLI	UTION PRE	VENTION PLA	AN			
ST	ORM W	ATER MANAG	EMENT MEET	S PERMIT RE	QUIREMENTS	3	□s □m	□U □NA ☑NE	
DE	ETAILS:	No exposure	status			<u>.</u>			
1.		PDATED AS NEEDED:		DATE:				□Y □N □NA ☑NE	
2.	SITE MAP	INCLUDING ALL DISC	HARGES AND SURFA	CE WATERS:				□Y □N □NA ☑NE	
3.								□Y □N □NA ☑NE	
4.	. POLLUTION PREVENTION TEAM PROPERLY TRAINED:							□Y □N □NA ☑NE	
5.	LIST OF POTENTIAL POLLUTANT SOURCES:								
6.	S. LIST OF POTENTIAL SOURCES AND PAST SPILLS AND LEAKS:								
7.	7. ALL NON-STORM WATER DISCHARGES ARE AUTHORIZED:								
8.	8. LIST OF STRUCTURAL BMPS:								
9.	LIST OF NO	ON-STRUCTURAL BMF	PS:					□Y □N □NA ☑NE	
10.	0. BMPS PROPERLY OPERATED AND MAINTAINED:								
11.	11. INSPECTIONS CONDUCTED AS REQUIRED:								

FLOW CALCULATION SHEET								
Date:	3/2/2011	Time:						
		-						
Head in	Inches:	Feet:						
Type &	Size of Primary	Flow Measureme	nt Device: 2	?' Parshal	I Flume			
Nama 8	Model of Secon	ndary Flow Measu	irement Dev	ica: ISC	O 2410			
Name 6	e inioder of occor	idary i low ivicaso	ilement Dev	100. 100	JO 2410			
Date of	last Calibration	of Secondary Flov	v Device: Ap	oril 10, 20	10			
Recorde	ed Flow at Date	& Time Listed Abo	ove:		(Facility Flow Mete	er)		
Calavila	to d Flow at Data	O Time o Linto d Ale						
		& Time Listed Ab		ement Handh	200k-5 th Edition			
(Flow is ca	iculated using now cha	rts III. 1300 Open Chan	inei Flow Measur	ement Handt	DOOK-3 Edition)			
0/ F	Recorded \	/alue - Calcul	ated Value	V 400				
% Error	=	Calculated Value		X 100				
% Error	_	-		X 100				
70 E1101	_			X 100				
% Error	=	X 100						
% Error = X 100								
75 2.15.								
% Error	=	%						
Comments: At the time of inspection, the facility did not have an effluent discharge. Therefore, a calculation check was not conducted.								
	discharge	e. Therefore, a ca	aiculation c	neck was	s not conducted.			

DMR Calculation Check

Reporting Period: From 2011 01 01 To 2011 01 31 Year Month Day Year Month Day

Parameter Checked: TSS

	Loading Mass	Concentration Monthly				
	Mo. Avg lbs/day	Mo. Avg mg/l	7-day Avg mg/l			
Reported Value:		63	65			
Calculated Value:		63	65			
Permit Value:		90	135			

If calculated value does not equal reported value, explain: EQUAL