

November 8, 2011

Tommy Lawson, Manager City of Stuttgart Water Utilities P.O. Box 130 Stuttgart, Arkansas 72160

RE: Sanitary Sewer Collection System

AFIN: 01-00041 NPDES Permit No.: AR0034380

Dear Mr. Lawson:

On November 2, 2011, I conducted a Sanitary Sewer Overflow Inspection of the above referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. At the time of inspection, the system appeared to be in compliance with the applicable regulations.

If I can be of any assistance, please contact me at (870) 247-5155 or e-mail at Henderson@adeq.state.ar.us.

Sincerely,

Steven L. Henderson District 6 Inspector Water Division

,, 6001 21,151011

cc: Water Division Enforcement Branch Water Division Permits Branch

≎ EPA							Form Approved OMB No. 2040-0003													
		UNIT	ED STATES 1				N AGEN	ICY												
	NPDES Compliance Inspection Report																			
				:	Section A	: Natio	nal Da	ıta Sy	stem Codi	ng										
1	Transaction Code NPDES Yr/Mo/Day Insp I N 2 5 3 A R 0 0 3 4 3 8 0 11 12 1 1 1 1 0 2 17 18						vec. Ty	ype	Insp	ecto S	r F	ac. Type								
Ĺ	Remarks																			
	Inspection Work Days	I	Facility Eva	Ī	ating		BI I I		QA 	 I	 I I		 	F 	Reserv	ed	 	I	I	
	67 69		70	N		71	N	72	N 73		Ш	74	75							80
						ection l								1						
incli City	ne and Location of Facility Inspected ade POTW name and NPDES permi Tof Stuttgart Water Utilities			users disc	charging t	o POTV	V, also		Entry Tim 9:00 a.m.		te 1/2/20	11					fective ler 1, 20			
Stut	South College tgart, Arkansas 72160 ansas County, Arkansas								Exit Time 11:30 a.m			11					piratior 1, 2014		e	
	Name(s) of On-Site Representative(s)/Title(s)/Phone and Fax Number(s) Danny Wilson, Head Wastewater Operator (870) 674-4819 Other Facility Data PDS# 062150																			
Ton City P.O	Name, Address of Responsible Official/Title/Phone and Fax Number Tommy Lawson, Manager (870) 674-7115 City of Stuttgart Water Utilities P.O. Box 130 Stuttgart, Arkansas 72160 Contacted Yes No																			
	Section C: Areas Evaluated During Inspection																			
S		N				arginal,	$\mathbf{U} = \mathbf{U}$		sfactory, N					N						
S	Permit	N		easureme			N	•	erations &				-	N N	Samp					
S	Records/Reports Facility Site Review	N		nitoring l ince Sche	_		N		dge Handli treatment	ing/Di	isposa	I	-	N	Pollution Prevention Multimedia					
N	Effluent/Receiving Waters	N	Laborat		uuies		N		rm Water				-	N	Othe		ıa			
	Emucing Receiving Waters	Se		•	of Findin	gs/Com	ments		ach additio	onal s	heets i	f nece	ssary))	Othe					
At the time of inspection, the sanitary sewer collection system appeared to be in compliance with the applicable regulations.																				
Name(s) and Signature(s) of Inspector(s) Storen J. Houderson Steven L. Henderson				Agency. ADEQ/				Fax 247-5155 /	(870)	247-5	185			Date November 3, 2011						
Sim	nature of Reviewer				Agency	v/Office	/Phone	e and	Fax Numbe	ers					Date	<u> </u>				
Jig!	Signature of Reviewer Agency/Office/Phone and Fax Numbers Date																			

ADEQ Water NPDES Inspection	AFIN: 01-00041	Permit #: AR0034380

COLLECTION SYSTEM INSPECTION AND OVER	RALL RATING	Øs	□м	□u	□NA	□NE
PROVIDE A BRIEF DESCRIPTION OF THE COLLECTION SYSTEM:						
Gravity Flow > 17 secondary pump stations > 3 primary pump stations > WWTP pump station POPULATION SERVED/NUMBER OF RESIDENTIAL AND COMMERCIAL CONNECTIONS:						
Population = 9,500/ 3,854 residential/ 563 commercial						
FEET OF SEWER SYSTEM: approximately 63 miles	station FO latast		- 4- 10	/\A/TD	2002	
AGE OF SYSTEM: Some lines as old as 80 years, oldest p 2009 construction was completed on 2.5 miles of new for	ce main	upaaı				
DOES THE SYSTEM EXPERIENCE PROBLEMS DURING DESCRIPTION (EXPLAIN): Infiltration during heavy rainfall events	DRY OR WET WEATHER		ØY	□N	□NA	□NE
IS THERE A SYSTEM IN PLACE FOR REPORTING SSOS Monthly SSO Reports are submitted with DMR's		ØY	□N	□NA	□NE	
ARE ALL SSOs REPORTED REGARDLESS OF SIZE:			ØY	□N	□NA	□NE
HAVE SSOs REACHED "WATERS OF THE U. S." (LIST DA	HAVE SSOs REACHED "WATERS OF THE U. S." (LIST DATE AND LOCATION OF EACH):					□NE
PUMP STATIONS		Øs	□м	□u	□NA	□NE
NUMBER OF PUMP STATIONS IN SYSTEM: 20 NUMBER WITH BACKUP POWER: 20						
HOW OFTEN ARE PUMP STATIONS INSPECTED/MONITORED: Daily						
ARE MAINTENANCE RECORDS AND/OR OPERATOR LOGS KEPT: Yes						
ADEQUATE INVENTORY OF SPARE PARTS: Yes	ADEQUATE INVENTORY OF SPARE PARTS: Yes					
TYPE OF REMOTE ELECTRONIC MONITORING USED (I.E. SCADA OR AUTO DIALERS): SCADA (McCracken only)						only)
BRIEF SUMMARY OF EMERGENCY PROCEDURES: Portable generators are available for pump stations, Permanent generators are available at the WWTP						
NUMBER OF PUMP STATIONS VISITED DURING INSPEC	TION (SEE ATTACHED CHEC	KLIST	S FOF	R EAC	CH): 2	
SATELLITE SYSTEMS		□s	□м	□U	ØNA	□NE
DOES THE COLLECTION SYSTEM RECEIVE FLOW FROM SATELLITE SYSTEMS:						
TYPE(S) OF WASTE WATER RECEIVED:_ □RESIDENTIAL □COMMERCIAL □INDUSTRIAL □OTHER:						
BRIEFLY DESCRIBE THE SATELLITE SYSTEM:						
ANY KNOWN PROBLEMS WITH SATELLITE SYSTEM:						
NAME, ADDRESS AND PHONE NUMBER OF PERSON RE	SPONSIBLE FOR SATELLITE	SYST	EM:			
			_			

ADEQ Water NPDES Inspection	AFIN: 01-00041	Permit #: AR0034380

PUMP STATION VISIT (COMPLETE A SEPARATE	CHECKLIST FOR EACH PU	MP STATION VISITED)
GENERAL INFORMATION AND OVERALL EVAL	.UATION	⊠S □M □U □NA
NAME AND/OR LOCATION OF PUMP STATION: 13th Street Pump Station		
TYPE(S) OF WASTE WATER RECEIVED: ☑RESIDENTIAL	☑COMMERCIAL □INDUSTRIA	AL DOTHER:
NUMBER OF PUMPS: 3	NUMBER OPERATIONAL: 2	
NUMBER AND SIZE OF PUMPS APPEARS ADEQUATE:		☑S □M □U □NA □NE
EVIDENCE OF RECENT OVERFLOWS OR HIGH LEVELS:		□Y ØN □NA □NE
GENERAL OPERATION AND MAINTENANCE		⊠S □M □U □NA
CLEAN AND WELL MAINTAINED WITH MINIMAL STORAG EQUIPMENT:	E OF UNRELATED	☑S ☐M ☐U ☐NA ☐NE
GATES/DOORS/HATCHES/LIDS/ETC. LOCKED TO PREVE ACCESS AND/OR TAMPERING:		ØS □M □U □NA □NE
WET WELLS, SUMPS AND PITS ADEQUATELY COVERED PROTECTED:	•	⊠S □M □U □NA □NE
ELECTRICAL CONTROLS COVERS CONDUIT AND EQUIP INSTALLED AND MAINTAINED:		☑S □M □U □NA □NE
GUARDS AND SHIELDS IN PLACE AROUND MOVING EQUIDRIVESHAFTS, ETC.) :	,	☑S □M □U □NA □NE
ADEQUATE VENTILATION TO PREVENT EXCESSIVE COL GASES AND FUMES:	NDENSATION AND/OR	☑S □M □U □NA □NE
ADEQUATE LIGHTING FOR ROUTINE INSPECTION/MAIN	TENANCE:	☑S □M □U □NA □NE
SEALS, VALVES AND PACKING ADEQUATELY MAINTAIN	ED TO PREVENT LEAKS:	☑S □M □U □NA □NE
MINIMAL ACCUMULATION OF GREASE AND SOLIDS IN V	VET WELLS:	☑S □M □U □NA □NE
BACKUP POWER AND ALARMS		⊠S □M □U □NA
PROVISIONS FOR GENERATOR AND/OR EMERGENCY T	RANSEER DIIMD:	ØS DM DU DNA DNE
AUDIBLE/VISUAL ALARM WITH EMERGENCY CONTACT I		ØS □M □U □NA □NE
	INFORMATION POSTED.	
SCADA SYSTEM (LIST PARAMETERS MONITORED):		□Y ☑N □NA □NE

ADEQ Water NPDES Inspection AFIN: 01-00041 Permit #: AR0034380			
	ADEQ Water NPDES Inspection	AFIN: 01-00041	Permit #: AR0034380

PUMP STATION VISIT (COMPLETE A SEPARATE CHECKLIST FOR EACH PUMP STATION VISITED)					
GENERAL INFORMATION AND OVERALL EVAL	LUATION	☑S □M □U □NA			
NAME AND/OR LOCATION OF PUMP STATION: McCracken Pump Station					
TYPE(S) OF WASTE WATER RECEIVED: MRESIDENTIAL	. □COMMERCIAL □INDUSTRIA	AL OTHER:			
NUMBER OF PUMPS: 2	NUMBER OPERATIONAL: 2				
NUMBER AND SIZE OF PUMPS APPEARS ADEQUATE:		ØS DM DU DNA DNE			
EVIDENCE OF RECENT OVERFLOWS OR HIGH LEVELS:		□Y ØN □NA □NE			
GENERAL OPERATION AND MAINTENANCE		☑S □M □U □NA			
CLEAN AND WELL MAINTAINED WITH MINIMAL STORAG EQUIPMENT:		⊠S □M □U □NA □NE			
GATES/DOORS/HATCHES/LIDS/ETC. LOCKED TO PREVE ACCESS AND/OR TAMPERING:	ENT UNAUTHORIZED	ØS OM OU ONA ONE			
WET WELLS, SUMPS AND PITS ADEQUATELY COVERED PROTECTED:		☑S □M □U □NA □NE			
ELECTRICAL CONTROLS COVERS CONDUIT AND EQUIP INSTALLED AND MAINTAINED:		⊠S □M □U □NA □NE			
GUARDS AND SHIELDS IN PLACE AROUND MOVING EQUIDRIVESHAFTS, ETC.):	UIPMENT (BELTS, PULLEYS,	☑S □M □U □NA □NE			
ADEQUATE VENTILATION TO PREVENT EXCESSIVE COL GASES AND FUMES:	NDENSATION AND/OR	⊠S □M □U □NA □NE			
ADEQUATE LIGHTING FOR ROUTINE INSPECTION/MAIN	TENANCE:	☑S □M □U □NA □NE			
SEALS, VALVES AND PACKING ADEQUATELY MAINTAIN	ED TO PREVENT LEAKS:	ØS OM OU ONA ONE			
MINIMAL ACCUMULATION OF GREASE AND SOLIDS IN V	VET WELLS:	☑S □M □U □NA □NE			
BACKUP POWER AND ALARMS		☑S □M □U □NA			
PROVISIONS FOR GENERATOR AND/OR EMERGENCY T	RANSFER PUMP:	☑S □M □U □NA □NE			
AUDIBLE/VISUAL ALARM WITH EMERGENCY CONTACT	INFORMATION POSTED:	☑S □M □U □NA □NE			
SCADA SYSTEM (LIST PARAMETERS MONITORED): Hi/L	o levels, power outage	☑Y □N □NA □NE			