

<h1 style="margin:0;">ADEQ</h1> <p style="margin:0; font-weight: normal;">A R K A N S A S Department of Environmental Quality</p>	WATER DIVISION INSPECTION REPORT				
	AFIN: 35-00149	PERMIT #: AR0033316	DATE: 12/9/2014		
	COUNTY: 35 Jefferson	PDS #: 081743	MEDIA: WN		
	GPS LAT: 34.256850 LONG: -92.053332 LOCATION: Entrance				
FACILITY INFORMATION		INSPECTION INFORMATION			
NAME: KisWire LOCATION: 5100 Industrial Drive South CITY: Pine Bluff, AR		FACILITY TYPE: 2 - Industrial INSPECTOR ID#: 26075 S - State FACILITY EVALUATION RATING: 3 - Satisfactory INSPECTION TYPE: Industrial User			
RESPONSIBLE OFFICIAL		DATE(S): 12/9/2014 ENTRY TIME: 13:45 EXIT TIME: 14:30 PERMIT EFFECTIVE DATE: 9/1/2009 PERMIT EXPIRATION DATE: 8/31/2014			
NAME / TITLE: Mike Barrett, / EHS Manager COMPANY: KisWire MAILING ADDRESS: 5100 Industrial Drive South CITY, STATE, ZIP: Pine Bluff, AR 71602 PHONE & EXT: / FAX: / EMAIL:		INSPECTION PARTICIPANTS			
CONTACTED DURING INSPECTION: Yes		NAME/TITLE/PHONE/FAX/EMAIL/ETC.: Vincent Miles, PBWW			
AREA EVALUATIONS					
(S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)					
N	PERMIT	N	FLOW MEASUREMENT	N	STORMWATER
N	RECORDS/REPORTS	N	LABORATORY	S	FACILITY SITE REVIEW
S	OPERATION & MAINTENANCE	N	EFFLUENT/RECEIVING WATER	S	SELF-MONITORING PROGRAM
S	SAMPLING	N	SLUDGE HANDLING/DISPOSAL	S	PRETREATMENT
S	OTHER: Industrial User				
SUMMARY OF FINDINGS					
GENERAL COMMENTS					
An Industrial User site visit was conducted at the KisWire facility in Pine Bluff, AR. The facility has a continuous flow system consisting of collection points for acidic and cyanide bearing waste. They have treatment tanks for cyanide destruction. They have neutralization and metal precipitation tanks. They have flocculation equipment. The system also has sludge separation and handling equipment including two clarifiers, sludge thickener, and a filter press. At the time of the visit, no environmental issues were observed.					
INSPECTOR'S SIGNATURE: <i>Steven L. Henderson</i>				DATE: 1/8/2015	
SUPERVISOR'S SIGNATURE: <i>Kerri McCabe</i>				DATE: 1/9/2015	

POTW Pretreatment Program

Industrial Site Visit

Name of Industry: KisWire

Industry Contacts: Mike Barrett, EHS Manager

Type of Industry: Steel Wire Manufacturer

Date of Visit: December 9, 2014

- | | | | |
|--|----------------|-------------|-------------------------|
| 1. Significant industrial user: | <u> X </u> Yes | <u> </u> No | <u> </u> Not Determined |
| 2. Pretreatment equipment or procedures? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 3. Pretreatment equipment maintained and operational? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 4. Hazardous waste generated or stored? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 5. Proper solid waste disposal? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 6. Solvent management/TTO control? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 7. Suitable sampling location? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 8. Appropriate self-monitoring procedures / equipment? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 9. Adequate spill prevention? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 10. Industry familiar with limits and requirements? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |

Additional Comments: None

Visit Conducted By: Steven L. Henderson Date: January 8, 2015