

July 9, 2015

Steve Dufresne, Van Buren Municipal Utilities PO Drawer 1269 Van Buren, AR 72956

RE: City of Van Buren WWTP - Main Inspection (Crawford Co)

AFIN: 17-00062 NPDES Permit No.: AR0021482

ARR000413

Dear Mr. Dufresne:

On June 25, 2015 I performed a Compliance Evaluation Inspection, a Collection System Inspection, and an Industrial Stormwater Inspection of the above-referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. Copies of the inspection reports are enclosed for your records.

Please refer to the "Summary of Findings" section of each of the attached inspection reports and provide a written response for each violation that was noted. This response should be mailed to the attention of the Water Division Inspection Branch at the address at the bottom of this letter or e-mailed to Water-Inspection-Report@adeq.state.ar.us. This response should contain documentation describing the course of action taken to correct each item noted. This corrective action should be completed as soon as possible, and the written response with all necessary documentation (i.e. photos) is due by July 23, 2015.

If I can be of any assistance, please contact me at grayd@adeq.state.ar.us or (479) 424-0333.

Sincerely,

Dannielle Gray
District 4 Field Inspector
Water Division

cc: James Dunn, Chief Plant Operator, City of Van Buren, jodmsd@yahoo.com

	ADEO		WATER	DIVISION I	NSP	ECTION	N REI	PORT
	ADLU	AF	IN: 17-00062	PERMIT #: AR002 1	1482		DATE: 6	/25/2015
ARKANSAS			OUNTY: 17 Craw	/ford	PDS :	#: 085107		MEDIA: WN
Dep	partment of Environmental Quality	GF	'S LAT: 35.4189	36 LONG: -94.338	544 L	OCATION: E	ntrance	
FACILITY INFORMATION				IN	SPEC	TION INFOR	MATION	ı
Cit	y of Van Buren WWTP - Main			FACILITY TYPE: 1 - Municipal		30 S - State		
	01 Port Road			3 - Satisfactory				Evaluation
Va	n Buren, AR				1TRY TIME: 9:30	13:30		FECTIVE DATE:
	RESPONSIBLE OFFIC	CIAL		0/23/2013	3.30	13.30	1/1/20 PERMIT EXI	115 PIRATION DATE:
	: / TITLE						12/31/	2019
Steve Dufresne /			FAYETTEVILLE SHALE RELATED: N					
Va	n Buren Municipal Utilities							
MAILI	NG ADDRESS:			FAYETTEVILLE SHALE VIOLATIONS: N				
	Drawer 1269			INSPECTION PARTICIPANTS NAME/TITLE/PHONE/FAX/EMAIL/ETC:				
	state, zip: n Buren AR 72956			James Dunn, Chief Plant Operator, 479-474-5067				
	IE & EXT: / FAX:			Kerri McCabe, I				
479	9-474-5067 /			Cody Wallace, V				
EMAI								
	ve@vbmu.arcoxmail.com NTACTED DURING INSPECTION:	Var						
CC	INTACTED DURING INSPECTION.	16		ALLIATIONO				
	(S=S	atisfac		ALUATIONS atisfactory, N=Not Applicable	/Evaluated)		
S	PERMIT	S	FLOW MEASL		S	STORMWA	TER	
S	RECORDS/REPORTS	S	LABORATORY	/	М	FACILITY S	SITE RE	VIEW
S	OPERATION & MAINTENANCE	S	EFFLUENT/RE	CEIVING WATER	S	SELF-MON	IITORIN	G PROGRAM
S	SAMPLING	S	SLUDGE HAN	DLING/DISPOSAL	**	PRETREAT	MENT	
**	OTHER:				•	•		

The following violation was noted during inspection:

1. All systems of treatment and control used by the permittee to achieve compliance are not being properly operated and maintained, violating Part III, Section B.1 of the permit. Specifically, the following items need to be addressed:

SUMMARY OF FINDINGS

- a. The refrigerator located at the "dog house" is not operational. See additional information in "General Comments" below.
- b. Trash associated with wastewater (i.e., tampon applicators and miscellaneous trash) are making their way past the bar screen and collecting along the edges of the pond.

GENERAL COMMENTS

I inspected this facility with the above-referenced participants on June 25, 2015. Inspection included a facility assessment, records audit, industrial stormwater No-Exposure verification, and a collection system assessment.

Inspection began with a facility assessment. Treatment includes an influent bar screen with an auto clean feature, an activated sludge pond, an equalization pond, final clarifiers, and UV disinfection. Bar Screen appeared to be functioning properly. I observed sewage-related waste (i.e., plastic tampon applicators, miscellaneous trash, etc.) in the pond. The Operator informed that some of the material occasionally gets past the screens. I also noted some of this waste in the clarifiers. I did not observe the waste in the effluent.

The plant has a single pond that serves as their activated sludge track, equalization pond, and waste sludge pond. The three sections are divided by curtains. Activated sludge occurs on the north/northwest portion of the pond, equalization occurs on the centermost portion of the pond, and waste sludge storage occurs on the south/southeast portion of the pond (see Figure 2). According to the Operator, when the activated sludge system needs "bugs," they pull water from the equalization pond to add them. The Operator informed that they rarely have to waste sludge; but when they do, it is sent to the far end of the pond to the waste sludge storage area. He further informed that they have not had to dredge or remove waste sludge from that end of the pond for disposal. No solids processing or removal is occurring in the system; solids are collecting in the waste sludge pond but are not being processed and removed.

Pin floc was noted during inspection, but records review did not indicate elevated TSS levels in the effluent. Pin floc is associated with young sludge. The Operator is encouraged to identify and address the source of the pin floc so that it does not cause effluent limit exceedances in the future.

Composite samples are collected in a building referred to as the "dog house." The sampler is designed to collect samples at appropriate time intervals and keep them cool in a refrigerated container during collection. The refrigerating unit isn't operational; therefore, staff is keeping a bucket of ice under the sample container throughout the 24-hour collection time. No records were available to verify that the composite sample is being maintained at the required temperature throughout the collection time. The refrigerator should be repaired or replaced to improve quality control and comply with preservation regulations.

Records audited included January 2014 through May 2015. One pH exceedance was noted in March 2014 (reported 5.75 su). A discrepancy was noted on the lab analyses sheets for samples collected May 26, 27, and 28, 2015. On the Chain of Custody (COC) form, it states that Bryan Clifton collected the sample. However, on the lab analysis report, it states that Danny Gattis collected the sample. The permittee is reminded to closely review data provided on lab analyses reports to ensure that it is accurate and reflects the true conditions of the sampling event.

Some data reported on DMRs are being rounded incorrectly. Specifically, results are being rounded to whole numbers for reporting. Loading values shall be reported to the level contained in the permit. For example, TSS and BOD have loading limits of 1000.8 lbs/d. Therefore, load must be reported to the tenth of a pound. No violations were noted during records audit.

See attached Collection System inspection report for details regarding collection system assessment.

See attached Industrial Stormwater inspection report for details regarding the facility's No-Exposure verification.

Samielle & Fray	
INSPECTOR'S SIGNATURE: Dannielle Gray	DATE: 7/8/2015
Kerri Mª Cale	
SUPERVISOR'S SIGNATURE:Kerri McCabe	DATE: 7/8/2015

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	⊠S □M □U □NA □NE
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	Øy □n □na □ne
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	□Y □N ☑NA □NE
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	☑Y □N □NA □NE
4. ALL DISCHARGES ARE PERMITTED:	☑Y □N □NA □NE
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	ØS OM OU ONA ONE
DETAILS:	
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	☑Y □N □NA □NE
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	ØS □M □U □NA □NE
a. DATES AND TIME(S) OF SAMPLING:	☑Y □N □NA □NE
b. EXACT LOCATION(S) OF SAMPLING:	☑Y □N □NA □NE
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	☑Y □N □NA □NE
d. ANALYTICAL METHODS AND TECHNIQUES:	☑Y □N □NA □NE
e. RESULTS OF CALIBRATIONS:	☑Y □N □NA □NE
f. RESULTS OF ANALYSES:	☑Y □N □NA □NE
g. DATES AND TIMES OF ANALYSES:	☑Y □N □NA □NE
h. NAME OF PERSON(S) PERFORMING ANALYSES:	☑Y □N □NA □NE
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	Øs □m □u □na □ne
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	□S □M □U □NA ☑NE
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	☑Y □N □NA □NE
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	⊠S □M □U □NA □NE
DETAILS:	
1. TREATMENT UNITS PROPERLY OPERATED:	⊠s □m □u □na □ne
2. TREATMENT UNITS PROPERLY MAINTAINED:	⊠s □m □u □na □ne
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	⊠s □m □u □na □ne
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	⊠s □m □u □na □ne
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	⊠s □m □u □na □ne
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	⊠s □m □u □na □ne
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	⊠s □m □u □na □ne
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	☑Y □N □NA □NE
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	☑Y □N □NA □NE
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	☑Y □N □NA □NE
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:	□y Øn □na □ne
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	□Y □N ☑NA □NE
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	□Y □N ☑NA □NE
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	□Y □N ☑NA □NE
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:	□Y □N ☑NA □NE

SECTION D: SAMPLING	
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DETAILS:	
1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	Øy □n □na □ne
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	Øy □n □na □ne
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	Øy □n □na □ne
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	Øy □n □na □ne
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	Øy □n □na □ne
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	Øy □n □na □ne
a. SAMPLES REFRIGERATED DURING COMPOSITING:	ØY □N □NA □NE
b. PROPER PRESERVATION TECHNIQUES USED:	Øy □n □na □ne
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	Øy □n □na □ne
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	□y □n ☑na □ne
COMMENTS: Cooler is non-op at sample collector. Staff is putting ice and a bucket under sample to keep cool while it's collector.	ted.
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DETAILS: Krohne IFC 101 D magnetic flowmeter	
PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: TYPE OF DEVICE:	Øy □n □na □ne
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	Øy □n □na □ne
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:	Øy □n □na □ne
4. CALIBRATION FREQUENCY ADEQUATE:	□y □n ☑na □ne
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	□y □n ☑na □ne
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	□y □n ☑na □ne
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	Øy □n □na □ne
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	Øy □n □na □ne
9. HEAD MEASURED AT PROPER LOCATION:	Øy □n □na □ne
COMMENTS: Facility has magnetic flowmeter that does not require calibration as per manufacturer's specifications.	
SECTION F: LABORATORY	
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DETAILS:	
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	Øy □n □na □ne
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	□y □n ☑na □ne
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	☑Y □N □NA □NE
4. QUALITY CONTROL PROCEDURES ADEQUATE:	☑y □n □na □ne
5. DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:	☑Y □N □NA □NE
6. SPIKED SAMPLES ARE ANALYZED ≥10% OF THE TIME:	☑Y □N □NA □NE
7. COMMERCIAL LABORATORY USED:	☑Y □N □NA □NE
a. LAB NAME: Data Testing	
b. LAB ADDRESS: 3434 Country Club Drive, Fort Smith	
c. PARAMETERS PERFORMED: TSS, TDS, BOD, Chlorides, Nitrites+Nitrogen, FCB, and Phosphorous	
8. BIOMONITORING PROCEDURES ADEQUATE:	Øy □n □na □ne
a. PROPER ORGANISMS USED:	Øy □n □na □ne
b. PROPER DILUTION SERIES FOLLOWED:	Øy □n □na □ne
c. PROPER TEST METHODS AND DURATION:	☑Y □N □NA □NE
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	□Y □N □NA ☑NE
COMMENTS: WET testing is conducted by American Interplay 8600 Kanis Road Little Rock AP	

SECTION 6	SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS									
	N VISUAL OBS					MS UM U	IU □NA □NE			
DETAILS:										
OUTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER			
001	NO	NO	NO	NO	NO	clear				
			1	•	1	1	•			
SECTION H	: SLUDGE DIS	POSAL								
SLUDGE D	DISPOSAL ME	ETS PERMIT F	REQUIREMEN	TS		ØS □M □	IU □NA □NE			
DETAILS:					<u> </u>					
1. SLUDGE M	IANAGEMENT ADEQU	ATE TO MAINTAIN EF	FLUENT QUALITY:			⊠s □m	□U □NA □NE			
2. SLUDGE R	ECORDS MAINTAINED	AS REQUIRED BY 4	0 CFR 503:			□s □м	□U ☑NA □NE			
3. FOR LAND	APPLIED SLUDGE, TY	PE OF LAND APPLIE	D TO: (E.G., FOREST	, AGRICULTURAL, PU	BLIC CONTACT SITE):					
COMMENTS: O	perator states sludge	is not an issue; no sl	udge removal has occ	curred since 2008. Slu	dge is wasted to the was	ste pond at the back o	f the EQ pond.			
SECTION I:	SAMPLING IN	SPECTION PRO	OCEDURES							
SAMPLE F	SAMPLE RESULTS WITHIN PERMIT REQUIREMENTS									
DETAILS:	DETAILS:									
1. SAMPLES	1. SAMPLES OBTAINED THIS INSPECTION:									
2. TYPE OF S	AMPLE: ☐GRAB:	COMPOSITE:_ I	METHOD: FREQU	ENCY:						
3. SAMPLES	3. SAMPLES PRESERVED: □Y □N ☑NA □NE									
4. FLOW PRO	PORTIONED SAMPLE	S OBTAINED:					□N ☑NA □NE			
5. SAMPLE O	BTAINED FROM FACIL	LITY'S SAMPLING DE	VICE:				□N ☑NA □NE			
6. SAMPLE R	EPRESENTATIVE OF V	VOLUME AND NATUR	E OF DISCHARGE:				□N ☑NA □NE			
7. SAMPLE S	PLIT WITH PERMITTE	E:					□N ØNA □NE			
	CUSTODY PROCEDUI						□N ☑NA □NE			
9. SAMPLES	COLLECTED IN ACCO	RDANCE WITH PERM	IIT:			□Y	□N ☑NA □NE			
OF OTION I	070014 14/4 7			DI ANI						
	: STORM WATE				<u> </u>		UL FALA FINE			
	ATER MANAG	EMENT MEET	S PERMIT RE	QUIREMENTS)		IU ⊠NA □NE			
DETAILS: 1. SWPPP UF	PDATED AS NEEDED:	DATE OF LAST U	DATE:			ПУ	□n ☑na □ne			
	INCLUDING ALL DISCH									
			CL WATERS.				□N ☑NA □NE			
	OTENTIAL POLLUTANT		·							
	OTENTIAL TOLLOTANI		D I FAKS:				□N ☑NA □NE			
	STORM WATER DISCH						□N ☑NA □NE			
	RUCTURAL BMPS:						□N ☑NA □NE			
	ON-STRUCTURAL BMF	PS:					□N ☑NA □NE			
	PERLY OPERATED A									
	11. INSPECTIONS CONDUCTED AS REQUIRED:									

Inspection Report: City of Van Buren WWTP - Main, AFIN: 17-00062, Permit #: AR0021482 **DMR Calculation Check**

7-day Avg. - mg/l

8

Mo. Avg. - mg/l

6

Reporting Period:	From	2015	02	01	То	2015	02	28
		Year	Month	Day		Year	Month	Day
Parameter Checked:		BOD						
		Loading				Concent	ration	
		Mass				Month	nly	

Calculated Value: 125.9062 6.25 8.33

Permit Value: 30 45 1000.8

If calculated value does not equal reported value, explain:

Mo. Avg. - Ibs/day

126

Reported Value:

Rounding differences. Note: loading values shall be reported to the level contained in the permit. BOD has a loading limit of 1000.8 lbs/d. Therefore, load must be reported to the tenth of a pound.

Inspection Report: City of Van Buren WWTP - Main, AFIN: 17-00062, Permit #: AR0021482 DMR Calculation Check

Reporting Period:	From	2015	05	01	То	2015	05	31
		Year	Month	Day		Year	Month	Day
Parameter Checked	: <u></u>	TSS	_					

	Loading		entration
	Mass Mo. Avg Ibs/day	Mo. Avg mg/l	onthly 7-day Avg mg/l
Reported Value:	132	3	7
Calculated Value:	132.1296	3.41	6.667
Permit Value:	1000.8	30	45

If calculated value does not equal reported value, explain:

Rounding differences. Note: loading values shall be reported to the level contained in the permit. TSS has a loading limit of 1000.8 lbs/d. Therefore, load must be reported to the tenth of a pound.



Water Division Photographic Evidence Sheet Location: City of Van Buren WWTP - Main Photographer: Dannielle Gray Date: 6/25/2015 Time: 0950 Witness: James Dunn, Kerri McCabe, & Cody Wallace Photo #: 3



Photographer:Dannielle GrayDate:6/25/2015Time:0951Witness:James Dunn, Kerri McCabe, & Cody WallacePhoto #:4




Inspection Report: City of Van Buren WWTP - Main, AFIN: 17-00062, Permit #: AR0021482

Water Division Photographic Evidence Sheet							
Location: City of Van Buren WWTP - Main							
Photograp	her:	Dannielle Gray	Date:	6/25/2015	Time:	0954	
Witness: James Dunn, Kerri McCabe, & Cody Wallace Photo #: 5							
Description	٦. ٦	Freatment pond – taken from activated	sludge	section on north/no	rthwest-si	de of	
Description	''. r	ond.					



Photographer: Dannielle Gray	Date:	6/25/2015	Time:	0955
Witness: James Dunn, Kerri McCabe, & Cod	y Wallace		Photo #	: 6



Water Division Photographic Evidence Sheet Location: City of Van Buren WWTP - Main Photographer: Dannielle Gray Date: 6/25/2015 Time: 1001 Witness: James Dunn, Kerri McCabe, & Cody Wallace Photo #: 7 Description: Example of pond levee condition.



Photographer:Dannielle GrayDate:6/25/2015Time:1006Witness:James Dunn, Kerri McCabe, & Cody WallacePhoto #:8

Description: Curtain between equalization portion of pond and waste sludge portion of pond – note solids along bank (i.e., plastic tampon applicators, trash, etc.).





Inspection Report: City of Van Buren WWTP - Main, AFIN: 17-00062, Permit #: AR0021482




Figure 1: Google Earth image dated October 5, 2013 showing overview of treatment plant.



Figure 2: Google Earth image dated Oct 5, 2013 showing close-up of treatment pond.



Commission: C.E. Dougan John Barnwell J.W. Floyd Jim Williamson Todd Young



Attorney
Paul Gant
Engineer
Larry Weir
Secretary
Kathy Geppert

"Providing Water, Sewer, and Sanitation Services"
2806 Bryan Road / P.O. Drawer 1269
Van Buren, Arkansas 72957
479-474-5067 / Fax 479-471-8969
Van Buren Municipal Utilities

July 17, 2015

Arkansas Department of Environmental Quality Water Division Inspection Branch, Dannielle Gray 5301 Northshore Drive North Little Rock, Arkansas 72118-5317

Re:

City of Van Buren Municipal Utilities Main Plant

AFIN: 17-00062 NPDES PERMIT NO.: AR0021482

Compliance Evaluation Inspection June 25, 2015

Dear Ms. Gray:

In response to your letter dated July 9, 2015 (copy attached):

"Please refer to the "Summary of Findings" section of each of the attached inspection reports and provide a written response for each violation that was noted"

The following violation was noted during the inspection:

- 1. All systems of the treatment and control used by the permittee to achieve compliance are not being properly operated and maintained, violating Part III, Section B.1 of the permit. Specifically, the following items need to be addressed:
 - a. The refrigerator at the "dog house" is not operational.

VBMU RESPONSE: A new sample refrigerator has been ordered and will be installed upon delivery, furthermore; department personnel will keep daily record the refrigerator temperature daily.

b. Trash associated with wastewater (i.e., tampon applicators and miscellaneous trash) are making their way past the bar screen and collecting along the edges of the pond.

City of Van Buren Municipal Utilities Main Plant AFIN: 17-00062 NPDES PERMIT NO.: AR0021482

Compliance Evaluation Inspection June 25, 2015 Pg. 2

July 17, 2015

VBMU RESPONSE: We are not certain that all of the materials are in the pond as a result of them making their way past the bar screen, we believe that some of the materials are remnants from before the bar screen was installed and get washed up during high flow events. Plant personnel have been instructed to clean up the materials on a timely schedule.

If you have any questions, need further information, or if you would like for photo documentation to be provided after the above items are completed, please let me know.

Sincerely

Steve Dufresne

Director of Utilities

Cc: File

Darel Manus, VBMU Operations Superintendent James Dunn, VBMU Chief Plant Operator



July 9, 2015

Steve Dufresne, Van Buren Municipal Utilities PO Drawer 1269 Van Buren, AR 72956

RE: City of Van Buren WWTP - Main Inspection (Crawford Co)

AFIN: 17-00062 NPDES Permit No.: AR0021482

ARR000413

Dear Mr. Dufresne:

On June 25, 2015 I performed a Compliance Evaluation Inspection, a Collection System Inspection, and an Industrial Stormwater Inspection of the above-referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. Copies of the inspection reports are enclosed for your records.

Please refer to the "Summary of Findings" section of each of the attached inspection reports and provide a written response for each violation that was noted. This response should be mailed to the attention of the Water Division Inspection Branch at the address at the bottom of this letter or e-mailed to Water-Inspection-Report@adeq.state.ar.us. This response should contain documentation describing the course of action taken to correct each item noted. This corrective action should be completed as soon as possible, and the written response with all necessary documentation (i.e. photos) is due by July 23, 2015.

If I can be of any assistance, please contact me at grayd@adeq.state.ar.us or (479) 424-0333.

Sincerely,

Dannielle Gray
District 4 Field Inspector
Water Division

cc: James Dunn, Chief Plant Operator, City of Van Buren, jodmsd@yahoo.com

VAN BUREN MUNICIPAL UTILITIES Providing Water, Sewer and Solid Waste Services 2806 Bryan Road P.O. DRAWER 1269 VAN BUREN, ARKANSAS 72957



ADEQ WATER DIVISION INSPECTION BRANCH 5301 NORTH SHORE DR NORTH LITTLE ROCK, AR 72/18-

72118+5317



July 23, 2015

Steve Dufresne Van Buren Municipal Utilities PO Drawer 1269 Van Buren, AR 72956

RE: Response to Inspection (Crawford Co)

AFIN: 17-00062 NPDES Permit No.: AR0021482

Dear Mr. Dufresne:

I have reviewed the response pertaining to my June 25, 2015 inspection of the Van Buren Main wastewater treatment facility. The information provided sufficiently addresses the violations referenced in my inspection report. At this time, the Department has no further comment concerning this particular inspection. Acceptance of this response by the Department does not preclude any future enforcement action deemed necessary at this site or any other site.

If we need further information concerning this matter, we will contact you. Thank you for your attention to this matter. Should you have any questions, feel free to contact me at (479) 424-0333 or you may e-mail me at grayd@adeq.state.ar.us.

Sincerely,

Dannielle Gray

District 4 Field Inspector

Water Division