

August 1, 2017

Darrell Phillips, General Manager & CEO Paragould Light, Water & Cable P.O. Box 9 Paragould, AR 72451

RE: Paragould Light, Water & Cable Inspection AFIN: 28-00470 Permit No.: AR0033766

Dear Mr. Phillips:

On June 21 and 26, 2017, I performed a Compliance Evaluation Inspection, SSO/Collection System Inspection, Pretreatment Compliance Inspection, and Industrial Stormwater Inspection of the above referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. A copy of the inspection reports are enclosed for your records.

No violations were noted at the time of the inspection. Please refer to the attached inspection reports for any comments.

If I can be of any assistance, please contact me at 870-935-7221 ext.-15 or frasher@adeq.state.ar.us.

Sincerely,

Sarah Frasher District 3 Field Inspector Water Division

			WATER I	DIVISION I	NSF	PECTION	I RE	PORT
	JLQ	AF	IN: 28-00470 PI	ERMIT #: AR0033766			DATE: 6/21/2017	
A R K	ANSAS	CC	UNTY: 28 Green	e	PDS	#: 098366		MEDIA: WN
	f Environmental Quality	GF	S LAT: 36.03151	0 LONG: -90.491	631 L	OCATION: E	ntrance	9
	FACILITY INFORMAT	ION		IN	ISPEC	TION INFORI	NATIO	Ν
	Light, Water & Cable			FACILITY TYPE:INSPECTOR ID#:1 - Municipal112347 S - State				
401 Grant Lane			FACILITY EVALUATION RATING: INSPECTION TYPE: 4 - Satisfactory Compliance Evaluation			Evaluation		
Paragould				(-)	NTRY TIME:	EXIT TIME: 15:52	PERMIT EF	FECTIVE DATE:
RESPONSIBLE OFFICIAL					9:17	16:22		KPIRATION DATE:
NAME: / TITLE Darrell Phillips / General Manager & CEO							7/31/2	2020
COMPANY:			FAYETTEVILLE SHALE RELATED: N					
Paragould Light, Water & Cable				FAYETTEVILLE SHALE VIOLATIONS: N				
P.O. Box 9				INSPECTION PARTICIPANTS				
CITY, STATE, ZIP: Paragould AR 72451 PHONE & EXT: / FAX:				NAME/TITLE/PHONE/FAX/EMAIL/ETC: Lisa Ellington, PhD/Manager-Environmental Services Brett Bradford/ Chief Operating Officer				
	ED DURING INSPECTION	Va						
CONTACTE	ED DURING INSPECTION	res	AREA EVA					
	(S=S	atisfac	AREA EVA tory, M=Marginal, U=Unsati		/Evaluated	(k		
S PERMI		S	FLOW MEASUR	REMENT	Ν	STORMWA		
	RDS/REPORTS	S LABORATORY			S		FACILITY SITE REVIEW	
	TION & MAINTENANCE	S				SELF-MONITORING PROGRAM		IG PROGRAM
S SAMPL		S	SLUDGE HAND	LING/DISPOSAL	Ν	PRETREAT	MENT	
N OTHER								
			SUMMARY C	F FINDINGS				
No violatio	ns were noted at the time	e of t	he inspection.					

Dr. Lisa Ellington is very knowledgeable and passionate about Paragould Light, Water & Cable Wastewater Treatment Plant. The staff of PLWC works well together in the laboratory and on the grounds to properly operate and maintain the facility. The WWTP has plans for future improvements to the facility to better treat the wastewater to not only meet permit limits but also to improve water quality for all.

Maintenance work and future planning is being done on various portions of the Wastewater Treatment Plant. The Inlet Structure and grit chamber (Photos 1-3) is in the planning process to replace in the future. One of the Aeration Basins is currently being drained for maintenance and annual cleaning (Photos 4-8). The accumulation of grit and other solids in the drained Aeration Basin reaffirms the WWTP need to look at the headworks of the plant. The Clarifiers are scheduled for maintenance, in which the tanks will be drained and all parts removed for intense cleaning (Photos 9-11). The movable parts and weirs will be shipped to the manufacturer for cleaning and inspection as well as a guard put on the weirs to discourage algae growth.

The UV Disinfection system was just installed at the WWTP (Photos 12-14). The light panels are place in the water at 45° angles to allow proper disinfection. The lights are closely monitored, cleaned regularly, and are sequenced to rotate on/off cycles. The WWTP is planning to build a cover on the wet well to protect the UV system from excessive algae growth and foreign matter.

The Biosolids process is no longer operational since February 2017 for land application. The treated sludge is now sent through the Gravity Table Thickener and Belt Filter Press before being hauled off to the landfill (Photos 17-22).

A SSO/Collection System Inspection, Pretreatment Compliance Inspection, and Stormwater Inspection were all performed in conjunction with this inspection.

Brent Walker, District 3 Water Inspector, and Jason Bolenbaugh, Compliance Branch Manager, also participated in this inspection.

CI ful	
INSPECTOR'S SIGNATURE: Sarah Frasher	DATE: 7/26/2017
SUPERVISOR'S SIGNATURE: JasoBolenbaugh	DATE: 7/31/2017

Inspection Report: Paragould Light, Water & Cable , AFIN: 28-00470 , Permit #:	AR0033700
SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	ØS OM OU ONA ONE
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	🗹 y 🗆 n 🗆 na 🗆 ne
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	Dy Dn Øna Dne
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	
4. ALL DISCHARGES ARE PERMITTED:	
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	
DETAILS:	
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	
a. DATES AND TIME(S) OF SAMPLING:	Øy 🛛 n 🗆 na 🗆 ne
b. EXACT LOCATION(S) OF SAMPLING:	
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	
d. ANALYTICAL METHODS AND TECHNIQUES:	
e. RESULTS OF CALIBRATIONS:	
f. RESULTS OF ANALYSES:	
g. DATES AND TIMES OF ANALYSES:	
h. NAME OF PERSON(S) PERFORMING ANALYSES:	
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	
DETAILS:	
1. TREATMENT UNITS PROPERLY OPERATED:	
2. TREATMENT UNITS PROPERLY MAINTAINED:	
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	
 HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR: <u>Overflow</u> reported at plant on 6/23/2017. See SSO/Collection System report for details. 	
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	

SECTION D: SAMPLING	
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	
DETAILS:	
1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	
a. SAMPLES REFRIGERATED DURING COMPOSITING:	
b. PROPER PRESERVATION TECHNIQUES USED:	
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	ØS OM OU ONA ONE
PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: Yes TYPE OF DEVICE: 4 ft. Rectain weir with end contractions	
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	
 SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED: <u>Simmons</u> <u>Hydrometer</u> 	
4. CALIBRATION FREQUENCY ADEQUATE:	
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	
9. HEAD MEASURED AT PROPER LOCATION:	
SECTION F: LABORATORY	
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	ØS OM OU ONA ONE
DETAILS:	
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	
4. QUALITY CONTROL PROCEDURES ADEQUATE:	
5. DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:	
6. SPIKED SAMPLES ARE ANALYZED ≥10% OF THE TIME:	
7. COMMERCIAL LABORATORY USED:	
a. LAB NAME: <u>Arkansas Analytical, Inc.</u>	
b. LAB ADDRESS: <u>Little Rock, AR</u>	
c. PARAMETERS PERFORMED: <u>Biomonitoring</u>	
8. BIOMONITORING PROCEDURES ADEQUATE:	
a. PROPER ORGANISMS USED:	
b. PROPER DILUTION SERIES FOLLOWED:	
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	

SECTION G	SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS								
BASED ON	VISUAL OBS	ERVATIONS C	DNLY			ØS OM O			
DETAILS:									
OUTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER		
001	N/A	N/A	Low	N/A	N/A	clear			
SECTION H	: SLUDGE DIS	POSAL							
SLUDGE D	ISPOSAL MEE	ETS PERMIT F	REQUIREMEN	ΓS		ØS OM O	IU 🗆 NA 🗆 NE		
DETAILS:	Biosolids proce	ess not operation	<u>onal</u>						
1. SLUDGE MANAGEMENT ADEQUATE TO MAINTAIN EFFLUENT QUALITY: Image: Comparison of the second seco									
2. SLUDGE R	2. SLUDGE RECORDS MAINTAINED AS REQUIRED BY 40 CFR 503:								
3. FOR LAND	APPLIED SLUDGE, TY	PE OF LAND APPLIE	D TO: (E.G., FOREST,	AGRICULTURAL, PUE	BLIC CONTACT SITE):	ludge hauled to landf	<u>ill</u>		
	SAMPLING IN								
	ESULTS WITH	HIN PERMIT R	EQUIREMENT	S			IU ⊠NA ⊡NE		
DETAILS:									
	OBTAINED THIS INSPE					ΠY	On Øna One		
2. TYPE OF S	AMPLE: GRAB:		IETHOD: FREQUE	NCY:					
3. SAMPLES F	PRESERVED:								
4. FLOW PRO	PORTIONED SAMPLE	S OBTAINED:							
5. SAMPLE OBTAINED FROM FACILITY'S SAMPLING DEVICE:									
6. SAMPLE RI	EPRESENTATIVE OF	VOLUME AND NATUR	E OF DISCHARGE:						
7. SAMPLE SI	PLIT WITH PERMITTER	Ξ:							
8. CHAIN-OF-	CUSTODY PROCEDU	RES EMPLOYED:							
9. SAMPLES (COLLECTED IN ACCO	RDANCE WITH PERM	IT:			ΠY	□n Øna □ne		
	STORM WAT								
	ATER MANAG		-				IU ⊠NA ⊡NE		
	See Industrial S			or details.					
	DATED AS NEEDED:								
2. SITE MAP INCLUDING ALL DISCHARGES AND SURFACE WATERS:									
OLLUTION PREVENTION TEAM IDENTIFIED: POLLUTION PREVENTION TEAM PROPERLY TRAINED:							On Øna One		
	TENTIAL SOURCES A			DN ØNA DNE					
		<u>.</u>					On Øna One		
	DN-STRUCTURAL BMF								
	PERLY OPERATED AN								
II. INGELUIIU	1. INSPECTIONS CONDUCTED AS REQUIRED: Image: Conducted as required: Conducted as req								

FLOW CALCULATION SHEET

Date: 6/2	26/2017	Time: 14:	12				
	-		1				
Head in Ind	ches:	Feet:	0.58				
TUDO 8 SIZ	o of Drimory		nont Do		Aft Docton	aulorwo	ir with and
contraction		low Measurer		vice.	411 NEUlan	gulai we	
Contraction	13						
Name & M	odel of Secon	dary Flow Mea	asureme	ent De	evice: Sin	nmons H	lydrometer
				_			
Date of las	t Calibration o	f Secondary F	low Dev	vice:	10/27/20	16	
Recorded	Flow at Date 8	k Time Listed	Abovo:	3.92	07		
Recorded			-0006.	5.57	<u> </u>	(1	Facility Flow Meter)
Calculated	Flow at Date	& Time Listed	Above:	3.0	692		
(Flow is calcula	ited using flow char	ts in: <u>ISCO Open C</u>	hannel Flov	w Meas	surement Hand	book-5 th Edi	tion)
	Decerded						
% Error =	Recorded V		culated V	[*] X 100			
		Calculated Val	ue				
a. –	3.927	-	3.692		N/ 400		
% Error =		3.692			— X 100		
			1				
% Error =	0.235	— X 100					
70 EITOI =	3.692	Х 100					
% Error =	0.0637	X 100					
76 EITOI =	0.0037	X 100					
% Error =	6.37	%					
	_L	I I					
Comments	: <u>Within ±10</u>) % requireme	<u>ents</u>				

DMR Calculation Check

Reporting Period:	From	2016 Year	08 Month	01 Day	_ To _	2016 Year	08 Month	<u>31</u> Day		
Parameter Checked:		ТР	-							
		Loading				Concen	tration			
		Mass			Monthly					
	Мо. /	Avg Ibs/d	lay	Mo. A	vg r	ng/l	7-day Avg	mg/l		
Reported Value:		66			2.6		3.8			
Calculated Value:		66	·		2.6		3.8			
Permit Value:		Report		R	eport		Repo	ort		

If calculated value does not equal reported value, explain: Equal

DMR Calculation Check

Reporting Period:	From	<u>2017</u> Year	02 Month	01 Day	_ To _	2017 Year	02 Month	<u>28</u> Day
Parameter Checked:		CBOD	-					
		Loading				Concer	tration	
		Mass				Mon	thly	
	Mo.	Avg Ibs/d	lay	Mo. A	vg r	ng/l	7-day Avg	mg/l
Reported Value:		109			3.4		3.9	
Calculated Value:		109			3.4		3.9	
Permit Value:		500			10		15	

If calculated value does not equal reported value, explain: Equal

DMR Calculation Check

Reporting Period:	From	<u>2017</u> Year	02 Month	01 Day	_ To _	2017 Year	02 Month	28 Day
Parameter Checked:		TSS	-					
		Loading Mass				Concer Mon		
	Mo.	Avg Ibs/c	lay	Mo. A	vg r		7-day Avg	mg/l
Reported Value:		187			5.5		8.6	
Calculated Value:		187			5.5		8.6	
Permit Value:		750			15		22.5	5

If calculated value does not equal reported value, explain: <u>Equal</u>







Figure 1. Google Earth image of Paragould Light, Water and Cable Wastewater Treatment Plant with labels.
















Water Division Pho	otographic Evidence Sheet	
Location: Paragould Light, Water & Cable		
Photographer: Sarah Frasher	Date: 6/21/2017	Time: 9:18
Witness: Brent Walker, Jason Bolenbaugh		Photo #: 15
Description: View of the Outfall Structure with	th aeration. Note the staff gauge	9.
Photographer: Sarah Frasher Witness: Brent Walker, Jason Bolenbaugh	Date: 6/21/2017	Time: 9:18 Photo #: 16
Description: View of the water from the Outfi	all Structure before final discha	
	DE -21.2017	







