
 A R K A N S A S Department of Environmental Quality		WATER DIVISION INSPECTION REPORT						
		AFIN: 73-00055		PERMIT #: AR0021601		DATE: 2/5/2019		
		COUNTY: 73 White			PDS #: 106608		MEDIA: WN	
		GPS LAT: 35.243674 LONG: -91.738233 LOCATION: Entrance						
FACILITY INFORMATION				INSPECTION INFORMATION				
NAME: Searcy WWTP LOCATION: Cintas Laundry CITY: Searcy				FACILITY TYPE: 1 - Municipal		INSPECTOR ID#: 83321 S - State		
				FACILITY EVALUATION RATING: ***		INSPECTION TYPE: Industrial User		
				DATE(S): 2/5/2019	ENTRY TIME: 10:20	EXIT TIME: 10:51	PERMIT EFFECTIVE DATE: 10/1/2013 PERMIT EXPIRATION DATE: 9/30/2018	
				RESPONSIBLE OFFICIAL				INSPECTION PARTICIPANTS
NAME / TITLE: Daniel Dawson / General Manager COMPANY: Searcy Board of Public Utilities MAILING ADDRESS: P.O. Box 1319 CITY, STATE, ZIP: Searcy AR 72145 PHONE & EXT. / FAX: 501-268-2481 / EMAIL: d.dawson@cablelynx.com				NAME/TITLE/PHONE/FAX/EMAIL/ETC.: Jimmy Smith, WWTP Manager, City of Searcy Spencer Oyemaja, Pretreatment Coordinator, City of Searcy Jason Gibson, Maintenance Supervisor, Cintas Keith Waters, Inspector, ADEQ				
CONTACTED DURING INSPECTION: Yes								
AREA EVALUATIONS								
(S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)								
**	PERMIT	**	FLOW MEASUREMENT	**	STORMWATER			
**	RECORDS/REPORTS	**	LABORATORY	**	FACILITY SITE REVIEW			
**	OPERATION & MAINTENANCE	**	EFFLUENT/RECEIVING WATER	**	SELF-MONITORING PROGRAM			
**	SAMPLING	**	SLUDGE HANDLING/DISPOSAL	**	PRETREATMENT			
**	OTHER:							
SUMMARY OF FINDINGS								
<p>Wastewater is generated from normal wash and rinse cycles from industrial sized washers. Bleach is commonly used in the cleaning process. All wastewater is drains to one drainage pit that runs the length of the floor where the washers are located. Solids, mostly lint, are separated with a shaker. Due to the addition of bleach in the cleaning process the wastewater pH is adjusted with sulfuric acid to lower the pH to acceptable levels prior to discharge to the POTW. During the visit the wastewater pH prior to adjustment was 12.33 and following adjustment it was 8.42. Meter pH calibrations occur every Friday.</p> <p>No further action is required for this inspection.</p>								
GENERAL COMMENTS								
This site visit of Cintas Laundry was conducted as a requirement of the City of Searcy's Pretreatment Compliance Inspection conducted on February 4 and 5, 2019. Cintas Laundry is a non-categorical Significant Industrial User. Cintas Laundry is located at 101 West Beebe Capps Expressway, Searcy, Arkansas, 72143.								
INSPECTOR'S SIGNATURE: <small>←Click text to left to add signature</small>				-Inspector Name		DATE:		
SUPERVISOR'S SIGNATURE: 				Jason Bolenbaugh		DATE: 2/18/2019		

POTW Pretreatment Program

Industrial Site Visit

Name of Industry: **Cintas Laundry**

Industry Contacts: **Jason Gibson, Maintenance Supervisor**

Type of Industry: **Cleaning Services**

Date of Visit: **February 5, 2019**

- | | | | | |
|-----|--|-------------------|------------------|-------------------|
| 1. | Significant industrial user: | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 2. | Pretreatment equipment or procedures? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 3. | Pretreatment equipment maintained and operational? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 4. | Hazardous waste generated or stored? | <u> </u> Yes | <u> X </u> No | <u> </u> N/A |
| 5. | Proper solid waste disposal? | <u> X </u> Yes | <u> X </u> No | <u> </u> N/A |
| 6. | Solvent management/TTO control? | <u> </u> Yes | <u> </u> No | <u> X </u> N/A |
| 7. | Suitable sampling location? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 8. | Appropriate self-monitoring procedures/equipment? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 9. | Adequate spill prevention? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 10. | Industry familiar with limits and requirements? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |

Additional Comments: **None**

Water Division Photographic Evidence Sheet

Location:	Searcy WWTP		
Photographer:	Jason Bolenbaugh	Date:	2/5/2019
Witness:		Time:	10:28
		Photo #:	1
Description:	Solid separation of lint.		



Photographer:	Jason Bolenbaugh	Date:	2/5/2019
Witness:		Time:	10:29
		Photo #:	2
Description:	Pretreatment system with sulfuric acid addition for pH adjustment.		



Water Division Photographic Evidence Sheet

Location:	Searcy WWTP		
Photographer:	Jason Bolenbaugh	Date:	2/5/2019
Witness:		Time:	10:29
		Photo #:	3
Description:	PH adjustment basin and discharge pipe to the city's collection system.		



Photographer:	Jason Bolenbaugh	Date:	2/5/2019
Witness:		Time:	10:29
		Photo #:	4
Description:	PH of wastewater prior to adjustment.		



Water Division Photographic Evidence Sheet

Location:	Searcy WWTP		
Photographer:	Jason Bolenbaugh	Date:	2/5/2019
Witness:		Time:	10:30
		Photo #:	5
Description:	PH of wastewater discharged to city's collection system following pH adjustment.		

