
 A R K A N S A S Department of Environmental Quality		WATER DIVISION INSPECTION REPORT						
		AFIN: 73-00055		PERMIT #: AR0021601		DATE: 2/5/2019		
		COUNTY: 73 White			PDS #: 106609		MEDIA: WN	
		GPS LAT: 35.240034 LONG: -91.732767 LOCATION: Entrance						
FACILITY INFORMATION				INSPECTION INFORMATION				
NAME: Searcy WWTP LOCATION: Eaton Hydraulics, LLC. CITY: Searcy				FACILITY TYPE: 1 - Municipal		INSPECTOR ID#: 83321 S - State		
				FACILITY EVALUATION RATING: ***		INSPECTION TYPE: Industrial User		
				DATE(S): 2/5/2019	ENTRY TIME: 09:31	EXIT TIME: 10:10	PERMIT EFFECTIVE DATE: 10/1/2013	
						PERMIT EXPIRATION DATE: 9/30/2018		
RESPONSIBLE OFFICIAL				INSPECTION PARTICIPANTS				
NAME / TITLE: Daniel Dawson / General Manager COMPANY: Searcy Board of Public Utilities MAILING ADDRESS: P.O. Box 1319 CITY, STATE, ZIP: Searcy AR 72145 PHONE & EXT. / FAX: 501-268-2481 / EMAIL: d.dawson@cabkelynx.com								
CONTACTED DURING INSPECTION: No								
AREA EVALUATIONS								
(S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)								
**	PERMIT	**	FLOW MEASUREMENT	**	STORMWATER			
**	RECORDS/REPORTS	**	LABORATORY	**	FACILITY SITE REVIEW			
**	OPERATION & MAINTENANCE	**	EFFLUENT/RECEIVING WATER	**	SELF-MONITORING PROGRAM			
**	SAMPLING	**	SLUDGE HANDLING/DISPOSAL	**	PRETREATMENT			
**	OTHER:							
SUMMARY OF FINDINGS								
<p>Wastewater generating processes include nickel plating, hot blacking, parts cleaning, cold blacking, painting, and machining cast iron, steel, brass, and aluminum. All production areas sit within a pit so any spills are contained and drain to the pretreatment unit. The pretreatment area was very clean and orderly and Mr. Walker was very knowledgeable of the system. All solids generated from the pretreatment unit pressed and disposed of in a landfill in Tulsa, Oklahoma. All hazardous waste is maintained in a fully enclosed, secure area. Further details are found in the Pretreatment Compliance Inspection report.</p> <p>No further actions are required for this inspection.</p>								
GENERAL COMMENTS								
<p>This site visit of Eaton Hydraulics, LLC was conducted as a requirement of the City of Searcy's Pretreatment Compliance Inspection conducted on February 4 and 5, 2019. Eaton Hydraulics is the only categorical Significant Industrial User in the pretreatment program. Eaton Hydraulics is located at 400 East Lincoln Avenue, Searcy, Arkansas, 72143.</p>								
INSPECTOR'S SIGNATURE: <small>←Click text to left to add signature</small>				-Inspector Name				
SUPERVISOR'S SIGNATURE: 				DATE: 2/18/2019				
				DATE: 2/18/2019				

POTW Pretreatment Program

Industrial Site Visit

Name of Industry: Eaton Hydraulics, LLC.

Industry Contacts: Kenneth Waller, EHS Technician

Type of Industry: Metal Plating

Date of Visit: February 5, 2019

- | | | | | |
|-----|--|-------------------|------------------|-------------------|
| 1. | Significant industrial user: | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 2. | Pretreatment equipment or procedures? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 3. | Pretreatment equipment maintained and operational? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 4. | Hazardous waste generated or stored? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 5. | Proper solid waste disposal? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 6. | Solvent management/TTO control? | <u> </u> Yes | <u> </u> No | <u> X </u> N/A |
| 7. | Suitable sampling location? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 8. | Appropriate self-monitoring procedures/equipment? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 9. | Adequate spill prevention? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |
| 10. | Industry familiar with limits and requirements? | <u> X </u> Yes | <u> </u> No | <u> </u> N/A |

Additional Comments: None

Water Division Photographic Evidence Sheet

Location:	Searcy WWTP		
Photographer:	Jason Bolenbaugh	Date:	2/5/2019
Witness:		Time:	09:46
		Photo #:	1
Description:	4,000 gallon accumulation tank with oil skimmer.		



Photographer:	Jason Bolenbaugh	Date:	2/5/2019
Witness:		Time:	09:47
		Photo #:	2
Description:	6,000 gallon tank that receives all plating process wastewater.		



Water Division Photographic Evidence Sheet

Location:	Searcy WWTP		
Photographer:	Jason Bolenbaugh	Date:	2/5/2019
Witness:		Time:	09:49
		Photo #:	3
Description:	Reaction stage tanks that adjust pH levels.		



Photographer:	Jason Bolenbaugh	Date:	2/5/2019
Witness:		Time:	09:49
		Photo #:	4
Description:	Process tank where carbon is added to help remove organics.		



Water Division Photographic Evidence Sheet

Location:	Searcy WWTP				
Photographer:	Jason Bolenbaugh	Date:	2/5/2019	Time:	09:52
Witness:				Photo #:	5
Description:	Sludge press.				



Photographer:	Jason Bolenbaugh	Date:	2/5/2019	Time:	09:55
Witness:				Photo #:	6
Description:	Final sampling port tank where water is discharged to the POTW.				



Water Division Photographic Evidence Sheet

Location:	Searcy WWTP				
Photographer:	Jason Bolenbaugh	Date:	2/5/2019	Time:	09:56
Witness:				Photo #:	7
Description:	PH reading of process water being discharged to the POTW.				



Photographer:	Jason Bolenbaugh	Date:	2/5/2019	Time:	10:02
Witness:				Photo #:	8
Description:	Hazardous waste storage area.				

