Inspection Report: **George's Inc.**, AFIN: **72-00003**, Permit #: **AR0022063**

	Λ DEO	WATER DIVISION INSPECTION REPORT								
A R K A N S A S		AF	AFIN: 72-00003 PERMIT #: AR00220		063		DATE: 9/18/2019			
		COUNTY: 72 Washi		ington P		#: 110040	MEDIA: WN			
Dep	partment of Environmental Quality	GF	PS LAT: 36.19929	36.19929 LONG: -94.13972 LOCATION: General Area						
	FACILITY INFORMAT		INSPECTION INFORMATION							
George's Inc.			FACILITY TYPE: 2 - Industrial	INSPECTOR ID#: 104111 S - State						
1306 N Kansas Street			RACILITY EVALUATION RATING: INSPECTION TYPE: N Industrial User							
Springdale				1 /	:15	EXIT TIME: 10:00	PERMIT EFFECTIVE DATE:			
	RESPONSIBLE OFFICE	-	3/10/2013	.10	10.00	4/1/2004 PERMIT EXPIRATION DATE: 3/31/2009				
Heath Ward / Executive Director COMPANY:				FAYETTEVILLE SHALE RELATED: N						
Springdale Water Utilities MAILING ADDRESS:				FAYETTEVILLE :	SHAL	E VIOLATIO	DNS: N			
P.O. Box 769				INSPECTION PARTICIPANTS						
CITY, STATE, ZIP: Springdale AR 72765 PHONE & EXT: / FAX: 479-751-5751 / EMAIL:				NAME/TITLE:PHONE:FAX:EMAIL/ETC.: Bud Kirk, Wastewater Manager, George's Inc.; Bradley Stewart, Pretreatment Manager, Springdale Water Utilities; Tiffany Mallard, Laboratory Supervisor, Springdale Water Utilities;						
CONTACTED DURING INSPECTION: No				Garrett Grimes, District 1 Inspector, ADEQ						
	(9-9)	atisfac	AREA EVA		valuated	١				
S	S PERMIT N FLOW MEASUR N FLOW MEASUR				N	STORMW	ATER			
N	RECORDS/REPORTS	N	LABORATORY			FACILITY SITE REVIEW SELF-MONITORING PROGRAM				
N	OPERATION & MAINTENANCE	N		FFLUENT/RECEIVING WATER						
N	SAMPLING OTHER:	N	N SLUDGE HANDLING/DISPOSAL		S	PRETREATMENT				
	OTTIEK.		SUMMARY C	F FINDINGS						
IU visit performed as part of a PCI of Springdale										
GENERAL COMMENTS										
George's Inc. maintains a bubble meter for flow measurement. Mr. Kirk stated that the meter is not professionally calibrated annually, but that calibration checks are conducted. However, no records of these checks were available. George's Inc. should have its flow meter professionally calibrated per manufacturer recommendations. Calibration checks for +/- 10% deviation should be conducted regularly and recorded.										
INS	SPECTOR'S SIGNATURE:	Garrett Grin	nes		DATE: 10/16/2019					
INSPECTOR'S SIGNATURE: Brest 2 Walker Brent L. Walker DATE: 11/13/2019										

Inspection Report: George's Inc., AFIN: 72-00003, Permit #: AR0022063

POTW Pretreatment Program

Industrial Site Visit

	or industry: George's inc,				
Indus	try Contacts: Bud Kirk, Wastewater Manager				
Туре	of Industry: Poultry Processing				
Date	of Visit: September 18, 2019				
1.	Significant industrial user:	<u>x</u>	Yes	No	N/A
2.	Pretreatment equipment or procedures?	<u>x</u>	Yes	No	N/A
3.	Pretreatment equipment maintained				
	and operational?	<u>X</u>	Yes	No	N/A
4.	Hazardous waste generated or stored?		Yes	<u>X</u> No	N/A
5.	Proper solid waste disposal?	<u>X</u>	Yes	No	N/A
6.	Solvent management/TTO control?		Yes	No	<u>X</u> N/A
7.	Suitable sampling location?	<u>X</u>	Yes	No	N/A
8.	Appropriate self-monitoring				
	procedures/equipment?	X	Yes	No	N/A
9.	Adequate spill prevention?	<u>X</u>	Yes	No	N/A
10.	Industry familiar with limits				
	and requirements?	X	Yes	No	N/A

Additional Comments: See comments section.

Visit Conducted By: Garrett Grimes, District 1 Inspector

Date of Report: 9/18/2019