

June 5, 2020

David Green, Utilities Manager City of Arkadelphia PO Box 495 Arkadelphia, AR 71923

RE: Arkadelphia WWTP Inspections (Clark Co) AFIN: 10-00463 NPDES Permit No.: AR0020605 ARR000190

Dear Mr. Green:

On May 13, 2020, I performed a Compliance Evaluation Inspection, an SSO/Collection System Inspection, and an Industrial Stormwater Inspection of the above-referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. A copy of each of the inspection reports is enclosed for your records.

Please refer to the "Summary of Findings" section of each of the attached inspection reports and provide a written response for each violation that was noted. This response should be mailed to the attention of the Office of Water Quality (OWQ) Compliance Branch at the address at the bottom of this letter or e-mailed to <u>Water-Inspection-Report@adeq.state.ar.us</u>. This response should contain documentation describing the course of action taken to correct each item noted. This corrective action should be completed as soon as possible, and the written response with all necessary documentation (i.e., photos) is due by <u>June 19, 2020</u>.

If I can be of any assistance, please contact me at <u>youngm@adeq.state.ar.us</u> or (501) 837-2073.

Sincerely,

Ming

Michael Young District 8 Inspector Office of Water Quality

Inspection Report: Arkadelphia WWTP, AFIN: 10-00463, Permit #: AR0020605

	· · · · ·								
	NDEO	WATER DIVISION INSPECTION REPORT							
		AF	IN: 10-00463 PI	ERMIT #: AR0020	0605		D	DATE: 5	5/13/2020
ARKANSAS		COUNTY: 10 Clark			PDS ;	#: 11208	0		MEDIA: WN
Department of Environmental Quality			GPS LAT: 34.084117 LONG: -93.		1534 LOCATION: Entrance)
	FACILITY INFORMAT	INSPECTION INFORMATION							
Arkadelphia WWTP				FACILITY TYPE:	pal 101531 S - State				
LOCATION:				1 - Municipal FACILITY EVALUATION RATIN					
South 3 rd Street and Open Banks Road				2 - Marginal	G:				Evaluation
CITY:	adelphia, AR 71923					EXIT TIME 14:11		PERMIT EFI	FECTIVE DATE:
	RESPONSIBLE OFFIC			5/13/2020 1 7/12/2018	1:00	14.1	1	11/1/2	017 PIRATION DATE:
	: / TITLE		-	//12/2010				10/31/	
	vid Green / Utilities Manager			FAYETTEVILLE	CUAL				-
	y of Arkadelphia								
MAILI	NG ADDRESS:			FAYETTEVILLE					-
-	Box 495 STATE, ZIP:			INSPECTION PARTICIPANTS					
	cadelphia AR 71923			Christi Daniel/Operator and Lab Tech(Lic. #:					
PHON	E & EXT: / FAX:			007392)/870-246-0697/christi.daniel@arkadelphia.gov					
870 EMAIL)-246-5863 / 870-246-9546			David Thomason/Operator (Lic. #001842)/870-264-5863					
	vid.green@arkadelphia.gov								
CC	NTACTED DURING INSPECTION	No							
	(S=S	atisfac	AREA EVA tory, M=Marginal, U=Unsati		/Evaluated)			
S	PERMIT	S	FLOW MEASUF		S	STOR	MWA	TER	
S	RECORDS/REPORTS	S	LABORATORY		S				
Μ	OPERATION & MAINTENANCE	S		CEIVING WATER					G PROGRAM
S	SAMPLING	S	SLUDGE HAND	LING/DISPOSAL	S	PRETF	REATI	MENT	
**	OTHER:								
4.1	There is successive us actually in	414.4	SUMMARY C			400 A 01		41	
	There is excessive vegetation in						and	the aqu	laculture
po	nd (see Photos 11-13). This is a v	1012	ation of permit co	ondition Part III.	(В.) (1.) (A.).			
2 \	Composito compling is being or	mnl	lated as a time w	aighted collectio	n and	not o fl		aiahtar	deallection
	Composite sampling is being co is is a violation of permit condition	-		-		not a lie	0w-w	eigniet	
m	is is a violation of permit conditio	115 1	rait II. (0.) (D.) (4	.) (a.) and Part IV	. (0.).				
3.)	3.) There was no thermometer in the composite sampler (see Photo 24) to monitor the temperature to maintain								

a 0-6° C for proper preservation. This is a violation of permit condition Part III. (C.) (3.).

GENERAL COMMENTS

On May 13, 2020, I performed an inspection at the City of Arkadelphia WWTP with the above participants in attendance. City of Arkadelphia operates a treatment plant with a design consisting of an aerated industrial pretreatment lagoon, followed by three oxidation lagoons, followed by an aquaculture pond with an aeration cell, followed by disinfection through hypochlorite bleach and dechlorination using sodium bisulfite, flow monitoring through a rectangular weir with end contractions and totalizer, and discharge from Outfall 001 to the Ouachita River (see Figure 1). Sample collection and analysis is completed by City of Arkadelphia for all parameters except Whole Effluent Toxicity (WET) Testing. This inspection consisted of a facility inspection, laboratory inspection, and records review.

Facility Inspection:

Operator David Thomason explained that there is currently no industrial process wastewater treated in the aerated industrial pretreatment lagoon and that domestic waste from the industrial park is the majority of the discharges when there is no stormwater. At the time of inspection, there was an intruding cover of Water Hyacinth (Eichhornia crassipes) in the pond and other reed plants were established (see Photos 1-2). There was a steady discharge from the aerated industrial pretreatment lagoon (see Photo 3) that was being routed to the primary oxidation lagoon. At the main lift station, there is an automatic bar screen (see Photo 4) and the water is pumped to the primary oxidation lagoon (see Photos 5-6). From the primary lagoon, water gravity flows to the second lagoon (see Photos 7-8) and then to the third lagoon (see Photo 9). From the third lagoon, water gravity flows to the aquaculture pond, which had excessive vegetation on the surface and outside of the vegetation cells (see Photos 10-13). Water discharges from the aquaculture pond to the chlorine contact chamber (see Photo 14) and the water is injected with liquid hypochlorite bleach and allowed to have contact time in the contact chamber (see Photos 15-16). Flow is measured through a rectangular weir with end contractions and a totalizer (see Photo 17), and the treated effluent is dechlorinated using sodium bisulfite prior to the sampling point (see Photo 18). I observed the tanks and feeding system for the bleach (see Photos 19-21) and observed the totalizer (see Photo 22). This facility documents the instantaneous and totalized flow daily (see Photo 23), and I observed the refrigerated composite sample (see Photo 24), which lacked a thermometer and was incapable of performing a flow-weighted composite. Mr. Thomason and I walked to the Outfall 001 discharge point at the Ouachita River and observed a large concrete pipe submerged under the water (see Photos 25-26).

Laboratory Inspection:

Prior to the facility inspection, I observed the methods utilized to analyze wastewater samples for City of Arkadelphia. Christi Daniel, operator and lab tech, preforms all analyses on wastewater for the City of Arkadelphia. I observed the calibration records for pH (see Photo 27) and the calibration sheet for the Dissolved Oxygen (DO) meter (see Photo 28), which contained all the required information. A field meter is used for DO measurements at the sampling point for Outfall 001, and a separate desktop DO meter is used for the Biochemical Oxygen Demand (BOD5) analysis (see Photo 29). Filter paper (see Photo 30), drying ovens (see Photo 31-32), desiccant (see Photo 33), and weights (see Photos 34-35) were all in good condition and in compliance with the analytical method. Temperature is monitored in the BOD5 cooler (see Photo 36) and the fecal coliform bath (see Photo 37) using a digital thermometer that is replaced annually.

Records Review:

Collection records for samples provide a good chain of custody (COC) and analysis records also contained all the required information (see Photos 38-40). Additionally, all the totals tabulated on the spreadsheets for the facility are correct, and the information reviewed in NetDMR did not have any inconsistencies.

Note: This facility was inspected on July 12, 2018; however, no report was drafted. This CEI documents current conditions and replaces the observations made during the 2018 inspection.

Milles	
INSPECTOR'S SIGNATURE: Michael Young	DATE: 6/3/2020
Kerri MS Cale	
SUPERVISOR'S SIGNATURE:Kerri McCabe	DATE: 6/3/2020

Inspection Report: Arkadelphia WWTP, AFIN: 10-00463, Permit #: AR0020605

Inspection Report: Arkadelphia WWTP, AFIN: 10-00463, Permit #: A	
SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	ØS OM OU ONA ONE
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	Øy 🛛 n 🗆 na 🗆 ne
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	
4. ALL DISCHARGES ARE PERMITTED:	
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	
DETAILS:	
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	Øs 🗆m 🗇u 🗇na 🗇ne
a. DATES AND TIME(S) OF SAMPLING:	
b. EXACT LOCATION(S) OF SAMPLING:	
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	
d. ANALYTICAL METHODS AND TECHNIQUES:	
e. RESULTS OF CALIBRATIONS:	
f. RESULTS OF ANALYSES:	
g. DATES AND TIMES OF ANALYSES:	
h. NAME OF PERSON(S) PERFORMING ANALYSES:	
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	Øs 🗆m 🗇u 🗇na 🗇ne
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	Øs 🗆m 🗇u 🗇na 🗇ne
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	
DETAILS:	·
1. TREATMENT UNITS PROPERLY OPERATED:	OS ØM OU ONA ONE
2. TREATMENT UNITS PROPERLY MAINTAINED:	
	🗆 s 🗹 m 🗇 u 🖾 na 🖾 ne
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	OS ØM OU ONA ONE Øs Om Ou Ona One
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	Øs 🗆m 🗇u 🖾na 🖾ne
 STANDBY POWER OR OTHER EQUIVALENT PROVIDED: ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: 	Øs Om Ou Ona One Øs Om Ou Ona One
 STANDBY POWER OR OTHER EQUIVALENT PROVIDED: ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: ALL NEEDED TREATMENT UNITS IN SERVICE: 	Øs Om Ou Ona One Øs Om Ou Ona One Øs Om Ou Ona One
 STANDBY POWER OR OTHER EQUIVALENT PROVIDED: ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: ALL NEEDED TREATMENT UNITS IN SERVICE: ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: 	Øs Im Iu Ina Ine
 STANDBY POWER OR OTHER EQUIVALENT PROVIDED: ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: ALL NEEDED TREATMENT UNITS IN SERVICE: ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED: 	Øs Im Iu Ina Ine
 STANDBY POWER OR OTHER EQUIVALENT PROVIDED: ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: ALL NEEDED TREATMENT UNITS IN SERVICE: ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED: OPERATION AND MAINTENANCE MANUAL AVAILABLE: 	Øs Im Iu Ina Ine Øy In Ina Ine
 STANDBY POWER OR OTHER EQUIVALENT PROVIDED: ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: ALL NEEDED TREATMENT UNITS IN SERVICE: ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED: OPERATION AND MAINTENANCE MANUAL AVAILABLE: STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED: 	ØS M U INA INE ØS M U INA INE ØS IM U INA INE ØY IN INA INE ØY IN INA INE ØY IN INA INE
 STANDBY POWER OR OTHER EQUIVALENT PROVIDED: ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: ALL NEEDED TREATMENT UNITS IN SERVICE: ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED: OPERATION AND MAINTENANCE MANUAL AVAILABLE: STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED: PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED: 	Øs Im Iu Ina Ine Øy In Ina Ine
 STANDBY POWER OR OTHER EQUIVALENT PROVIDED: ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: ALL NEEDED TREATMENT UNITS IN SERVICE: ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED: OPERATION AND MAINTENANCE MANUAL AVAILABLE: STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED: PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED: HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR: 	Øs Im Iu Ina Ine Øy In Ina Ine Øy In
 STANDBY POWER OR OTHER EQUIVALENT PROVIDED: ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: ALL NEEDED TREATMENT UNITS IN SERVICE: ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED: OPERATION AND MAINTENANCE MANUAL AVAILABLE: STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED: PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED: HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR: IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED: 	Øs Im Iu Ina Ine Øy In Ina Ine

SECTION D: SAMPLING	
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	ØS OM OU ONA ONE
DETAILS:	
1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	Øy 🛛 n 🗆 na 🗆 ne
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	Øy 🛛 n 🗆 na 🗆 ne
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	
a. SAMPLES REFRIGERATED DURING COMPOSITING:	
b. PROPER PRESERVATION TECHNIQUES USED:	
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	⊠S □M □U □NA □NE
DETAILS:	
 PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: Yes TYPE OF DEVICE: Rectangula with end contractions 	<u>rweir</u> Øy ⊡n ⊡na ⊡ne
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	Øy 🛛 n 🗆 na 🗆 ne
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:	Øy 🛛 n 🗆 na 🗆 ne
4. CALIBRATION FREQUENCY ADEQUATE:	Øy 🛛 n 🗆 na 🗆 ne
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	
9. HEAD MEASURED AT PROPER LOCATION:	
SECTION F: LABORATORY	
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	ØS OM OU ONA ONE
DETAILS:	
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	Øy 🛛 n 🖓 na 🖓 ne
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	
4. QUALITY CONTROL PROCEDURES ADEQUATE:	
5. DUPLICATE SAMPLES ARE ANALYZED >10% OF THE TIME:	
6. SPIKED SAMPLES ARE ANALYZED <u>></u> 10% OF THE TIME:	
7. COMMERCIAL LABORATORY USED:	
a. LAB NAME: <u>Arkansas Analytical</u>	
b. LAB ADDRESS: Little Rock	
c. PARAMETERS PERFORMED: WET Testing	
8. BIOMONITORING PROCEDURES ADEQUATE:	
a. PROPER ORGANISMS USED:	
b. PROPER DILUTION SERIES FOLLOWED:	
c. PROPER TEST METHODS AND DURATION:	
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	Øy On Ona One

SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS										
BASED ON VISUAL OBSERVATIONS ONLY 🗹 S 🗆 M 🗆 U 🗆 NA 🗆 NE										
DETAILS:										
OUTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER			
001	No	No	No	No	No	Colorless				
SECTION H: SLUDGE DISPOSAL										
SLUDGE DISPOSAL MEETS PERMIT REQUIREMENTS										
DETAILS:										
1. SLUDGE M	ANAGEMENT ADEQU	ATE TO MAINTAIN EF	FLUENT QUALITY:			⊠s ⊡m				
2. SLUDGE R	ECORDS MAINTAINE	DAS REQUIRED BY 40) CFR 503:			⊠s ⊡m				
3. FOR LAND	APPLIED SLUDGE, TY	PE OF LAND APPLIE	D TO: (E.G., FOREST,	AGRICULTURAL, PUE	BLIC CONTACT SITE):					
SECTION I:	SAMPLING IN	SPECTION PRO	DCEDURES							
SAMPLE F	RESULTS WITH	HIN PERMIT R	EQUIREMENT	S			U ⊠NA ⊡NE			
DETAILS:										
1. SAMPLES	OBTAINED THIS INSPI	ECTION:				ΠY	On Øna One			
2. TYPE OF S			/ETHOD: FREQUE	NCY:						
	PRESERVED:					ΠY	□n Øna □ne			
4. FLOW PRC	PORTIONED SAMPLE	S OBTAINED:				ΠY	🗆 n 🗹 na 🗆 ne			
5. SAMPLE O	BTAINED FROM FACIL	LITY'S SAMPLING DE	/ICE:			ΠY	🗆 n 🗹 na 🗆 ne			
6. SAMPLE R	EPRESENTATIVE OF	VOLUME AND NATUR	E OF DISCHARGE:			ΠY	🗆 n 🗹 na 🗆 ne			
7. SAMPLE S	PLIT WITH PERMITTEI	E:				ΠY	🗆 n 🗹 na 🗆 ne			
8. CHAIN-OF-	CUSTODY PROCEDU	RES EMPLOYED:				ΠY	□n Øna □ne			
9. SAMPLES	COLLECTED IN ACCO	RDANCE WITH PERM	IT:			ΠY	🗆 n 🗹 na 🗆 ne			
SECTION J	: STORM WAT	ER POLLUTION	PREVENTION	PLAN						
STORM W	ATER MANAG	EMENT MEET	S PERMIT RE	QUIREMENTS			U ØNA ⊡NE			
DETAILS:										
1. SWPPP UP	DATED AS NEEDED:	DATE OF LAST UP	DATE:			ΠY	□n Øna □ne			
2. SITE MAP	NCLUDING ALL DISCH	HARGES AND SURFA	CE WATERS:			ΠY	🗆 n 🗹 na 🗆 ne			
3. POLLUTIO	N PREVENTION TEAM	IDENTIFIED:				ΠY	□n Øna □ne			
4. POLLUTIO	N PREVENTION TEAM	PROPERLY TRAINED):			ΠY	□n Øna □ne			
5. LIST OF PC	DTENTIAL POLLUTAN	SOURCES:				ΠY	□n Øna □ne			
6. LIST OF PC	DTENTIAL SOURCES A	AND PAST SPILLS AND	D LEAKS:			ΠY	□n Øna □ne			
7. ALL NON-S	TORM WATER DISCH	ARGES ARE AUTHOR	RIZED:			ΠY	□n Øna □ne			
8. LIST OF ST	RUCTURAL BMPS:						🗆 n 🗹 na 🗆 ne			
9. LIST OF NO	ON-STRUCTURAL BMF	PS:				Ωy	□n Øna □ne			
10. BMPS PRC	PERLY OPERATED AI	ND MAINTAINED:				ΠY	□n Øna □ne			
11. INSPECTIO	INS CONDUCTED AS	REQUIRED:					□n Øna □ne			

Inspection Report: Arkadelphia WWTP, AFIN: 10-00463, Permit #: AR0020605

FLOW CALCULATION SHEET

Г

Date: 05/	13/2020	Time: 13:	03		
Head in Inc	ches: 5.64	Feet:	0.47		
Type & Siz	e of Primary Flov	w Measuren	nent Device:		
Name & Mo	odel of Secondar	y Flow Mea	surement Dev	vice: Siem	nens HydroRanger 200
Data of loo	t Calibratian of C			4 00 0000	
Date of las	t Calibration of Se	econdary F	Iow Device:	4-20-2020	
Recorded I	-low at Date & Ti	ime Listed A	Above: 1.998	3	(Facility Flow Meter)
Calculated	Flow at Date & T	Fime Listed	Above: 1.8	85	
•					
(Flow is calcula	ted using flow charts in:				ok-5 th Edition)
(Flow is calcula	ted using flow charts in:	: ISCO Open Cl	hannel Flow Measu		ok-5 th Edition)
	Recorded Valu	: <u>ISCO Open Cl</u> le - Calc	hannel Flow Measu		ok-5 th Edition)
(Flow is calcula % Error =	Recorded Valu	: ISCO Open Cl	hannel Flow Measu	rement Handbo	ok-5 th Edition)
% Error =	Recorded Valu	ISCO Open Cl e - Calc culated Valu	hannel Flow Measu	X 100	ok-5 th Edition)
	Recorded Valu Cal	: <u>ISCO Open Cl</u> ie - Calc culated Vali	hannel Flow Measu culated Value ue	rement Handbo	ok-5 th Edition)
% Error = % Error =	Recorded Valu Cale	ISCO Open Cl e - Calc culated Valu - 1.885	hannel Flow Measu culated Value ue	X 100	<u>ok-5th Edition)</u>
% Error = % Error =	Recorded Valu Cal	ISCO Open Cl e - Calc culated Valu	hannel Flow Measu culated Value ue	X 100	<u>ok-5th Edition)</u>
% Error = % Error = % Error =	Recorded Valu Cale 1.998 0.113 1.885	: <u>ISCO Open Cl</u> ie - Calc culated Valu 1.885 - X 100	hannel Flow Measu culated Value ue	X 100	<u>ok-5th Edition</u>)
% Error = % Error = % Error =	Recorded Valu Calo 1.998 0.113	ISCO Open Cl e - Calc culated Valu - 1.885	hannel Flow Measu culated Value ue	X 100	<u>ok-5th Edition)</u>
% Error = % Error =	Recorded Valu Cale 1.998 0.113 1.885	: <u>ISCO Open Cl</u> ie - Calc culated Valu 1.885 - X 100	hannel Flow Measu culated Value ue	X 100	<u>ok-5th Edition)</u>

DMR Calculation Check

Reporting Period:	From	<u>2020</u> Year	02 Month	01 Day	_ To _	2020 Year	02 Month	29 Day
Parameter Checked:		TSS	-					
		Loading Mass					ntration hthly	
	Mo.	Avg Ibs/c	lay	Mo. A	vg r		7-day Avg	mg/l
Reported Value:		212.1			6.3		10.0)
Calculated Value:		212.1	·		6.3		10.0)
Permit Value:		2252.0			90		135	

If calculated value does not equal reported value, explain:


<u>Equal</u>

DMR Calculation Check


Reporting Period:	From	2020 Year	03 Month	01 Day	_ To _	2020 Year	03 Month	<u>31</u> Day
Parameter Checked:		BOD5	-					
		Loading Mass				Concer Mon		
	Mo.	Avg Ibs/d	lay	Mo. A	vg r	ng/l	7-day Av	g mg/l
Reported Value:		400			16		16.	2
Calculated Value:	. <u></u>	400	·		16		16	2
Permit Value:		751			30		4	5


If calculated value does not equal reported value, explain:

<u>Equal.</u>




































Water Division	Photographic Evidence Sheet	
Location: Arkadelphia WWTP		
Photographer: Michael Young	Date: 05/13/2020	Time: 11:13
Witness:	· ·	Photo #: 27
Description: Calibration records for pH n	neter.	
W-E 200 Da U1-20-20 Da U1-20-20<	$\begin{array}{ c c c c c c c c c c c c c c c c c c c$	3
Photographer: Michael Young	Date: 05/13/2020	Time: 11:13
Witness:		Photo #: 28
	Antern Antern A Data A Antern A Data A Antern A Data A Anterno Data A A Anterno Oriso Data A Solido Data Data A Anterno Orior CD A Solido Data Data A Solido Data Data A Anterno Or	












Water Division Photographic Evidence Sheet Location: Arkadelphia WWTP Photographer: Michael Young Date: 05/13/2020 Time: 11:32 Witness: Photo #: 39 Description: | Collection records for composite samples serve as a Chain of Custody (COC). Day Chain Of Custody For Outfall 001 24 Hour Composite m Month: Astruces Month: ALLY WOLL Vear 20.00 Set-Up Date/Time Start Date/Time End Date/Time Programmer DQ. Sample Collected For Analysis Date/Time Taken By: 1/21 032 3/02 0300 3/02 0700 CD 2/03 09:9 CD (2) 1000 2016 (2) 0000 2016 0000 2016 000 2016 (2) 1080 2016 (2) 0000 2016 000 2016 2016 00 pa 2/01 as assa alle assa asle capa 0930 00 13 0943 7/13 0800 2/13 0700 CD Fail DT 0943 7/13 0800 7/14 0800 DT 7/14 08 42 DT 81 0843 /17 0800 /18 ORW DT 2/18 0840 254 114 0741 2/18 0745 2/19 0745 CD 107 219 075 2/17 2/19 6000 16/6 6000 00% 0000 077 2/01 an arto 00 2/19/09 0757 260 0800 2/24 0700 P/24 0911 00 C.F OF 2/200 0910 0912/2/25 0700 2/2. 0700 CD 121 00 2/20 2/21 2/27 0921 0911 2/27 0700 2/28 0700 CD 0° 2/22 CA22 3/01 0700 3/02 0700 08 2/24 09 2/24 0 0A 05.13.2020 Photographer: Michael Young Date: 05/13/2020 Time: 11:33 Photo #: 40 Witness: Description: Collection records for composite samples serve as a COC. Chain Of Custody For Outfall 001 24 Hour Composite Februar Pomposite Collection Set-Up Sample Collected For Analysis Date/Time Taken B Set-Up Date/Time Takon By: Start Date/Time End Date/Time Programmer 0931 203 0919 2/02 0700 2/02 0700 (2) 205 0907 00 CO 2010 2016 0000 1016 0690 2/05 201 0901 00 an arra role ara unle 500 2/01 2/10 (930 (0) as assa alle casa alle capa 022 2/2 0700 2/13 0700 00 Fail 714 0842 14 0800 DT 0 843 13 0800 CD 0843 717 0820 718 0800 DT 2/17 0740 114 2/18 2/9 0755 S 2/18 0745 2/19 0745 CD 0741 CD 2/01 0770 CD COTO 16/0 0000 06/0 0000 00 2/24 CAU CA 0757 2/03 0700 464 0700 2/210 OPID CD 0700 1/2 000 00 0912 2/25 121 0911 2/27 0700 761 070 CD 2/27 0921 CD 2/22 0700 3/00 0700 C920 3/01 00 2/57 05 13 2020

Figure 1. Overview of City of Arkadelphia WWTP with location of treatment components and discharge point.



June 15, 2020

Michael Young District 8 Inspector 5301 Northshore Drive North Little Rock, AR 72118

RE: Arkadelphia WWTP Inspection Response/ Permit No. AR0020605

Dear Mr. Young;

I have read and reviewed your reports of the facility from your inspection May 13th and have the following response for the violations listed in each "Summary of Findings" section.

Lagoons/Lab Inspection Report

1. There is excessive vegetation in the aerated, pretreatment lagoon and the aquaculture pond. This is a violation of permit condition Part III. (B.) (1.) (A.).

We are currently in the process of treating the excessive vegetation in the lagoon with the herbicide Rodeo. The first treatment had been applied prior to your May 13th inspection. Our Notice of Coverage states a start date of 4/01/2020 with an approximate end date of 10/31/2020. Each treatment is applied in accordance to the instructions on the herbicide label and all state laws and regulations.

2. Composite sampling is being completed as a time-weighted collection and not a flowweighted collection. This is a violation of permit conditions Part II. (8.) (B.) (4.) (a.) and Part IV. (8.).

We have requested a technician from Instrument and Supply to inspect and conclude as to why the refrigerated sampler freezes up whenever a flow weighted sample is in the process of being collected. The sampler will be repaired as soon as possible. 3. There was no thermometer in the composite sampler to monitor the temperature to maintain a 0-6°C for proper preservation. This is a violation of permit condition Part III. (C.) (3.).

Not long before the inspection an issue with the primary sampler caused the switch to a back-up sampler and not placing the thermometer in the new sampler was just an oversight that has been corrected.

South Pump Station Inspection Report

1. Materials from the drain box for the bar screen were removed and placed on ground and drain is clogged. This is a violation of permit condition Part **1.7**.

The drain has been unclogged. We will monitor the area more closely in the future as well as speaking with the Sanitation Department about collecting the contents of the dumpster more frequently to prevent overflow onto the ground.

If you have any questions please don't hesitate to contact me.


Sincere David Green

Water & Sewer Utilities Manager City of Arkadelphia PO Box 495 Arkadelphia, AR 71923 870-246-5863 david.green@arkadelphia.gov

cd

1) *Lagoons*





1) South Pump Station



3)

72118-592801

· . ·

، فرزود وراغلو او دار المار الفائل داغل الواد الفائل المراغ والمراغ د الزارات ال

Michael Young District 8 Inspector 5301 Northshore Drive North Little Rock, AR 72118





700 Clay Street • P. O. Box 495 Arkadelphia, Arkansas 71923

. .

13771E-ROCK - AR 722 - 18-A.W 20 - PM-4 L



July 2, 2020

David Green, Utilities Manager City of Arkadelphia PO Box 495 Arkadelphia, AR 71923

RE: City of Arkadelphia - Response to Inspections (Clark Co) AFIN: 10-00463 NPDES Permit No.: AR0020605 ARR000190

Dear Mr. Green:

I have reviewed the response pertaining to my May 13, 2020 inspections of the City of Arkadelphia WWTP. The information provided sufficiently addresses the violations referenced in my inspection reports. At this time, the Department has no further comment concerning these particular inspections. Acceptance of this response by the Department does not preclude any future enforcement action deemed necessary at this site or any other site.

If we need further information concerning this matter, we will contact you. Thank you for your attention to this matter. Should you have any questions, feel free to contact me at (501) 837-2073 or you may e-mail me at <u>youngm@adeq.state.ar.us</u>.

Sincerely,

Ming

Michael Young District 8 Inspector Office of Water Quality