

ENVIRONMENTAL QUALITY

August 13, 2020

Paul Graham, General Manager Heber Springs Water and Sewer Commission 1108 West Front Street Heber Springs, AR 72543

RE: Heber Springs WWTP Inspections (Cleburne Co)

AFIN: 12-00029 NPDES Permit No.: AR0022381

Dear Mr. Graham:

On July 7, 2020, I performed a Compliance Evaluation Inspection and an SSO/Collection System Inspection of the above-referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. A copy of each of the inspection reports is enclosed for your records.

Please refer to the "Summary of Findings" section of each the attached inspection reports and provide a written response for each violation that was noted. This response should be mailed to the attention of the Office of Water Quality Compliance Branch at the address at the bottom of this letter or e-mailed to Water-Inspection-Report@adeq.state.ar.us. This response should contain documentation describing the course of action taken to correct each item noted. This corrective action should be completed as soon as possible, and the written response with all necessary documentation (i.e., photos) is due by August 27, 2020.

If I can be of any assistance, please contact me at harmont@adeq.state.ar.us or (501) 837-2070.

Sincerely,

Travis Hormun

Travis Harmon
District 5 Inspector

Office of Water Quality

	<u>'</u>	_						
^	RKANSAS ENVIRONMENTAL QUALITY	OFFICE OF WATER QUALITY INSPECTION REPORT						
		AFIN: 12-00029 PERMIT #: AR002238		2381		DATE:	7/7/2020	
		CC	DUNTY: 12 Clebu	rne	PDS:	#: 112973	•	MEDIA: WN
		GF	GPS LAT: 35.485717 LONG: -91.995			OCATION:	General	Area
	FACILITY INFORMAT	IN	SPEC	TION INFO	RMATIO	N		
	ber Springs WWTP			facility type: 1 - Municipal		ror id#: 89 S - State)	
	≀⊓on: 74 Bypass Road	FACILITY EVALUATION RATING 2 - Marginal		Co	CTION TYPE: mpliance	Evaluation		
He	ber Springs, AR 72543			· '	TRY TIME: 9:30	12:30		FFECTIVE DATE:
	RESPONSIBLE OFFIC	CIAL	-	17172020	3.00	12.00	1/1/2 PERMIT E	U19 EXPIRATION DATE:
	E: / TITLE							/2023
Paul Graham / General Manager				FAYETTEVILLE SHALE RELATED: N				
	ber Springs Water and Sewer Co	mmi	ission	FAYETTEVILLE SHALE VIOLATIONS: N				
MAILI	NG ADDRESS:			INSPECTION PARTICIPANTS				
	08 West Front Street			NAME/TITLE/PHONE/FAX/EMAIL/ETC.:				
He	ber Springs AR 72543			Mr. Joey Massey/ WWTP Mgr.				
	NE & EXT: / FAX:			Mr. Carl Johnson/ Operator				
DU'	1-362-3422 / :							
pa	ul@heberspringswater.com							
	wwtp@heberspringswater.com							
CC	INTACTED DURING INSPECTION:	Ye						
	(S=S:	atisfac	AREA EVA	LUATIONS isfactory, N=Not Applicable	/Evaluated))		
S	PERMIT	S	FLOW MEASUR		N	STORMV	VATER	
S	RECORDS/REPORTS	S	LABORATORY		N	FACILITY	' SITE RE	EVIEW
M	OPERATION & MAINTENANCE	S		CEIVING WATER	N			NG PROGRAM
S	SAMPLING	S	SLUDGE HAND	LING/DISPOSAL	N	PRETRE	ATMENT	
N	OTHER:							
			SHMMARY	JE EINDINGS				

SUMMARY OF FINDINGS

The following violations were noted during the last inspection:

- 1. The 2019 annual DMR for TP/NO3+NO2-N does not include analysis results. This information is required in DMR per Part I.A1 of the permit. The facility provided TP/NO3+NO2-N analysis results for 2019 during the inspection. The facility must resubmit the 2019 DMR (002-Y) with the analysis results entered. TP/NO3+NO2-N do not have limits, but the results are required to be reported (see screenshot on Page 15 of 16 of this report).
- 2. At the time of inspection, an airline had a leak. This is a violation of Part III.B.1.A of the permit. The leak should be repaired when conditions allow. Also, some vegetation is established along the 3-cell lagoon. Please see Photos #3-4.

GENERAL COMMENTS

Introduction

I inspected on July 7, 2020. Mr. Joey Massey, WWTP Manager, and Mr. Carl Johnson, Operator, represented the facility during the inspection. Heber Springs operates a POTW with two treatment systems and two outfalls. Outfall 002 (at 1.75 MGD) consists of a bar screen/grinder, 3-cell lagoon with air, rapid sand filtration, and UV disinfection. Outfall 003 (at 1.75 MGD; Emergency Only) consists of wastewater from the bar screen/grinder and 3-cell lagoon at 002 discharged to an equalization basin, if 002 is discharging 1.5 MGD.

Treatment System Inspections

I inspected both systems. At the 3-cell lagoon (002) I observed a leak from an airline, which needs repaired. No other operational or maintenance issues were observed concerning the treatment system at 002. There is some levee vegetation established along the northwestern section of the 3-cell lagoon. The UV disinfection system was in operation and flow is monitored via an in-line meter. I collected a sample for visual observation from the sample collection point. Final effluent appeared sufficiently treated. There was some water stored at the 003 lagoon with no incoming influent or discharge. Levee vegetation was maintained. There was no discharge from 003 from June 2019 through May 2020.

Records Review

I reviewed DMR from June 2019-May 2020 prior to the inspection. There were no exceedances reported during this time. There was no discharge from 003 during this time. I also reviewed the four sample custody/analysis sheets for weekly samples collected in December 2019, associated flow records, bio-monitoring report, TP and NO3+NO2-N analysis for 2019, and records for 003 required in Part II.10 and 11.

·	
Travis Horman	
INSPECTOR'S SIGNATURE: Travis Harmon	DATE: 7/28/2020
Kerri Mª Cale	
SUPERVISOR'S SIGNATURE:Kerri McCabe	DATE: 8/12/2020

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	☑S □M □U □NA □NE
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	⊠y □n □na □ne
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	□Y □N ☑NA □NE
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	Øy □n □na □ne
4. ALL DISCHARGES ARE PERMITTED:	☑Y □N □NA □NE
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	☑S □M □U □NA □NE
DETAILS: No TP/ NO3+NO2-N results reported in annual 2019 DMR (002-Y); analysis was	conducted as required.
ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	Øy □n □na □ne
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	⊠s □m □u □na □ne
a. DATES AND TIME(S) OF SAMPLING:	☑Y □N □NA □NE
b. EXACT LOCATION(S) OF SAMPLING:	ØY □N □NA □NE
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	Øy □n □na □ne
d. ANALYTICAL METHODS AND TECHNIQUES:	Øy □n □na □ne
e. RESULTS OF CALIBRATIONS:	□Y □N □NA ☑NE
f. RESULTS OF ANALYSES:	Øy □n □na □ne
g. DATES AND TIMES OF ANALYSES:	ØY □N □NA □NE
h. NAME OF PERSON(S) PERFORMING ANALYSES:	ØY □N □NA □NE
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	□S □M □U □NA ☑NE
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	□S □M □U □NA ☑NE
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	Øy □n □na □ne
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	□S ØM □U □NA □NE
DETAILS:	
TREATMENT UNITS PROPERLY OPERATED:	⊠s □m □u □na □ne
2. TREATMENT UNITS PROPERLY MAINTAINED: One airline joint loose or with hole, with spray to air.	□S ☑M □U □NA □NE
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	⊠S □M □U □NA □NE
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	□S □M □U ☑NA □NE
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	⊠S □M □U □NA □NE
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	⊠s □m □u □na □ne
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	⊠S □M □U □NA □NE
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	ØY □N □NA □NE
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	Øy □n □na □ne
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	Øy □n □na □ne
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:	□y Øn □na □ne
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	□Y □N ☑NA □NE
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	□Y □N ☑NA □NE
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	□y Øn □na □ne
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:	□y □n ☑na □ne

SECTION D: SAMPLING	
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DETAILS:	
1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	☑y □n □na □ne
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	☑Y □N □NA □NE
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	☑y □n □na □ne
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	☑y □n □na □ne
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	☑Y □N □NA □NE
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	☑y □n □na □ne
a. SAMPLES REFRIGERATED DURING COMPOSITING:	☑Y □N □NA □NE
b. PROPER PRESERVATION TECHNIQUES USED:	☑Y □N □NA □NE
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	☑Y □N □NA □NE
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	□y □n ☑na □ne
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	⊠S □M □U □NA □NE
DETAILS: Closed pipe with in-line meter.	
PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: TYPE OF DEVICE:	□y □n ☑na □ne
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	☑y □n □na □ne
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED: <u>In-line meter</u>	☑Y □N □NA □NE
4. CALIBRATION FREQUENCY ADEQUATE:	□Y □N ☑NA □NE
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	□y □n ☑na □ne
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	□y □n ☑na □ne
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	□y □n ☑na □ne
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	□y □n ☑na □ne
9. HEAD MEASURED AT PROPER LOCATION:	□Y □N ☑NA □NE
SECTION F: LABORATORY	
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DETAILS:	
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES):	☑Y □N □NA □NE
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	□y □n ☑na □ne
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	□Y □N □NA ☑NE
4. QUALITY CONTROL PROCEDURES ADEQUATE:	☑Y □N □NA □NE
5. DUPLICATE SAMPLES ARE ANALYZED >10% OF THE TIME:	☑Y □N □NA □NE
6. SPIKED SAMPLES ARE ANALYZED ≥10% OF THE TIME:	✓Y □N □NA □NE
7. COMMERCIAL LABORATORY USED:	☑Y □N □NA □NE
a. LAB NAME: Arkansas Testing Laboratories	
b. LAB ADDRESS: 3301 Langley Drive, Searcy, AR 72143	
c. PARAMETERS PERFORMED: BOD, TSS, FCB, TP, NO3+NO2-N	
8. BIOMONITORING PROCEDURES ADEQUATE: <u>American Interplex</u>	✓Y □N □NA □NE
a. PROPER ORGANISMS USED:	MY ON ONA ONE
b. PROPER DILUTION SERIES FOLLOWED:	✓Y □N □NA □NE
c. PROPER TEST METHODS AND DURATION:	✓Y □N □NA □NE
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	□Y □N ØNA □NE

Г		•		•	0029, Permit #: A	R0022381				
	: EFFLUENT/R			ATIONS						
BASED ON	N VISUAL OBS	ERVATIONS C	NLY			ØS □M □	U DNA DNE			
DETAILS:_	Viewed at samp	ole collection po	oint at 002 (lago	oon system); no	o discharge at 00	<u>3.</u>				
OUTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER			
001	None	None	Slight	None	None	Slight green				
						L				
SECTION H	: SLUDGE DIS	POSAL								
	DISPOSAL ME		EQUIREMEN	TS		MS DM D	U DNA DNE			
					50); Statement of					
4463-WG-W				_ (/ 00)	,		ing moto onto			
1. SLUDGE M	IANAGEMENT ADEQU	ATE TO MAINTAIN EFI	FLUENT QUALITY:			⊠s □m	□U □NA □NE			
2. SLUDGE R	ECORDS MAINTAINED	AS REQUIRED BY 40	CFR 503:			□s □м	□U □NA ☑NE			
3. FOR LAND	APPLIED SLUDGE, TY	PE OF LAND APPLIED	TO: (E.G., FOREST,	AGRICULTURAL, PUE	BLIC CONTACT SITE):					
SECTION I:	SAMPLING IN	SPECTION PRO	CEDURES							
SAMPLE F	RESULTS WITH	HIN PERMIT RI	EQUIREMENT	S			U ⊠NA □NE			
DETAILS:					1					
1. SAMPLES	OBTAINED THIS INSPE	ECTION:				□Y	□n Øna □ne			
2. TYPE OF S	SAMPLE: GRAB:	□COMPOSITE: M	IETHOD: FREQUE	NCY:						
2. TYPE OF SAMPLE: □GRAB: □COMPOSITE: METHOD: FREQUENCY: 3. SAMPLES PRESERVED: □Y □N ☑N □N □NE										
4. FLOW PROPORTIONED SAMPLES OBTAINED:										
5. SAMPLE O										
6. SAMPLE R										
7. SAMPLE S	PLIT WITH PERMITTER	E:				□Y	□n Øna □ne			
8. CHAIN-OF-	CUSTODY PROCEDUI	RES EMPLOYED:				□Y	□n Øna □ne			
9. SAMPLES										
	The state of the s									
SECTION J	: STORM WATE	ER POLLUTION	PREVENTION	PLAN						
STORM W	ATER MANAG	EMENT MEET	S PERMIT RE	QUIREMENTS	;	□S□M□	U □NA ☑NE			
DETAILS:					<u> </u>					
1. SWPPP UF	PDATED AS NEEDED:_	_ DATE OF LAST UP	DATE:			□Y	□n □na ☑ne			
2. SITE MAP	INCLUDING ALL DISCH	HARGES AND SURFAC	E WATERS:			□Y	□N □NA ☑NE			
3. POLLUTIO	N PREVENTION TEAM	IDENTIFIED:				□Y	□n □na ☑ne			
4. POLLUTIO	N PREVENTION TEAM	PROPERLY TRAINED	:			□Y	□n □na ☑ne			
5. LIST OF PO	OTENTIAL POLLUTANT	SOURCES:				□Y	□N □NA ☑NE			
6. LIST OF PO	OTENTIAL SOURCES A	AND PAST SPILLS AND) LEAKS:			□Y	□N □NA ☑NE			
7. ALL NON-S	STORM WATER DISCH	ARGES ARE AUTHOR	IZED:				□n □na ☑ne			
8. LIST OF ST	RUCTURAL BMPS:						□n □na ☑ne			
9. LIST OF NO	ON-STRUCTURAL BMF	PS:					□n □na ☑ne			
10. BMPS PRC	PERLY OPERATED A	ND MAINTAINED:					□N □NA ☑NE			
	ONS CONDUCTED AS I						□N □NA ☑NE			

$Inspection \ Report: \ \textbf{Heber Springs WWTP}, \ AFIN: \textbf{12-00029}, \ Permit \ \#: \ \textbf{AR0022381}$

DMR Calculation Check

Reporting Period:	From	2019	12	01	_ To	2019	12	31
		Year	Month	Day		Year	Month	Day
Parameter Checked:		TSS	_					
		Loading				Concer		
		Mass				Mon	ithly	
	Mo.	Avg Ibs/	day	Mo. A	vg r	ng/l	7-day Avç	J mg/l
Reported Value:		71.18			9.25		12.0	0
Calculated Value:		71.18			9.25		12.	0
Permit Value:		292			20		30	

If calculated value does not equal reported value, explain:

$Inspection \ Report: \ \textbf{Heber Springs WWTP}, \ AFIN: \textbf{12-00029}, \ Permit \ \#: \ \textbf{AR0022381}$

DMR Calculation Check

Reporting Period:	From	2019	12	01	_ To	2019	12	31
		Year	Month	Day		Year	Month	Day
Parameter Checked:		BOD	_					
		Loading				Concer		
	Ma	Mass	ala	Ma A		Mon	_	
	IVIO.	Avg lbs/	uay	Mo. A	wg i	iig/i	7-day Avg	j mg/i
Reported Value:		41.68			5.4		6.0)
Calculated Value:		41.68			5.4		6.0)
Permit Value:		292			20		30	


If calculated value does not equal reported value, explain:

Office of Water Quality Photographic Evidence Sheet Location: Heber Springs WWTP Photographer: Travis Harmon Date: 7/7/2020 Time: 0945 Witness: None; no other regulatory personnel Photo #: 1 Description: Plant influent bar screens and grinders.



Photographer:Travis HarmonDate:7/7/2020Time:0951Witness:NonePhoto #:2







Office of Water Quality Photographic Evidence Sheet Location: Heber Springs WWTP Photographer: Travis Harmon Date: 7/7/2020 Time: 1021 Witness: None Photo #: 7


Description: UV disinfection.




Photograp	her:	Travis Harmon	Date:	7/7/2020	Time:	1017
Witness:	None				Photo 7	# : 8

Description: In-line flowmeter.









Photographer: Travis Harmon	Date: 7/7/2020	Time:	
Witness: None		Photo #:	12




Figure 1. Screenshot of Outfall 002 2019 Annual TP/NO2+NO3-N DMR.





Figure 2. Google Earth image.





Heber Springs Water and Wastewater Utility 1108 W. Front St. Heber Springs, AR 72543 Phr (501) 362-3422, Fax: (501) 362-3338 hswd@heberspringswater.com

August 18, 2020

Office of Water Quality Compliance Branch ADEQ 5301 Northshore Dr. Little Rock, AR 72118-5137

Re: Heber Springs WWTP Inspections (Cleburne Co.) AFIN: 12-00029 NPDES Permit No.: AR0022381

To Whom It May Concern,

After receiving the inspection report dated August 13, 2020, I reviewed the "Summary of Findings" and contacted the Wastewater Treatment Plant Manager, Joey Massey, immediately and we began the process of correcting the violations that were noted. Below, you will see the violation followed by our response to it.

1. 2019 Annual DMR for TP/NO3+NO2-N does not include analysis results.

On August 14, 2020 I entered in the TP/NO3+NO2-N results into the NetDMR database and submitted them. The reason we did not have them on the 002-Y was that our permit had recently changed to not require testing for that and we were unaware that it still needed to be done once a year. We did have it done, but we did not report it on NetDMR. That has been corrected and we now know what we need to do going forward. See attached picture.

2. A subsurface airline had a leak in it.

Mr. Massey determined what parts were needed to fix the leak and he had it repaired on August 18, 2020. The crew used a full-circle repair clamp to repair the line. Please see attached pictures.

2B. Vegetation is established along the 3-cell lagoon.


On August 18, 2020, Mr. Massey cut and removed the vegetation. Please see attached picture.

As of the date of this letter, all of the above violations have been mitigated. Please let me know if you need anything further. Thank you for your assistance.


Paul Graham, General Manager


Sineerely


1. The readings were 0.32 for Nitrate, and 2.30 for Phosphorous. 8/14/20



2 A. The crew repairing the broken airline in the lagoon. 8/18/20









2 B. Vegetation along the 3-cell lagoon has been removed. 8/18/20



HEBER SPRINGS WATER DEPARTMENT 1108 West Front Heber Springs, Arkansas 72543







September 14, 2020

Paul Graham, General Manager Heber Springs Water and Sewer Commission 1108 West Front Street Heber Springs, AR 72543

RE: Heber Springs WWTP - Response to Inspections (Cleburne Co)
AFIN: 12-00029
NPDES Permit No.: AR0022381

Dear Mr. Graham:

I have reviewed the response pertaining to my July 7, 2020 inspections of the Heber Springs WWTP and collection system. The information provided sufficiently addresses the violations referenced in my inspection reports. At this time, the Department has no further comment concerning these particular inspections. Acceptance of this response by the Department does not preclude any future enforcement action deemed necessary at this site or any other site.

If we need further information concerning this matter, we will contact you. Thank you for your attention to this matter. Should you have any questions, feel free to contact me at (501) 837-2070 or you may e-mail me at harmont@adeq.state.ar.us.

Sincerely.

Travis Harmon
District 5 Inspector

Office of Water Quality

Travis Hormun