



November 3, 2021

Honorable Joe Wise, Mayor City of Sheridan P.O. Box 44 Sheridan, AR 72150

RE: City of Sheridan WTF Inspection AFIN: 27-00022 Permit No.: AR0034347

Dear Mayor Wise:

On August 18, 2021, I performed a Compliance Evaluation Inspection of the above referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. A copy of the inspection report is enclosed for your records.

Please refer to the "Summary of Findings" section of the inspection report and provide a written response for the first item noted. This response should be mailed to the attention of the Office of Water Quality Compliance Branch at the address below my signature or emailed to <u>Water-Inspection-Report@adeq.state.ar.us</u>. This response should contain documentation describing the course of action taken to correct each item noted. The corrective action(s) should be completed as soon as possible and the written response with all necessary documentation (i.e. photos) is due by November 17, 2021.

If I can be of any assistance please contact me at <u>Bolenbaugh@adeq.state.ar.us</u> or 501-682-0659.

Sincerely,

Jan Relations

Jason Bolenbaugh Compliance Branch Manager, Office of Water Quality 5301 Northshore Drive, North Little Rock, AR, 72118

			OF	FICE OF W	ΙA	TE	ER QUA	<b>ALITY</b>	<b>7</b>
and the second s	UN DEFASTOR	INSPECTION REPORT							
V . ENER		AFIN: 27-00022 PERMIT #: AR003434		47		DATE:	8/18/2021		
	A 4ND ENVIRON	СС	OUNTY: 27 Grant		P	DS #	#: <b>118042</b>		MEDIA: WN
	GPS LAT: <b>34.30382</b>			8 LONG: -92.389	928	57 L(	OCATION:	Entrance	9
				INSPECTION INFORMATION					
NAME: City of Sheridan WTF			FACILITY TYPE:     INSPECTOR ID#:       1 - Municipal     83321 S - State       FACILITY EVALUATION RATING:     INSPECTION TYPE:						
Ga	atzke Drive			4 - Satisfactory Compliance Evaluation			Evaluation		
	eridan				NTRY '		EXIT TIME: 13:30		FFECTIVE DATE:
	RESPONSIBLE OFFIC	CIAL	-	0/10/2021 1	0.0		10.00	3/1/20 PERMIT EX	<b>J20</b> XPIRATION DATE:
	e: / TITLE Denorable Joe Wise / Mayor							2/28/2	2025
COM	IPANY:			FAYETTEVILLE	S⊦	HALE	E RELATED	D: N	
	ty of Sheridan			FAYETTEVILLE	SF	HALE		DNS: N	
P.(	O. Box 44						ION PART	ICIPANT	S
	r, state, zip: neridan AR 72150			NAME/TITLE/PHONE/FAX/EMA			Operator, C	citv of Sh	neridan
PHO	NE & EXT: / FAX:			Mr. David Fitzgerald, Operator, City of Sheridan Will Cody, OWQ Inspector, DEQ					
<b>87</b>	0-942-3921 /								
sh	ercity@windstream.net								
СС	ONTACTED DURING INSPECTION:	No							
	(5-5)	atisfar		LUATIONS isfactory, N=Not Applicable	/Fval	luated)			
S	PERMIT	S	FLOW MEASUR		/L vu	Ν	STORMW	ATER	
S	RECORDS/REPORTS	Ν	LABORATORY			S	FACILITY		
S	OPERATION & MAINTENANCE	Ν		CEIVING WATER		S			IG PROGRAM
S **	SAMPLING OTHER:	Ν	SLUDGE HAND	LING/DISPOSAL		Ν	PRETREA	IMENI	
	UTTER.		SUMMARY						
•	The weir box lacks a primary staf	f ga			or c	calib	ration che	cks to be	e conducted.
	Please install a primary staff gauge	ge. '	The outfall has s	econdary flow m	neas	suri	ng transdu	cer that	is calibrated
	annually.								
•	At Outfall 002, Discharge Monitor	_	• • •	•			-		
	May, 2021 but failed to conduct W			• • •					
	of the permit. WET testing was required between March and May. The permittee submitted a Non-								
	Compliance Report acknowledging a mistake was made with the sampling timeframe. No further action is required.								
	• The facility has the flexibility to discharge treated effluent to Big Creek through Outfall 001, to Hurricane						Hurricane		
	Creek through Outfall 002, or land apply under Permit 4694-WR-3. The facility's priority is first to discharge						to discharge		
	from Outfall 001 and then to Outfall 002. The pump system to Outfall 002 is automated which allows for								
	pumps to turn on or off depending on the flow reading within Hurricane Creek. If flows within Big Creek						-		
	reach the necessary rate to allow for discharge through Outfall 001, Mr. Fitzgerald will manually disengage								
	flows to Hurricane Creek prior to discharging from Outfall 001 as the permit does not allow for simultaneous								
	discharge to both waterbodies. Land application last occurred in 2018.								

- Treatment type consists of a 3-cell stabilization pond system followed by a holding pond. The first cell receives influent in the north side of the cell from the Guard Pack Pump Station and the Treatment Plant Pump Station.
- At Outfall 001, a review of the Whole Effluent Toxicity (WET) testing report was conducted. The report stated, "Due to cessation of flow, only two composites were sampled and used in testing". Flows within Big Creek can rise and fall rather quickly and although Mr. Fitzgerald collects four samples one hour apart, the flows can restrict the facility's ability to collect three composite samples prior to ceasing discharge due to flow restrictions.
- A review of DMRs was conducted from January 1, 2019 to May, 2021. During that time the permittee reported ten permit effluent limitation violations. The most recent violations were Fecal Coliform Bacteria in September, 2020. The submitted Non-Compliance Report suspected over 100 roosting Canada Geese on the holding pond was the cause for the exceedance.
- In addition to the Compliance Evaluation inspection, a Collection System Evaluation, and State No-Discharge inspection was also conducted. Please refer to those reports for greater detail.


INSPECTOR'S SIGNATURE:	←Click text to left to add signature	-Inspector Name	DATE:
	Jan Relation		
SUPERVISOR'S SIGNATURE		Jason Bolenbaugh	DATE: 11/2/2021

Inspection Report: City of Sheridan WTF, AFIN: 27-00022, Permit #: AR0034347

Inspection Report: City of Sheridan WIF, AFIN: 27-00022, Permit #: AR0	034347
SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	ØS OM OU ONA ONE
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	
4. ALL DISCHARGES ARE PERMITTED:	Øy 🛛n 🖾na 🖾ne
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	ØS OM OU ONA ONE
DETAILS: Reviewed March 13, 2020 Chain-of-Custody and sampling data.	
ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	
a. DATES AND TIME(S) OF SAMPLING: March 13, 2020, 07:15 to 10:53	
b. EXACT LOCATION(S) OF SAMPLING: Outfall 001	
c. NAME OF INDIVIDUAL PERFORMING SAMPLING: Randy Calver (City of Sheridan), Clint Wood (AR Analytical)	
d. ANALYTICAL METHODS AND TECHNIQUES:	
e. RESULTS OF CALIBRATIONS:	
f. RESULTS OF ANALYSES:	
g. DATES AND TIMES OF ANALYSES:	
h. NAME OF PERSON(S) PERFORMING ANALYSES: AR Analytical (Initials: CNW, JP, MH, AA, and SPS)	
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	
<ol> <li>PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:</li> <li>EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA: There are no loading rate</li> </ol>	
written in the permit effluent limitations.	
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	ØS OM OU ONA ONE
DETAILS:	
1. TREATMENT UNITS PROPERLY OPERATED:	
2. TREATMENT UNITS PROPERLY MAINTAINED:	
<ol> <li>STANDBY POWER OR OTHER EQUIVALENT PROVIDED: Backup generation is not necessary as short term power outages are not detrimental to the facility because the electrical components are not required to operate continuously.</li> </ol>	
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	OS OM OU ØNA ONE
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	🗹 S 🗆 M 🗇 U 🗆 NA 🗆 NE
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	Øs 🗆m 🗇u 🖾na 🗇ne
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	Øs 🗆m 🗇u 🖾na 🗇ne
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	Dy Dn Dna Øne
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	DY DN DNA ØNE
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR: No overflo have been reported from January 2019 to July 2021. Given the size of the lagoons it is unlikely bypasses will occur.	
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	Dy Dn Øna Dne
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	Dy Dn Øna Dne
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:	

SECTION D: SAMPLING	
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	ØS OM OU ONA ONE
DETAILS:	
1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	⊠y ⊡n ⊡na ⊡ne
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT: CBOD <sub>5</sub> , TSS, NH <sub>3</sub> -N, DO, FCB, and pH	
<ol> <li>SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT: Above listed parameters are collected t times per month. CBOD<sub>5</sub>, TSS, and NH<sub>3</sub>N are composite samples and DO, FCB, and pH are grab samples.</li> </ol>	
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	
a. SAMPLES REFRIGERATED DURING COMPOSITING: Composite samples are refrigerated following each one hour grab sar	
b. PROPER PRESERVATION TECHNIQUES USED:	🗹 Y 🗆 N 🗆 NA 🗇 NE
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	DY DN ØNA DNE
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	⊠S ⊡M ⊡U ⊡NA ⊡NE
DETAILS:	
1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED? TYPE OF DEVICE: The primary device Outfall 001 is a rectangular weir with end contractions. The crest length on the weir is 36-inches.	<sup>ce at</sup>
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:	
4. CALIBRATION FREQUENCY ADEQUATE:	
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	
<ol> <li>CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE: Calibration checks of the secondary flow measurin devices are completed annually. The primary rectangular weir at Outfall 001 lacks a staff gauge to attempt to conduct a cal check between the primary and secondary devices.</li> </ol>	
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE: No discharge	
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	
9. HEAD MEASURED AT PROPER LOCATION:	
SECTION F: LABORATORY	
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	ØS OM OU ONA ONE
DETAILS: WET testing in 3 <sup>rd</sup> quarter of 2020 did not meet requirements of the permit	
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	🗹 y 🗆 n 🗆 na 🖾 ne
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	Dy Dn Øna Dne
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	
4. QUALITY CONTROL PROCEDURES ADEQUATE:	
5. DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:	
6. SPIKED SAMPLES ARE ANALYZED <u>&gt;</u> 10% OF THE TIME:	
7. COMMERCIAL LABORATORY USED:	
a. LAB NAME: Arkansas Analytical, Inc.	
b. LAB ADDRESS: 8100 National Dr., Little Rock, AR, 72209	
c. PARAMETERS PERFORMED: WET, DO, pH, CBOD, TSS, NH <sub>3</sub> -N, FCB	
8. BIOMONITORING PROCEDURES ADEQUATE: 3 <sup>rd</sup> Quarter 2020 report evaluated (8/25/20 -9/1/20)	
a. PROPER ORGANISMS USED: Pimephales promelas and Ceriodaphnia dubia	
<ul> <li>b. PROPER DILUTION SERIES FOLLOWED: The dilution series and critical dilutions are different dependent upon the outfall a season.</li> </ul>	
c. PROPER TEST METHODS AND DURATION: EPA Method 1000.0 (P. promelase) and EPA Method 1002.0 (C. dubia)	Øy 🗆n 🗆na 🗇ne
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	Dy Dn Øna Dne

SE	SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS							
BA	BASED ON VISUAL OBSERVATIONS ONLY							
DETAILS: The facility was not discharging at the time of the inspection from Outfall 001. Outfall 002 is piped to								
Hurricane Creek and is not accessible. The flow calibration check sheet has been removed from the report due to no								
discharges at the time of the inspection.								
OL	JTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER
	001			-	-	-		
	002			-	-			
SE	CTION H	: SLUDGE DIS	POSAL					
SL	UDGE D	DISPOSAL ME	ETS PERMIT F		ſS		ØS OM O	U DNA DNE
		Sludge generate the sludge dep				on site. Sludge w	vas last measur	ed in January
1.		INAGEMENT ADEQU			sludge lias be	en removed.		
2.		ECORDS MAINTAINEE						
3.						BLIC CONTACT SITE): N		
0.				5 TO: (E.O., TOREOT,				
SE		SAMPLING IN	SPECTION PRC					
_		RESULTS WITH			۹			U ⊠NA ⊡NE
	ETAILS:				0			
1.		OBTAINED THIS INSPI	ECTION.					
2.								
3.								
4.								
5.	SAMPLE O	BTAINED FROM FACIL	LITY'S SAMPLING DEV	ICE:				
6.	SAMPLE R	EPRESENTATIVE OF	VOLUME AND NATUR	E OF DISCHARGE:				
7.	SAMPLE S	PLIT WITH PERMITTEI	E:				ΠY	
8.	CHAIN-OF-	CUSTODY PROCEDU	RES EMPLOYED:				ΠY	
9.	SAMPLES	COLLECTED IN ACCO	RDANCE WITH PERM	IT:			ΠY	□n Øna □ne
SE	CTION J	: STORM WAT	ER POLLUTION	PREVENTION	PLAN			
ST	ORM W	ATER MANAG	EMENT MEET	S PERMIT RE	QUIREMENTS			U ⊠NA ⊡NE
	DETAILS:							
1.	SWPPP UF	PDATED AS NEEDED:	DATE OF LAST UP	DATE:			ΠY	□n Øna □ne
2.	SITE MAP I	INCLUDING ALL DISCH	HARGES AND SURFAC	CE WATERS:			ΠY	
3.								
4.	POLLUTIO	N PREVENTION TEAM	PROPERLY TRAINED	:			ΠY	□n Øna □ne
5.	LIST OF PO	DTENTIAL POLLUTAN	SOURCES:				ΠY	
6.	LIST OF PO	DTENTIAL SOURCES A	AND PAST SPILLS AND	D LEAKS:			ΠY	
7.	ALL NON-S	TORM WATER DISCH	ARGES ARE AUTHOR	IZED:			ΠY	□n Øna □ne
8.	LIST OF ST	RUCTURAL BMPS:					ΠY	□n Øna □ne
9.	LIST OF NO	ON-STRUCTURAL BMF	PS:				ΠY	□n Øna □ne
10.	BMPS PRC	PERLY OPERATED AI	ND MAINTAINED:				ΠY	
11.	INSPECTIC	ONS CONDUCTED AS	REQUIRED:				ΠY	



Location: C	Office of Water Quality Ph	otographic Evidence Sheet	
	ity of Sheridan WTF		
Photographe		Date: 8/18/2021	Time: 11:36
Witness:		· ·	Photo #: 3
Description:	DSCN3033: Northeast corner of Ce	II 1 at the outlet control structure	to Cell 2.
		<b>00 / 10 / 2021 / 11 - 30</b>	
Photographe Witness: Description:	r: Jason Bolenbaugh DSCN3034: East side of Cells 2 and cells.	Date: 8/18/2021	Time:         11:37           Photo #:         4           dividing the

	Photographic Evidence Sheet
Location: City of Sheridan WTF	
Photographer: Jason Bolenbaugh	Date: 8/18/2021 Time: 11:37
Witness:	Photo #: <b>5</b>
Description: DSCN3036: holding pond looking	g east.
LUbotogrophery Liegen Delenheugh	
Photographer: Jason Bolenbaugh	Date: 8/18/2021 Time: 11:46
Witness:         Description:         DSCN3038: Cell 3 bank stabilization	Photo #: 6





-1	Office of Water Quality Pho	tographic Evidence Sheet	
Location: City	of Sheridan WTF		
Photographer:	Jason Bolenbaugh	Date: 8/18/2021	Time: 11:56
Witness:			Photo #: 11
	DSCN3043: Flow measuring device	for Outfall 002 and Hurricane Cr	
	(Manuat Overnder) Discharge Pump Seeed Sample Interval: 120 min	orson Orson Furricane Creek Tow Rate 1.34 MgD 1.34	6
Photographer:	Jason Bolenbaugh	Date: 8/18/2021	Time: 11:54
Witness:			Photo #: <b>12</b>
	OSCN3042: Effluent pumps to Outfa		







11-15-21

Mr. Jason Bolenbaugh,

In reference to first item in the "summary of findings" the primary staff gauge has been installed. I have enclosed pictures of the gauge that was installed.

If there are any changes that I need to do please let me know.

David Fitzgerald

SCANNED NOV 1 7 2021 MAILROOM







City of Sheridan

WATER AND SEWER WORKS

101 WEST HIGH STREET P.O. BOX 486 SHERIDAN, ARKANSAS 72150 LITTLE ROCK AR 720



Jason Bolenbaugh Compliance Branch Manager Office of Water Quality 5301 Northshore Drive North Little Rock, AR 72118

72118-531799

