



November 19, 2021

Tim Joyner, General Manager Cabot Water & WW Commission P.O. Box 1287 Cabot, AR 72023

RE: Cabot Water & Wastewater Comm. Inspection AFIN: 43-00059 Permit No.: AR0021661

Dear Mr. Joyner:

On June 24, 2021, I performed a Compliance Evaluation Inspection of the above referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. A copy of the inspection report is enclosed for your records.

Please refer to the "Summary of Findings" section of the inspection report and provide a written response for each item that was noted. This response should be mailed to the attention of the Office of Water Quality Compliance Branch at the address below my signature or emailed to Water-Inspection-Report@adeq.state.ar.us. This response should contain documentation describing the course of action taken to correct each item noted. The corrective action(s) should be completed as soon as possible and the written response with all necessary documentation (i.e. photos) is due by December 10, 2021.

If I can be of any assistance please contact me at <u>blain.sanders@adeq.state.ar.us</u> or (501) 682-0657.

Sincerely,

Blair JAN 734

Blain Sanders Inspector, Office of Water Quality 5301 Northshore Drive, North Little Rock, AR, 72118

AND DEPARTMENT	OFFICE OF WATER QUALITY INSPECTION REPORT							
	AFIN: 43-00059 PERMIT #: AR002166			661		DATE: <b>6/24/2021</b>		
POLAND ENVIRON	CC	OUNTY: 43 Lonol	(e	PDS	#: 118245	MEDIA: WN		
	GF	PS LAT: 34.9532	LONG: -92.0289	30 L	OCATION: G	eneral Area		
FACILITY INFORMAT			TION INFOR	MATION				
NAME: Cabot Water & Wastewater Comm.			FACILITY TYPE:INSPECTOR ID#:1 - Municipal123247 S - State					
76 Marshall Lane			FACILITY EVALUATION RATING:     INSPECTION TYPE:       3 - Satisfactory     Compliance Evaluati       DATE(S):     ENTRY TIME:     EXIT TIME:					
Cabot					EXIT TIME: 11:15	PERMIT EFFECTIVE DATE: 1/1/2020		
RESPONSIBLE OFFI	CIAL	-				PERMIT EXPIRATION DATE:		
Tim Joyner / General Manager						12/31/2024		
COMPANY:			FAYETTEVILLE	SHAL	E RELATED	: N		
Cabot Water & WW Commission			FAYETTEVILLE	SHAL	E VIOLATIO	NS: <b>N</b>		
P.O. Box 1287					TION PARTIC	CIPANTS		
CITY, STATE, ZIP: Cabot AR 72023			Blain Sanders, I		nspector, 50	1-682-0657		
PHONE & EXT: / FAX:			Will Cody, DEQ					
501-743-2154 /			Ryan Jones, Operator, 501-743-2154					
Tim@cabotwaterworks.com			Tim Joyner, General Manager, 501-743-2154					
CONTACTED DURING INSPECTION	: Ye							
(S=S	AREA EVALUATIONS (S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)							
S PERMIT	Μ	FLOW MEASUR	REMENT <b>N</b> STORMWATER					
S RECORDS/REPORTS	S	LABORATORY		S		ACILITY SITE REVIEW ELF-MONITORING PROGRAM		
M OPERATION & MAINTENANCE S SAMPLING				PRETREAT				
N OTHER:	3 SLODGE HANDLING/DISPOSAL IN PRETREATMENT							
SUMMARY OF FINDINGS								
<ol> <li>The following violations were noted and require a written response:</li> <li>1. The UV bulbs contained significant amounts of algae and debris (Photo 17). This is a violation of Part III, Section B, 1, Operations and Maintenance.</li> <li>2. The staff gauge located at the flume was stained and difficult to read (Photo 20). This is a violation of Part III, Section B, 1, Operations and Maintenance.</li> </ol>								
		GENERAL	COMMENTS					
None								
INSPECTOR'S SIGNATURE:	JAN 7	Blain Sand	ers			DATE: <b>6/28/2021</b>		
SUPERVISOR'S SIGNATURE:	er	+ 2 Walk	MBrent L. Wal	ker		DATE: <b>11/9/2021</b>		

Inspection Report: Cabot Water & Wastewater Comm., AFIN: 43-00059, Permit #: AR0021661

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	ØS OM OU ONA ONE
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	□y □n Øna □ne
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	
4. ALL DISCHARGES ARE PERMITTED:	
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	
DETAILS:	
ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	
a. DATES AND TIME(S) OF SAMPLING:	
b. EXACT LOCATION(S) OF SAMPLING:	
C. NAME OF INDIVIDUAL PERFORMING SAMPLING:	
d. ANALYTICAL METHODS AND TECHNIQUES:	
e. RESULTS OF CALIBRATIONS:	
f. RESULTS OF ANALYSES:	
g. DATES AND TIMES OF ANALYSES:	
h. NAME OF PERSON(S) PERFORMING ANALYSES:	
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	Øs 🗆m 🗇u 🖾na 🖾ne
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	Øy 🛛 n 🖓 na 🖓 ne
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	
DETAILS:	
DETAILS: 1. TREATMENT UNITS PROPERLY OPERATED:	
1. TREATMENT UNITS PROPERLY OPERATED:	
<ol> <li>TREATMENT UNITS PROPERLY OPERATED:</li> <li>TREATMENT UNITS PROPERLY MAINTAINED: UV bulbs and staff gauge in need of cleaning</li> </ol>	OS ØM OU ONA ONE Øs Om Ou Ona One
<ol> <li>TREATMENT UNITS PROPERLY OPERATED:</li> <li>TREATMENT UNITS PROPERLY MAINTAINED: <u>UV bulbs and staff gauge in need of cleaning</u></li> <li>STANDBY POWER OR OTHER EQUIVALENT PROVIDED: <b>Onsite generator; weekly inspections</b></li> </ol>	□s ∅m □u □na □ne ∅s □m □u □na □ne Øs □m □u □na □ne
<ol> <li>TREATMENT UNITS PROPERLY OPERATED:</li> <li>TREATMENT UNITS PROPERLY MAINTAINED: <u>UV bulbs and staff gauge in need of cleaning</u></li> <li>STANDBY POWER OR OTHER EQUIVALENT PROVIDED: <b>Onsite generator; weekly inspections</b></li> <li>ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: <b>SCADA</b></li> </ol>	OS ØM OU ONA ONE ØS OM OU ONA ONE ØS OM OU ONA ONE ØS OM OU ONA ONE
<ol> <li>TREATMENT UNITS PROPERLY OPERATED:</li> <li>TREATMENT UNITS PROPERLY MAINTAINED: <u>UV bulbs and staff gauge in need of cleaning</u></li> <li>STANDBY POWER OR OTHER EQUIVALENT PROVIDED: Onsite generator; weekly inspections</li> <li>ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: SCADA</li> <li>ALL NEEDED TREATMENT UNITS IN SERVICE:</li> </ol>	Image: Second state       Image: Second state<
<ol> <li>TREATMENT UNITS PROPERLY OPERATED:</li> <li>TREATMENT UNITS PROPERLY MAINTAINED: <u>UV bulbs and staff gauge in need of cleaning</u></li> <li>STANDBY POWER OR OTHER EQUIVALENT PROVIDED: Onsite generator; weekly inspections</li> <li>ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: SCADA</li> <li>ALL NEEDED TREATMENT UNITS IN SERVICE:</li> <li>ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: Ryan Jones; Class IV Municipal</li> </ol>	Image: Second state       Image: Second state<
<ol> <li>TREATMENT UNITS PROPERLY OPERATED:</li> <li>TREATMENT UNITS PROPERLY MAINTAINED: <u>UV bulbs and staff gauge in need of cleaning</u></li> <li>STANDBY POWER OR OTHER EQUIVALENT PROVIDED: Onsite generator; weekly inspections</li> <li>ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: SCADA</li> <li>ALL NEEDED TREATMENT UNITS IN SERVICE:</li> <li>ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: Ryan Jones; Class IV Municipal</li> <li>SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:</li> </ol>	Image: Second state       Image: Second state<
<ol> <li>TREATMENT UNITS PROPERLY OPERATED:</li> <li>TREATMENT UNITS PROPERLY MAINTAINED: <u>UV bulbs and staff gauge in need of cleaning</u></li> <li>STANDBY POWER OR OTHER EQUIVALENT PROVIDED: Onsite generator; weekly inspections</li> <li>ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: SCADA</li> <li>ALL NEEDED TREATMENT UNITS IN SERVICE:</li> <li>ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: Ryan Jones; Class IV Municipal</li> <li>SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:</li> <li>OPERATION AND MAINTENANCE MANUAL AVAILABLE:</li> </ol>	Image: Second state       Image: Second state<
<ol> <li>TREATMENT UNITS PROPERLY OPERATED:</li> <li>TREATMENT UNITS PROPERLY MAINTAINED: <u>UV bulbs and staff gauge in need of cleaning</u></li> <li>STANDBY POWER OR OTHER EQUIVALENT PROVIDED: Onsite generator; weekly inspections</li> <li>ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: SCADA</li> <li>ALL NEEDED TREATMENT UNITS IN SERVICE:</li> <li>ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: Ryan Jones; Class IV Municipal</li> <li>SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:</li> <li>OPERATION AND MAINTENANCE MANUAL AVAILABLE:</li> <li>STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:</li> <li>PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:</li> </ol>	Image: Second state       Image: Second state       Image: Second state       Image: Second state         Image: Second state       Image: Second state       Image: Second state       Image: Second state         Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: Second state         Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: Second state         Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: Second state         Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: Second state         Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: Second state         Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: Second state         Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: Second state       Image: S
<ol> <li>TREATMENT UNITS PROPERLY OPERATED:</li> <li>TREATMENT UNITS PROPERLY MAINTAINED: <u>UV bulbs and staff gauge in need of cleaning</u></li> <li>STANDBY POWER OR OTHER EQUIVALENT PROVIDED: Onsite generator; weekly inspections</li> <li>ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: SCADA</li> <li>ALL NEEDED TREATMENT UNITS IN SERVICE:</li> <li>ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: Ryan Jones; Class IV Municipal</li> <li>SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:</li> <li>OPERATION AND MAINTENANCE MANUAL AVAILABLE:</li> <li>STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:</li> <li>PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:</li> <li>HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:</li> </ol>	Image: Second state       Image: Second state<
<ol> <li>TREATMENT UNITS PROPERLY OPERATED:</li> <li>TREATMENT UNITS PROPERLY MAINTAINED: <u>UV bulbs and staff gauge in need of cleaning</u></li> <li>STANDBY POWER OR OTHER EQUIVALENT PROVIDED: Onsite generator; weekly inspections</li> <li>ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: SCADA</li> <li>ALL NEEDED TREATMENT UNITS IN SERVICE:</li> <li>ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: Ryan Jones; Class IV Municipal</li> <li>SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:</li> <li>OPERATION AND MAINTENANCE MANUAL AVAILABLE:</li> <li>STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:</li> <li>PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:</li> <li>HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:</li> <li>IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:</li> </ol>	Image: Second
<ol> <li>TREATMENT UNITS PROPERLY OPERATED:</li> <li>TREATMENT UNITS PROPERLY MAINTAINED: <u>UV bulbs and staff gauge in need of cleaning</u></li> <li>STANDBY POWER OR OTHER EQUIVALENT PROVIDED: Onsite generator; weekly inspections</li> <li>ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: SCADA</li> <li>ALL NEEDED TREATMENT UNITS IN SERVICE:</li> <li>ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: Ryan Jones; Class IV Municipal</li> <li>SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:</li> <li>OPERATION AND MAINTENANCE MANUAL AVAILABLE:</li> <li>STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:</li> <li>PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:</li> <li>HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:</li> <li>IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:</li> <li>HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:</li> </ol>	Image: Second
<ol> <li>TREATMENT UNITS PROPERLY OPERATED:</li> <li>TREATMENT UNITS PROPERLY MAINTAINED: <u>UV bulbs and staff gauge in need of cleaning</u></li> <li>STANDBY POWER OR OTHER EQUIVALENT PROVIDED: Onsite generator; weekly inspections</li> <li>ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: SCADA</li> <li>ALL NEEDED TREATMENT UNITS IN SERVICE:</li> <li>ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED: Ryan Jones; Class IV Municipal</li> <li>SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:</li> <li>OPERATION AND MAINTENANCE MANUAL AVAILABLE:</li> <li>STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:</li> <li>PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:</li> <li>HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:</li> <li>IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:</li> </ol>	Image: Second state       Image: Second state<

Inspection Report: Cabot Water & Wastewater Comm., AFIN: 43-00059, Permit	#. ARU021001
SECTION D: SAMPLING	
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS DETAILS:	ØS OM OU ONA ONE
1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT: Outfall 001	
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	
a. SAMPLES REFRIGERATED DURING COMPOSITING:	
b. PROPER PRESERVATION TECHNIQUES USED:	
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	Øy On Ona One
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	
DETAILS:	
<ol> <li>PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: TYPE OF DEVICE: 24" Parsi Flume; Unable to read staff gauge, maintenance needed</li> </ol>	
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:	
4. CALIBRATION FREQUENCY ADEQUATE: Annual	
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE: Unable to read staff gauge for routine checks	
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	
9. HEAD MEASURED AT PROPER LOCATION:	
SECTION F: LABORATORY	
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	ØS OM OU ONA ONE
DETAILS:	
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	Dy On Ona Øne
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	
4. QUALITY CONTROL PROCEDURES ADEQUATE:	
5. DUPLICATE SAMPLES ARE ANALYZED >10% OF THE TIME:	
6. SPIKED SAMPLES ARE ANALYZED <u>&gt;10%</u> OF THE TIME:	DY DN DNA ØNE
7. COMMERCIAL LABORATORY USED:	
a. LAB NAME: McClelland Consulting Engineers, Inc.	
b. LAB ADDRESS: 900 West Markham Street Little Rock, AR 72201	
c. PARAMETERS PERFORMED: NH3-N, CBOD, pH, TSS, FCB, Dissolved Oxygen, Total Phosphorus, Total Recoverable Arsei	nic, N+N
8. BIOMONITORING PROCEDURES ADEQUATE:	
a. PROPER ORGANISMS USED:	
b. PROPER DILUTION SERIES FOLLOWED: 0%, 32%, 45%, 56%, 75%, 100%	
c. PROPER TEST METHODS AND DURATION:	
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	

SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS								
BASED ON VISUAL OBSERVATIONS ONLY								
DETAILS:								
OUTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER	
001	None	None	None	None	None	Clear		
SECTION H	: SLUDGE DIS	POSAL						
SLUDGE D	DISPOSAL MEE	ETS PERMIT F	REQUIREMEN	ГS		ØS 🗆 M 🗆	U DNA DNE	
DETAILS:								
1. SLUDGE M	ANAGEMENT ADEQU	ATE TO MAINTAIN EF	FLUENT QUALITY: <u>SI</u>	udge is stored in large	e lagoon	⊠s ⊡m		
2. SLUDGE R	ECORDS MAINTAINED	DAS REQUIRED BY 40	) CFR 503:			⊠s ⊡m		
3. FOR LAND	APPLIED SLUDGE, TY	PE OF LAND APPLIE	D TO: (E.G., FOREST,	AGRICULTURAL, PUE	BLIC CONTACT SITE):			
SECTION I:	SAMPLING IN	SPECTION PRO	CEDURES					
SAMPLE R	ESULTS WITH	HIN PERMIT R	EQUIREMENT	S			U ⊠NA ⊡NE	
DETAILS:								
1. SAMPLES	OBTAINED THIS INSPE	ECTION:				ΠY	⊡n Øna ⊡ne	
2. TYPE OF S	AMPLE: GRAB:		IETHOD: FREQUE	NCY:				
3. SAMPLES F	PRESERVED:					ΠY	⊡n Øna ⊡ne	
4. FLOW PRO	PORTIONED SAMPLE	S OBTAINED:				ΠY	⊡n Øna ⊡ne	
5. SAMPLE O	BTAINED FROM FACIL	LITY'S SAMPLING DEV	/ICE:			ΠY	□n Øna □ne	
6. SAMPLE RI	EPRESENTATIVE OF	VOLUME AND NATUR	E OF DISCHARGE:			ΠY	⊡n Øna ⊡ne	
7. SAMPLE SE	PLIT WITH PERMITTE	E:				ΠY	□n Øna □ne	
8. CHAIN-OF-CUSTODY PROCEDURES EMPLOYED:						□n Øna □ne		
9. SAMPLES COLLECTED IN ACCORDANCE WITH PERMIT:								
	: STORM WAT							
	ATER MANAG	EMENT MEET	S PERMIT RE	QUIREMENTS			U ⊡NA ⊠NE	
DETAILS:								
1. SWPPP UP	DATED AS NEEDED:	DATE OF LAST UP	DATE:					
2. SITE MAP I	NCLUDING ALL DISCH	HARGES AND SURFAC	CE WATERS:					
3. POLLUTION	N PREVENTION TEAM	IDENTIFIED:						
4. POLLUTION PREVENTION TEAM PROPERLY TRAINED:						On Ona Øne		
5. LIST OF POTENTIAL POLLUTANT SOURCES:								
6. LIST OF PC	DTENTIAL SOURCES A	AND PAST SPILLS AND	D LEAKS:					
	TORM WATER DISCH	ARGES ARE AUTHOR	IZED:					
	RUCTURAL BMPS:							
9. LIST OF NO	ON-STRUCTURAL BMF	PS:						
10. BMPS PRO	PERLY OPERATED A	ND MAINTAINED:						
11. INSPECTIC	INS CONDUCTED AS I	REQUIRED:				ΠY		

Inspection Report: Cabot Water & Wastewater Comm., AFIN: 43-00059, Permit #: AR0021661

## FLOW CALCULATION SHEET

Date: June 24, 2021 Time: 10:19								
Head in Inches:   Feet:   Unable to read staff gauge								
Type & Size of Primary Flow Measurement Device: 24" Parshall Flume								
Name & Model of Secondary Flow Measurement Device: Endress+Hauser FMU90								
Date of last Calibration of Secondary Flow Device: Unable to read calibration stic	ker							
Recorded Flow at Date & Time Listed Above: (Facility Flow Meter)								
Calculated Flow at Date & Time Listed Above:								
(Flow is calculated using flow charts in: ISCO Open Channel Flow Measurement Handbook-5 <sup>th</sup> Edition)								
% Error = Recorded Value - Calculated Value X 100								
Calculated Value								
% Error = X 100								
% Error = X 100								
% Error = X 100								
% Error = %								
Comments: I was unable to perform a calibration check due to the staff gauge being difficult to read. Maintenance is needed.								

## **DMR Calculation Check**

Reporting Period:	From	<u>2021</u> Year	4 Month	1 Day	_ To _	2021 Year	 Month	<u>31</u> Day		
Parameter Checked:		CBOD	-							
		Loading Mass			Concentration Monthly					
	Mo.	Mo. Avg Ibs/day			Mo. Avg mg/l			g mg/l		
Reported Value:		60.5			2.5		3.5	5		
Calculated Value:		61.9			2.5		3.5	5		
Permit Value:		500.4			10.0		15.	0		

If calculated value does not equal reported value, explain:

## **DMR Calculation Check**


Reporting Period:	From	2021 Year	4 Month	1 Day	_ To _	2021 Year	4 Month	<u>31</u> Day		
Parameter Checked:		TSS	-							
		Loading Mass			Concentration Monthly					
	Mo.	Mo. Avg Ibs/day			Mo. Avg mg/l			mg/l		
Reported Value:		88			4.3		9			
Calculated Value:		88			4.3					
Permit Value:		750.6			15.0		22.5	5		


If calculated value does not equal reported value, explain:



































Figure 1: Google Earth image of the City of Cabot wastewater treatment plant.

Hey Melissa,

When you get a chance can you attach this to PDS #118245?

Thanks

From: tim@cabotwaterworks.com [mailto:tim@cabotwaterworks.com]
Sent: Tuesday, November 30, 2021 3:41 PM
To: Sanders, Blain
Cc: Water-Inspection-Report
Subject: Cabot Water & Wastewater Inspection June 24,2021 - Permit AR0021661

Blain,

Cabot Waterworks has corrected items 1. And 2. listed in your summary of findings. Attached are photos of the UV module and staff gauge that have been cleaned.

We will increase the frequency of cleaning these items in the future.


If you need any addition information, please let me know.


Tim Joyner, P.E. General Manager Cabot WaterWorks One City Plaza, Suite B PO Box 1287 Cabot, Arkansas 72023 Office: <u>501-843-4654</u> Cell: <u>501-743-2154</u>



Virus-free. <u>www.avg.com</u>







Instrument & Supply, Inc. Calibrated by: Paul Wofford Date: 067. 2021 Due: 067. 2027 Number: FIT-671 501-262-3282

