



March 14, 2024

Tim McKinney, Mayor City of Berryville P.O. BOX 227 Berryville, AR 72616

Email Address: mayortim@berryvillear.gov

RE: Berryville Waste Water Plant Inspection – PDS# 129411 (Carroll Co.)

AFIN: 08-00034 Permit No.: AR0021792

Dear Honorable Mayor McKinney:

On February 29, 2024, I performed a Compliance Evaluation Inspection of the above referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. A copy of the inspection report is enclosed for your records.

Please refer to the "Summary of Findings" section of the inspection report and provide a written response for each item that was noted. This response should be mailed to the attention of the Office of Water Quality Compliance Branch at the address below my signature or emailed to <u>Water-Inspection-Report@adeq.state.ar.us</u>. This response should contain documentation describing the course of action taken to correct each item noted. The corrective action(s) should be completed as soon as possible and the written response with all necessary documentation (i.e. photos) is due by March 29, 2024.

If I can be of any assistance, please contact me at William.Cody@adeq.state.ar.us or (501) 944-2569.

Sincerely,

William Cody

Inspector, Office of Water Quality

Cc: thom.vinson@jacobs.com

COUNTY: 08 Carroll



ENVIRONMENTAL QUALITY

OFFICE OF WATER QUALITY INSPECTION REPORT

PDS #: 129411

MEDIA: WN

AFIN: **08-00034** PERMIT #: **AR0021792** DATE: 2/29/2024

	GPS LAT: 36.356114 LONG: -93.580334 LOCATION: Entrance							
FACILITY INFORMA	INSPECTION INFORMATION				MATION			
Berryville Waste Water Plant			FACILITY TYPE: 1 - Municipal					
1000 Cedarvale Road			FACILITY EVALUATION RATING: INSPECTION TYPE: *** Compliance Evaluation					
Berryville				RY TIME: 0:50		XIT TIME: 1:07	PERMIT EFFECTIVE DATE: 11/1/2016	
RESPONSIBLE OFFI	CIAL	-					PERMIT EXPIRATION DATE:	
Tim McKinney / Mayor							10/31/2026	
COMPANY:			FAYETTEVILLE	SHAL	E RE	ELATED	: N	
City of Berryville			FAYETTEVILLE	SHAL	E VI	OLATIO	NS: N	
MAILING ADDRESS: P.O. BOX 227	INSPECTION PARTICIPANTS							
CITY, STATE, ZIP:			NAME/TITLE/PHONE/FAX/EMAIL/ETC.:					
Berryville AR 72616			Mike Maynard, Lead Operator, Class III					
PHONE & EXT: / FAX:			Brad Karnes, Operator, Class III					
870-654-3004 / EMAIL:			Thom Vinson, Operator Supervisor, Class IV,					
mayortim@berryvillear.gov			thom.vinson@jacobs.com					
CONTACTED DURING INSPECTION	· No		Austin Hawes, E&E Inspector II, (501) 837-6910,					
			austin.hawes@adeq.state.ar.us					
			William Cody, E&E Inspector II, (501) 944-2569, william.cody@adeq.state.ar.us					
		AREA EVA	LUATIONS	u c q.s	iaie.	ai.us		
(S=S	Satisfac		isfactory, N=Not Applicable/E	valuate)			
S PERMIT	S	FLOW MEASUR	REMENT	N	ST	ORMWA	ATER	
** RECORDS/REPORTS	S	LABORATORY		S	FA	CILITY	SITE REVIEW	
S OPERATION & MAINTENANCE	S	EFFLUENT/REG	CEIVING WATER	N	SE	LF-MON	IITORING PROGRAM	
S SAMPLING	S	SLUDGE HAND	LING/DISPOSAL	N	PR	RETREAT	rment	
** OTHER:								

SUMMARY OF FINDINGS

The following items were noted during the inspection:

- 1. Clarifier weirs are showing signs of rusting and algal growth. It is requested that the facility provide an update on the clarifier upgrade process. This is in accordance with Part III, B.1.A of the permit.
- 2. DMR data for February 2023 CBOD5 show reported values of 2.0 mg/L and 3.0 mg/L for Monthly Average and 7-Day Average, respectively. Manual DMR Calculation Checks resulted in values of 2.5 mg/L for both Monthly Average and 7-Day Average. It is requested that the facility respond to this item with an explanation as to how the values of 2.0 mg/L and 3.0 mg/L for Monthly Average and 7-Day Average were obtained.

GENERAL COMMENTS

On February 29, 2024, myself and Inspector Austin Hawes conducted a Compliance Evaluation Inspection at the above-referenced facility in accordance with the permit AR0021792. Mr. Mike Maynard, Mr. Brad Karnes, and Mr. Thom Vinson accompanied us during the inspection. The inspection consisted of a site assessment and a records review followed after the inspection.

Records Review:

Records are adequate overall. Records are thoroughly maintained and appear to match DMR submissions with the exception noted in Item 2 in the "Summary of Findings" section above. No other items were noted during the records review.

Site Assessment:

The site is in good condition overall. The facility averages approximately 1.25 MGD and a nearby Tyson plant provides approximately 60% of the wastewater influent. The facility went through an upgrade in 2011. From the influent, wastewater proceeds through a bar screen and grit removal. The bar screen is clean and in good condition; the grit removal device is showing signs of aging but appears to work adequately. Solids removed from these processes are dropped into a dumpster, where Carroll County Solid Waste Department hauls the dumpster to the Tontitown landfill every Monday. Wastewater then proceeds to a grit removal tank, where a sump at the bottom pulls any grit back to grit removal and/or solid waste handling.

A splitter box sends the wastewater to anaerobic selector basins where phosphorus removal occurs. Another splitter box following the anaerobic selector basins sends wastewater to the anoxic zone, followed by the oxidation ditch/aeration basin. There are two oxidation ditches; however, only one is used for operation. The second oxidation ditch is switched as the primary oxidation ditch every year or so, as one ditch has adequate capacity to run the operation. Wastewater then proceeds to one of two clarifiers. One clarifier has received recent updates and maintenance to replace the baffles and weirs along with other components. Previous inspection reports identified rusting and deteriorating weirs and baffles. The second clarifier does still resemble rusting conditions and has evidence of algal growth between the weirs. It was mentioned that this clarifier will receive the same updates as the first clarifier in the next four to five months. Sludge/scum from clarifiers proceeds to a gravity thickener basin and is then pumped to the sludge holding tank, where there are two submersed blowers. The UV disinfection system was refurbished in December 2023, and bulbs are pulled every month or so for manual cleaning. Effluent samples are taken at post-aeration. A new flow meter was installed in 2023 and is officially calibrated yearly, and Mr. Maynard calibrates manually once/month.

For solids handling, the facility uses a belt press as needed, typically once/week depending on the season. The solids handling equipment appeared very clean and well-maintained. Solids are then hauled off by Carroll County Solid Waste Department to the landfill.

Will Cedy	
INSPECTOR'S SIGNATURE: William Cody	DATE: 3/7/2024
Amy Huneyeutt	
SUPERVISOR'S SIGNATURE: Amy Huneycutt	DATE: 3/12/2024

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	⊠S □M □U □NA □NE
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	☑Y ☐N ☐NA ☐NE
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	□y □n ☑na □ne
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	☑Y □N □NA □NE
4. ALL DISCHARGES ARE PERMITTED:	☑y □n □na □ne
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	⊠S □M □U □NA □NE
DETAILS:	
ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	☑y □n □na □ne
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	⊠s □m □u □na □ne
a. DATES AND TIME(S) OF SAMPLING:	☑Y □N □NA □NE
b. EXACT LOCATION(S) OF SAMPLING:	☑Y □N □NA □NE
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	☑Y □N □NA □NE
d. ANALYTICAL METHODS AND TECHNIQUES:	☑y □n □na □ne
e. RESULTS OF CALIBRATIONS:	Øy □n □na □ne
f. RESULTS OF ANALYSES:	☑Y □N □NA □NE
g. DATES AND TIMES OF ANALYSES:	☑Y □N □NA □NE
h. NAME OF PERSON(S) PERFORMING ANALYSES:	☑y □n □na □ne
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	⊠S □M □U □NA □NE
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	⊠s □m □u □na □ne
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	☑Y □N □NA □NE
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	☑S □M □U □NA □NE
DETAILS:	
TREATMENT UNITS PROPERLY OPERATED:	⊠S □M □U □NA □NE
2. TREATMENT UNITS PROPERLY MAINTAINED:	⊠S □M □U □NA □NE
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	⊠S □M □U □NA □NE
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	⊠S □M □U □NA □NE
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	⊠s □m □u □na □ne
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	⊠S □M □U □NA □NE
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	⊠S □M □U □NA □NE
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	□Y □N □NA ☑NE
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	☑y □n □na □ne
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	☑y □n □na □ne
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:	□Y ☑N □NA □NE
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	□Y □N ☑NA □NE
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	□Y □N ☑NA □NE
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	□Y ☑N □NA □NE
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:	□y □n ☑na □ne
	- 11-

SE	ECTION D: SAMPLING	
PE	ERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DE	ETAILS:	
1.	SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	Øy □n □na □ne
2.	LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	☑Y □N □NA □NE
3.	FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	□y □n □na ☑ne
4.	SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	Øy □n □na □ne
5.	SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	Øy □n □na □ne
6.	SAMPLE COLLECTION PROCEDURES ADEQUATE:	Øy □n □na □ne
a	a. SAMPLES REFRIGERATED DURING COMPOSITING:	☑Y □N □NA □NE
t	D. PROPER PRESERVATION TECHNIQUES USED:	Øy □n □na □ne
c	c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	Øy □n □na □ne
7.	IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	□y □n □na ☑ne
SE	ECTION E: FLOW MEASUREMENT	
PE	ERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DI	ETAILS:	
1.	PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: 18" TYPE OF DEVICE: Parshall flu	me ØY □N □NA □NE
2.	FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	Øy □n □na □ne
3.	SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED: Militronics Hy Ranger	<u>ydro</u> ☑Y ☐N ☐NA ☐NE
4.	CALIBRATION FREQUENCY ADEQUATE:	ØY □N □NA □NE
5.	RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	Øy □n □na □ne
6.	CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	☑Y □N □NA □NE
7.	FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	Øy □n □na □ne
8.	FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	Øy □n □na □ne
9.	HEAD MEASURED AT PROPER LOCATION:	☑Y □N □NA □NE
SE	ECTION F: LABORATORY	
PΕ	ERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	☑S □M □U □NA □NE
DI	ETAILS:	
1.	EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	☑Y □N □NA □NE
2.	IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	□y □n □na ☑ne
3.	SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	Øy □n □na □ne
4.	QUALITY CONTROL PROCEDURES ADEQUATE:	⊠y □n □na □ne
5.	DUPLICATE SAMPLES ARE ANALYZED ≥10% OF THE TIME:	☑y □n □na □ne
6.	SPIKED SAMPLES ARE ANALYZED ≥10% OF THE TIME:	☑Y □N □NA □NE
7.	COMMERCIAL LABORATORY USED:	Øy □n □na □ne
a	a. LAB NAME: GTS, Inc.	
k	b. LAB ADDRESS: 1915 N. Shiloh Drive, Fayetteville, AR 72704	
C	2. PARAMETERS PERFORMED: BOD5, CBOD5, Ammonia-N, Total Phosphorus, TDS, TSS, Fecal Coliform	
8.	BIOMONITORING PROCEDURES ADEQUATE:	□Y □N □NA ☑NE
a	a. PROPER ORGANISMS USED:	□Y □N □NA ☑NE
k	p. PROPER DILUTION SERIES FOLLOWED:	□Y □N □NA ☑NE
	2. PROPER TEST METHODS AND DURATION:	□y □n □na ☑ne
	d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	□y □n □na ☑ne
		<u> </u>

SECTION G	: EFFLUENT/R	ECEIVING WA	TERS OBSERV	ATIONS						
BASED ON	VISUAL OBS	ERVATIONS (ONLY			⊠S □M □	IU □NA □NE			
DETAILS:					"					
OUTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER			
001	None	None	None	None	None	Clear				
					<u> </u>					
SECTION H	: SLUDGE DIS	POSAL								
	DISPOSAL ME		REQUIREMEN	TS		⊠S □M □	IU □NA □NE			
DETAILS:					I					
	1. SLUDGE MANAGEMENT ADEQUATE TO MAINTAIN EFFLUENT QUALITY: Hauled to landfill.									
2. SLUDGE RECORDS MAINTAINED AS REQUIRED BY 40 CFR 503:										
3. FOR LAND	APPLIED SLUDGE, TY	PE OF LAND APPLIE	D TO: (E.G., FOREST	, AGRICULTURAL, PU	BLIC CONTACT SITE):					
SECTION I:	SAMPLING IN:	SPECTION PRO	OCEDURES							
SAMPLE F	RESULTS WITH	IIN PERMIT R	EQUIREMENT	ΓS		□S □M □	IU ⊠NA □NE			
DETAILS:			·							
1. SAMPLES	OBTAINED THIS INSPE	ECTION:				□Y	□n Øna □ne			
2. TYPE OF S	AMPLE: GRAB:	COMPOSITE: I	METHOD: FREQUE	ENCY:						
	PRESERVED:		-			□Y	□N ☑NA □NE			
4. FLOW PRO	PORTIONED SAMPLE	S OBTAINED:				□Y	□n ☑na □ne			
5. SAMPLE O	BTAINED FROM FACIL	ITY'S SAMPLING DE	VICE:			□Y	□n ☑na □ne			
6. SAMPLE R	EPRESENTATIVE OF \	VOLUME AND NATUR	RE OF DISCHARGE:			□Y	□n ☑na □ne			
7. SAMPLE S	PLIT WITH PERMITTE	E:				□Y	□N ☑NA □NE			
8. CHAIN-OF-	CUSTODY PROCEDU	RES EMPLOYED:				□Y	□N ☑NA □NE			
9. SAMPLES	COLLECTED IN ACCO	RDANCE WITH PERM	IIT:			□Y	□N ☑NA □NE			
SECTION J	: STORM WATE	ER POLLUTION	PREVENTION	PLAN						
STORM W	ATER MANAG	EMENT MEET	S PERMIT RE	QUIREMENTS	3		IU □NA ☑NE			
DETAILS:					·					
1. SWPPP UP	PDATED AS NEEDED:_	_ DATE OF LAST UP	PDATE:			□Y	□N □NA ☑NE			
2. SITE MAP I	INCLUDING ALL DISCH	HARGES AND SURFA	CE WATERS:			□Y	□n □na ☑ne			
3. POLLUTIO	N PREVENTION TEAM	IDENTIFIED:				□Y	□n □na ☑ne			
4. POLLUTIO	N PREVENTION TEAM	PROPERLY TRAINED	D:			□Y	□N □NA ☑NE			
5. LIST OF PO	LIST OF POTENTIAL POLLUTANT SOURCES:									
6. LIST OF PO	OTENTIAL SOURCES A	AND PAST SPILLS AN	D LEAKS:			□Y	□n □na ☑ne			
7. ALL NON-S	STORM WATER DISCH	ARGES ARE AUTHOR	RIZED:			□Y	□N □NA ☑NE			
8. LIST OF ST	RUCTURAL BMPS:					□Y	□n □na ☑ne			
9. LIST OF NO	ON-STRUCTURAL BMF	PS:				□Y	□N □NA ☑NE			
10. BMPS PRO	PERLY OPERATED A	ND MAINTAINED:				□Y	□n □na ☑ne			
11. INSPECTIO	ONS CONDUCTED AS I	REQUIRED:				□Y	□n □na ☑ne			
	·	·				·				

FLOW CALCULATION SHEET								
Date: 2/29/2024 Time: 10:35								
Head in Inc	Head in Inches: 6.25" Feet: 0.5208'							
Type & Size	e of Primary Flow N	Measurement Device	e: 18" Parshall flume					
Name & Mo	odel of Secondary I	Flow Measurement [Device: Militronics Hydro Ranger					
Date of last	Calibration of Sec	ondary Flow Device:):					
Recorded F	low at Date & Time	e Listed Above: 98	(Facility Flow Meter)					
	Flow at Date & Tim		985.0 GPM					
(Flow is calculat	ted using flow charts in: <u>is</u>		easurement Handbook-5 th Edition)					
% Error =	Recorded Value Calcu	-	X 100					
% Error =	983.04	- 985.0	X 100					
70 E1101	!	985.0	7, 100					
% Error =	-1.96 985.0	X 100						
% Error =	-0.0019898477	X 100						
% Error =	-0.20	%						
Comments:								

DMR Calculation Check

Reporting Period:	From	2023	11	01	_ To	2023	11	30
		Year	Month	Day		Year	Month	Day
Parameter Checked:		ТР	_					
		Loading Mass				Concer Mon		
ľ		Mo. Avg Ibs/day			Mo. Avg mg/l			J mg/l
Reported Value:		4.6			0.5		0.5	<u> </u>
Calculated Value:		4.6			0.5		0.5	i
Permit Value:		20.0			1		2	

If calculated value does not equal reported value, explain:

DMR Calculation Check

01

To 2023

02

28

- I	-						
		Year	Month	Day	Year	Month	Day
Parameter Checked:		CBOD5	_				

02

	Loading Mass	Concentration Monthly				
	Mo. Avg Ibs/day	Mo. Avg mg/l	7-day Avg mg/l			
Reported Value:	31.8	2.0	3.0			
Calculated Value:	31.8	2.5	2.5			
Permit Value:	200.2	10	15			


If calculated value does not equal reported value, explain:

Reporting Period:

From

2023

The provided DMR Calculation Excel Sheet "MB Calc" identifies a CBOD monthly average value of 2.5 mg/L under the "MONTHLY AVERAGE" table. This sheet also identifies a CBOD 7-day average value of 2.5 mg/L under the "7 DAY AVERAGE" table. The reported values in NetDMR identify values of 2.0 mg/L for Monthly Average and 3.0 for 7-Day Average. Manual calculations resulted in the calculated values of 2.5 mg/L for both Monthly Average and 7-Day Average. It would be appreciated if the facility could explain how the 2.0 mg/L value for Monthly Average and the 3.0 mg/L value for 7-Day Average was calculated.





Photographer:William CodyDate:2/29/2024Time:09:58Witness:Mike Maynard, Austin HawesPhoto #:2



Office of Water Quality Photographic Evidence Sheet Location: Berryville Waste Water Plant Photographer: William Cody Date: 2/29/2024 Time: 10:00 Witness: Mike Maynard, Austin Hawes Photo #: 3 Description: Grit tank where a sump pulls grit back to removal/solid waste building.



Photographer: William Cody	Date:	2/29/2024	Time:	10:02
Witness: Mike Maynard, Austin Hawes			Photo #:	4

Description: Anaerobic selector basins with multiple cells.



Cocation: Berryville Waste Water Plant Photographer: William Cody Witness: Mike Maynard, Austin Hawes Description: Anoxic zone before oxidation ditch/aeration basin.



Photographer: William Cody	Date:	2/29/2024	Time:	10:08
Witness: Mike Maynard, Austin Hawes			Photo #:	6


Description: Oxidation ditch.



Office of Water Quality Photographic Evidence Sheet							
Location:	Ber	ryville Waste Water Plant					
Photograp	her:	William Cody	Date:	2/29/2024	Time:	10:08	
Witness:	Witness: Mike Maynard, Austin Hawes Photo #: 7						
Description	Description: Propeller-styled device used in the oxidation ditch to introduce oxygen.						



Photographer:William CodyDate:2/29/2024Time:10:10Witness:Mike Maynard, Austin HawesPhoto #:8



Coation: Berryville Waste Water Plant Photographer: William Cody Witness: Mike Maynard, Austin Hawes Description: Clarifier weirs are showing signs of rusting as well as algal growth.




Photographer:William CodyDate:2/29/2024Time:10:13Witness:Mike Maynard, Austin HawesPhoto #:10

Description: New weirs and additional parts installed on the second clarifier.




Coation: Berryville Waste Water Plant Photographer: William Cody Witness: Mike Maynard, Austin Hawes Office of Water Quality Photographic Evidence Sheet Date: 2/29/2024 Time: 10:16 Photo #: 11



Photographer: William Cody	Date: 2/29/2024	Time:	10:15
Witness: Mike Maynard, Austin Hawes		Photo #	: 12

Description: Parshall flume with stilling well and flow measurement.





Office of Water Quality Photographic Evidence Sheet								
Location:	Ber	ryville Waste Water Plant						
Photograp	her:	William Cody	Date:	2/29/2024	Time:	10:38		
Witness: Mike Maynard, Austin Hawes				Photo #	: 15			
Description: Sludge holding tank with submerged blowers.								



Photographer:William CodyDate:2/29/2024Time:10:40Witness:Mike Maynard, Austin HawesPhoto #:16

