STATEMENT OF BASIS

For the issuance of Air Permit # 2123-AOP-R7 AFIN: 29-00506

1. PERMITTING AUTHORITY:

Arkansas Department of Environmental Quality 5301 Northshore Drive North Little Rock, Arkansas 72118-5317

2. APPLICANT:

American Electric Power Service Corporation (John W. Turk Jr. Power Plant) 3711 Highway 355 South Fulton, Arkansas 71838

3. PERMIT WRITER:

Joseph Hurt

4. NAICS DESCRIPTION AND CODE:

NAICS Description: Fossil Fuel Electric Power Generation

NAICS Code: 221112

5. SUBMITTALS:

Date of Application	Type of Application	Short Description of Any Changes
	(New, Renewal, Modification,	That Would Be Considered New or
	Deminimis/Minor Mod, or	Modified Emissions
	Administrative Amendment)	
1/31/2017	Modification	Case-by-case MACT limits have been
		removed. VOC emissions have been
		increased to the existing BACT limits
		for SN-01 and SN-02.

6. REVIEWER'S NOTES:

As part of this modification, the facility requested to clarify permit language concerning Lead, VOC, Mercury, HAP, and air contaminant emissions for SN-01 and SN-02. The remaining case-by-case MACT limits were also removed. The permitted emission increases include 0.5 tpy of PM₁₀, 74.11 tpy of VOC, 36.6 tpy of CO. The permitted emission decreases include 341.05 tpy of PM. The increase in VOC emissions is based on the relaxation of the case-by-case MACT limit due to MATS. The new VOC limit is based on the existing BACT limit for SN-01 and SN-02. There were no physical changes

AFIN: 29-00506 Page 2 of 13

or change in the method of operation at the facility. Therefore, this modification is not a PSD major modification.

7. COMPLIANCE STATUS:

The following summarizes the current compliance of the facility including active/pending enforcement actions and recent compliance activities and issues.

The inspector conducted an inspection on July 28, 2016. There were no areas of concerns noted at the time of the inspection.

8. PSD APPLICABILITY:

- a) Did the facility undergo PSD review in this permit (i.e., BACT, Modeling, etc.)? N
- b) Is the facility categorized as a major source for PSD?

Y

• Single pollutant \geq 100 tpy and on the list of 28 or single pollutant \geq 250 tpy and not on list

If yes, explain why this permit modification is not PSD.

There were no physical changes or change in the method of operation at the facility.

9. SOURCE AND POLLUTANT SPECIFIC REGULATORY APPLICABILITY:

Source	Pollutant	Regulation (NSPS, NESHAP or PSD)
	all	PSD
01	HAPs	40 CFR Part 63, Subpart UUUUU
	PM, SO_2, NO_x	40 CFR Part 60, Subpart Da
	all	PSD
02	HAPs	40 CFR Part 63, Subpart DDDDD
	NO_x	40 CFR 60, Subpart Db
	all	PSD
03	PM, fuel specifications	40 CFR 60, Subpart IIII
	N/A	40 CFR 63, Subpart ZZZZ
04 & 05	PM, NO _x , fuel specifications	40 CFR 60, Subpart IIII
EP-01 through EP-10, EP-12 TP-11, TP-16 and TP-20	opacity	40 CFR 60, Subpart Y

AFIN: 29-00506 Page 3 of 13

10. EMISSION CHANGES AND FEE CALCULATION:

See emission change and fee calculation spreadsheet in Appendix A.

11. AMBIENT AIR EVALUATIONS:

a) Reserved.

b) Non-Criteria Pollutants:

The non-criteria pollutants listed below were evaluated. Based on Department procedures for review of non-criteria pollutants, emissions of all other non-criteria pollutants are below thresholds of concern.

1st Tier Screening (PAER)

Estimated hourly emissions from the following sources were compared to the Presumptively Acceptable Emission Rate (PAER) for each compound. The Department has deemed the PAER to be the product, in lb/hr, of 0.11 and the Threshold Limit Value (mg/m³), as listed by the American Conference of Governmental Industrial Hygienists (ACGIH).

Pollutant	TLV (mg/m ³)	$PAER (lb/hr) = 0.11 \times TLV$	Proposed lb/hr	Pass?
Acetaldehyde	44.05	4.954	0.25	Y
Acrolein	0.229	0.025	0.14	N
Antimony	0.5	0.055	0.15	N
Arsenic	0.01	0.001	0.52	N
Benzene	1.597	0.176	1.22	N
Benzyl Chloride	5.177	0.569	0.27	N
Beryllium	0.002	0.00022	0.02	N
1,3-Butadiene	4.425	0.487	0.04	Y
Cadmium	0.01	0.001	0.03	N
Carbon Disulfide	31.141	3.426	0.05	Y
Chloroform	48.826	5.371	0.03	Y
Chromium	0.5	0.055	0.19	N
Chromium VI	0.05	0.006	0.06	N

AFIN: 29-00506 Page 4 of 13

Pollutant	TLV (mg/m ³)	$PAER (lb/hr) = 0.11 \times TLV$	Proposed lb/hr	Pass?
Cobalt	0.2	0.002	0.04	N
Cyanide	5.19	0.571	0.94	N
Dichlorobenzene	60.127	6.614	0.01	Y
Dimethyl Sulfate	0.516	0.057	0.02	Y
Dioxins & Furans	0.001	0.0001	0.01	N
Formaldehyde	18.421	2.026	0.17	N
Hexane	1762.372	193.861	1.54	Y
Hydrogen Chloride	2.983	0.328	12.00	N
Hydrogen Fluoride	0.409	0.045	1.20	N
Lead	0.05	0.006	0.1603	N
Manganese	0.2	0.022	1.12	N
Mercury	0.025	0.003	7.34E-03	N
Methyl Hydrazine	0.019	0.002	0.07	N
Nickel	0.1	0.011	0.12	N
Phenol	19.245	2.117	0.01	Y
Phosphorous	0.1	0.011	2.40	N
POM	0.2	0.022	0.05	N
Propionaldehyde	47.526	5.228	0.15	Y
Selenium	0.2	0.022	0.25	N
Sulfuric Acid	0.2	0.022	25.20	N
Toluene	188.405	20.725	0.88	Y
2,2,4- Trimethylpentane	1401	154	0.21	Y
Xylene	434.192	47.761	0.22	Y
Ammonia	17.413	1.91	37.50	N

AFIN: 29-00506 Page 5 of 13

2nd Tier Screening (PAIL)

AERMOD air dispersion modeling was performed on the estimated hourly emissions from the following sources, in order to predict ambient concentrations beyond the property boundary. The Presumptively Acceptable Impact Level (PAIL) for each compound has been deemed by the Department to be one one-hundredth of the Threshold Limit Value as listed by the ACGIH.

Pollutant	PAIL (μ g/m ³) = 1/100 of Threshold Limit Value	Modeled Concentration (μg/m³)	Pass?
Acrolein	2.3	5.38E-04	Y
Antimony	5	7.43E-04	Y
Arsenic ¹ .	0.1	0.001	Y
Benzene	15.971	13.92155	Y
Benzyl Chloride	16	1.3E-03	Y
Beryllium	0.02	3.9E-05	Y
Cadmium	0.02	9.02E-05	Y
Chromium	5	8.58E-04	Y
Chromium VI	0.5	2.49E-04	Y
Cobalt	0.2	1.26E-04	Y
Cyanide	51.9	4.64E-03	Y
Dioxins & Furans	0.01	5E-05	Y
Formaldehyde	15	6.48E-04	Y
Hydrogen Chloride ^{2.}	29.8	0.06823	Y
Hydrogen Fluoride	24.6	0.0267	Y
Lead ^{2.}	0.5	0.00091	Y
Manganese	2.0	5.5E-03	Y
Mercury	0.1	1.97E-04	Y
Methyl hydrazine	0.19	3.16E-04	Y
Nickel	1.0	5.25E-04	Y
Phosphorous	1.0	1.19E-02	Y
POM	0.02	8.0E-05	Y

AFIN: 29-00506 Page 6 of 13

Pollutant	PAIL (μ g/m ³) = 1/100 of Threshold Limit Value	Modeled Concentration (μg/m³)	Pass?
Sulfuric Acid ^{1.}	2.0	1.19E-01	Y
Selenium	2.0	1.19E-03	Y
Ammonia ^{1.}	174	0.18575	Y

- 1. The permitted emission HAP increases with this Title V Minor Modification were a result of the addition of an emergency engine. The Department does not model the intermittent emissions from emergency engines at this time. Therefore, the results are from previous permitting decisions, see Air Permit 2123-AOP-R0 and Air Permit 2123-AOP-R1.
- 2. Short-term emission increases occurred for Hydrogen Chloride and Lead for Air Permit 2123-AOP-R7, and was modeled. All other modeling results are from previous permitting decisions.

Other	Modelin	σ:
Oute	MIOUCIIII	ے.

Odor:

H₂S Modeling:

A.C.A. §8-3-103 requires hydrogen sulfide emissions to meet specific ambient standards. Many sources are exempt from this regulation, refer to the Arkansas Code for details.

Is the facility exempt from the H ₂ S Standards	Y
If exempt, explain: No H ₂ S emissions	

12. CALCULATIONS:

SN	Emission Factor Source	Pollutant	Emission Factor	Control Equipment	Control Equipment Efficiency	Comments
		PM/PM ₁₀ (filterable)	0.012 lb/MMBtu	Baghouse	99.9	
		PM/PM ₁₀ (total)	0.025 lb/MMBtu	Baghouse	99.9	
	01 BACT	SO_2	0.065 lb/MMBTU	Dry Flue Gas Desulfurization	80-90+	
01		VOC	0.0036 lb/MMBtu	Proper Design/Operation		
		СО	0.15 lb/MMBtu	Proper Design/Operation		
		NO _x	0.067 lb/MMBTU/0.05 lb/MMBTU annual	SCR	70-90	

AFIN: 29-00506 Page 7 of 13

SN	Emission Factor Source	Pollutant	Emission Factor	Control Equipment	Control Equipment Efficiency	Comments
01 BACT	Pb	2.6E-05 lb/MMBtu	Baghouse	99.9		
01	DACI	H_2SO_4	0.0042	DFGD with		
		Mist	lb/MMBtu	Baghouse		
		PM (total)	0.0076 lb/MMBTU	Natural Gas Combustion		
		SO_2	0.0006 lb/MMBtu	Natural Gas Combustion		
		VOC	0.0055 lb/MMBtu	Proper Design/Operation		
02	BACT	СО	0.30 lb/MMBTU	Proper Design/Operation		
		NO _x	0.11 lb/MMBtu	Low NO _x Burner and Flue Gas Recirculation		
		Pb	N/A	Natural Gas combustion		
		NO _x + NMHC	6.4 g/kWh	Proper Design/Operation Low Sulfur Diesel		
03 and 04	BACT	SO_2	0.007 g/kWh			
	_	PM	0.2 g/kWh			
		СО	3.5 g/kWh	100 hrs/yr		
EP-01 – EP-10, TP- 16, TP-20	AP-42	PM/PM ₁₀	various	Water and Surfactant Spray		
EP-12	Design	PM/PM ₁₀	0.01 gr/dscf	filter		
TP-22 TP-23	design	PM/PM ₁₀	9.4E-05 lb/ton	none		
EP-15 - EP-18 EP-21 - EP-25	Design	PM/PM ₁₀	0.01 gr/dscf	filter		
F-01 – F- 03, F-05, F-06	EPA Guidance	PM/PM ₁₀	3.9 lb/day/acre	None	N/A	
F-04	AP-42	PM/PM ₁₀	lb/day/acre 1.0 PM 0.5 PM ₁₀	Water Spray	75%	Maximum of 26 acres

AFIN: 29-00506 Page 8 of 13

SN	Emission Factor Source	Pollutant	Emission Factor	Control Equipment	Control Equipment Efficiency	Comments
CT-01	BACT	Drift rate	0.0005%	Drift Eliminators	N/A	
RD-01	AP-42	PM/PM ₁₀	1.07 lb/VMT	Watering and chemical suppression	90	
TK-01	TANKS	VOC	Varies	N/A	N/A	Based on 25,000 gallons of gasoline per year.
		NO _x	4.0 g/kW-hr			_
	Manufacturer's	CO	3.5 g/kW-hr			
	specs	VOC	0.19 g/kW-hr	Oxidation Catalyst	Not specified	Annual emissions
05		PM/PM ₁₀	0.2 g/kW-hr			are based on
	ULSD	SO_2	0.007 g/kW-hr			100 hours per year
	AP-42 Chapter 3.3, Table 3.3-	HAPs	Varies			

13. TESTING REQUIREMENTS:

The permit requires testing of the following sources.

SN	Pollutants	Test Method Test Interval		Justification
01	VOC PM/PM ₁₀ HF HCl H ₂ SO ₄ Ammonia Lead (Pb)	various	annual	BACT/NSPS/MACT Verify Emission Rates
01	Other Non- Criteria	TBD	Once	Verify Emission Rates/MACT
02	PM CO	various	Once	NSPS/MACT
02	NO _x	7E	Initial and once every five years.	Verify emission rates

AFIN: 29-00506 Page 9 of 13

SN	Pollutants	Test Method	Test Interval	Justification
EP-01 through EP-10, and EP- 12	Opacity	Method 9	Initial	NSPS

14. MONITORING OR CEMS:

The permittee must monitor the following parameters with CEMS or other monitoring equipment (temperature, pressure differential, etc.)

SN	Parameter or Pollutant to be Monitored	Method (CEM, Pressure Gauge, etc.)	Frequency	Report (Y/N)
01	Opacity CO NO _x SO ₂ CO ₂ Mercury	COMS CEMS	Continuous	Y
01	Bag Leaks	Bag Leak Detector	Continuous	Y

15. RECORDKEEPING REQUIREMENTS:

The following are items (such as throughput, fuel usage, VOC content, etc.) that must be tracked and recorded.

SN	Recorded Item	Permit Limit	Frequency	Report (Y/N)
01	Mercury Emissions	1.7 lb/TBtu per 12-month period	Monthly	Y
01	Bag Leak Detector Readings	None specified	Monthly	Y
01	BTU input	6000 MMBtu/hr 24-hour average	Continuous	Y
01	SO omissions	0.065 lb/MMBtu (30-day rolling average)	Monthly	Y
01	SO ₂ emissions	480.0 lb/hr (24-hr rolling average)	Monthly	Y

AFIN: 29-00506 Page 10 of 13

SN	Recorded Item	Permit Limit	Frequency	Report (Y/N)
01	NO _x emissions	0.067 lb/MMBtu (24-hr rolling average normal operations)	Monthly	Y
		420.0 lb/hr (24-hr rolling average)	Monthly	Y
01	NO _x emissions	0.05 lb/MMBtu (12-month rolling average)	Monthly	Y
01	СО	0.15 lb/MMBtu (30-day rolling average)	Monthly	Y
02	Fuel Used	272.1 MMscf/12 month	Monthly	Y
03	Hours of operation	500 per year	Monthly	Y
04	Hours of operation	100 per year	Monthly	Y
F-04	Maximum area of the inactive coal piles	26 acres	Semi-annually	Y
F-06	Maximum area of the solid waste disposal area	50 acres	Semi-annually	Y
CT-01	Total Dissolved Solids (TDS)	750 ppm	Weekly	Y
TK-01	Gasoline		Monthly	Y
05			Monthly	Y
Welsh Unit 2			Semi-annually	Y

16. OPACITY:

SN	Opacity	Justification for limit	Compliance Mechanism
01	10	Good Operations	COM
02	10	Good Operations	COM

AFIN: 29-00506 Page 11 of 13

SN	Opacity	Justification for limit	Compliance Mechanism
03	20% in acceleration mode 15% in Lugging mode 50% during peaks (as measured according to 40 CFR 86, Subpart I)	Good Operations	Method 9
04 & 05	20	Dept. Guidance	One time visible observation
SN-EP-01 through EP-10, EP-12, TP-16, and TP-19 through TP-20	20	NSPS	Method 9
SN-TP-22	20	Dept. Guidance	Daily Observations
EP-15 through EP-25	10	Dept. Guidance	Weekly observations
SN-F-01 through F-06	10	Dept. Guidance	Weekly observations

17. DELETED CONDITIONS:

Former SC	Justification for removal
56 & 57	The case-by-case Mercury compliance mechanism is no longer applicable. The facility will comply with the necessary MATS compliance mechanisms.
229	These case-by-case MACT limits are no longer applicable. The facility will comply with the necessary Boiler MACT compliance mechanisms.

18. GROUP A INSIGNIFICANT ACTIVITIES:

	Group A	Emissions (tpy)						
Source Name	Category	PM/PM ₁₀	0.0	VOC	СО	NO	HAPs	
	g · J	PIVI/PIVI ₁₀	SO_2	VOC		NO_x	Single	Total
Diesel or Propane Space Heaters (20 Total)	A-1	0.002	1.1E- 05	0.0036	0.025	0.09	0.0036	0.0036
10,000 gallon Diesel Storage Tanks (3 Total)	A-3			0.005			0.005	0.005
700 gallon Diesel Storage Tank	A-3			0.0001			0.0001	0.0001
572 gallon Diesel Storage Tank	A-3			0.0002			0.0002	0.0002

AFIN: 29-00506 Page 12 of 13

	Group A	Emissions (tpy)						
Source Name	Category	PM/PM ₁₀	SO_2	VOC	СО	NO _x	HA	Ps
	g · J	PIVI/PIVI ₁₀	SO_2	VOC	CO	NO_X	Single	Total
Boiler Feed Pump Lube Oil Reservoir (2,906 gal)	A-3			0.0008			0.0008	0.0008
550 gallon Diesel Storage Tank	A-3			0.0001			0.0001	0.0001
10,000 gallon Construction fuel storage tank (diesel)	A-3			0.0128			0.0128	0.0128
10,000 gallon Sulfuric Acid Tanks (2 total)	A-4							
4,800 gallon Sulfuric Acid Tank	A-4							
10,000 gallon Sodium Hypochlorite Tank	A-4							
5,000 gallon Sodium Hypochlorite Tank	A-4							
1,500 gallon Sodium Bromide Tank	A-4							
11,100 gallon Coagulant Tank	A-4							
1,500 gallon Corrosion Inhibitor/Phosphoric Acid Tank	A-4							
30,000 gallon Anhydrous Ammonia Tank	A-4							
Emissions from laboratory equipment & vents	A-5	No VOCs are used in the plant's laboratory.						
Water washing activities of empty 55 gallon drums	A-6							
5 gallon Gasoline Containers (15 total)	A-8							

AFIN: 29-00506 Page 13 of 13

	Group A	Emissions (tpy)						
Source Name	Category	PM/PM ₁₀	SO_2	VOC	СО	NO _x	HAPs	
		1 1/1/1 1/11()				NO _x	Single	Total
Turbine Lube Oil	A 12			0.007			0.007	0.007
Storage Tank (16,800 gal)	A-13			0.007			0.007	0.007
Turbine Lube Oil								
Reservoir and	A-13			0.03			0.003	0.003
Storage Tank	A-13			0.03	.03		0.003	0.003
(11,624 gal)								

19. VOIDED, SUPERSEDED, OR SUBSUMED PERMITS:

List all active permits voided/superseded/subsumed by the issuance of this permit.

Permit #
2123-AOP-R6



Facility Name: American Electric Power Service Corporation (John W. Turk Jr. Power Plant)

Permit Number: 2123-AOP-R7

AFIN: 29-00506

\$/ton factor 23.93 Annual Chargeable Emissions (tpy) 4501.46
Permit Type Modification Permit Fee \$ 1114.6594

Minor Modification Fee \$ 500
Minimum Modification Fee \$ 1000
Renewal with Minor Modification \$ 500
Check if Facility Holds an Active Minor Source or Minor
Source General Permit
If Hold Active Permit, Amt of Last Annual Air Permit Invoice \$ 0
Total Permit Fee Chargeable Emissions (tpy) 46.58
Initial Title V Permit Fee Chargeable Emissions (tpy)

 $HAPs\ not\ included\ in\ VOC\ or\ PM:$

Chlorine, Hydrazine, HCl, HF, Methyl Chloroform, Methylene Chloride, Phosphine, Tetrachloroethylene, Titanium Tetrachloride

Air Contaminants:

All air contaminants are chargeable unless they are included in other totals (e.g., H2SO4 in condensible PM, H2S in TRS, etc.)

Pollutant (tpy)	Check if Chargeable Emission	Old Permit	New Permit	Change in Emissions	Permit Fee Chargeable Emissions	Annual Chargeable Emissions
PM		809.55	468.5	-341.05		
PM_{10}		743.5	744	0.5	-65.55	744
PM _{2.5}		0	0	0		
SO_2		2102.8	2102.8	0	0	2102.8
VOC		22.6	96.71	74.11	74.11	96.71
СО		3950.1	3986.7	36.6		
NO_X		1334.5	1334.5	0	0	1334.5
Acetaldehyde*		0.97	0.03	-0.94		
Acrolein*		0.51	0.03	-0.48		
Antimony**		0.66	0	-0.66		
Arsenic**		2.25	0	-2.25		
Benzene*		2.2	0.05	-2.15		
Benzyl Chloride*		1.15	0	-1.15		
Beryllium**		0.05	0	-0.05		
1,3-Butadiene*		0.04	0.04	0		
Cadmium**		0.09	0	-0.09		
Carbon Disulfide**		0.22	0	-0.22		
Chloroform*		0.1	0	-0.1		
Chromium**		0.77	0	-0.77		
Chromium VI**		0.23	0	-0.23		
Cobalt**		0.13	0	-0.13		
Cyanide**		4.11	0	-4.11		
Dichlorobenzene*		0.01	0	-0.01		
Dimethyl Sulfate*		0.08	0	-0.08		
Dioxins & Furans		0.01	0	-0.01		
Formaldehyde*		0.45	0.03	-0.42		
Hexane*		0.42	0.01	-0.41		
Hydrogen Chloride	~	15.77	52.56	36.79	36.79	52.56
Hydrogen Fluoride	~	5.26	5.26	0	0	5.26
Lead**		0.43	0.6801	0.2501		

Pollutant (tpy)	Check if Chargeable Emission	Old Permit	New Permit	Change in Emissions	Permit Fee Chargeable Emissions	Annual Chargeable Emissions
Manganese**		4.81	0	-4.81		
Mercury		0.044735	3.17E-02	-0.013035		
Methylhydrazine*		0.28	0	-0.28		
Nickel**		0.47	0	-0.47		
Phenol*		0.03	0	-0.03		
Phosphorous**		10.51	0	-10.51		
POM*		0.08	0.03	-0.05		
Propionaldehyde*		0.63	0	-0.63		
Selenium**		1.06	0	-1.06		
Sulfuric Acid		110.4	110.38	-0.02		
Toluene*		0.05	0.05	0		
2,2,4-Trimethylpentane		0.01	0.01	0		
Xylene*		0.04	0.04	0		
Ammonia	~	164.4	164.4	0	0	164.4
Total Other HAPs		0	35.15	35.15		
Total Other Chargeable HAPs	~	0	0.55	0.55	0.55	0.55
Total Other Air Contaminants	~	0	0.68	0.68	0.68	0.68