

# Boar's Head Provisions Co., Inc.



Established 1905

March 6, 2023

Arkansas Department of Environmental Quality  
Sanitary Sewer Overflow Reporting

RE: 5-day Follow-up Report From SSO Event on 3/3/2023

Submitted via email to: [ssoadeq@adeq.state.ar.us](mailto:ssoadeq@adeq.state.ar.us)

Submitted via email from: [paul.emerson@boarshead.com](mailto:paul.emerson@boarshead.com)

To whom it may concern,

This letter serves as the 5-day Follow-up Report to the Sanitary Sewer Overflow (SSO) notice reported on March 3, 2023. Further investigation revealed that immediately prior to the SSO the area received a large storm event that produced enough rainfall to overwhelm the lift station that services the facility. When the lift station gets overwhelmed the sanitary sewer flow from the plant ceases. The stagnated flow clogged the pipes immediately leaving the facility, requiring them to be jetted to re-store the normal flow.

Should you have questions or concerns, please contact me at the information below.

Sincerely,

A rectangular box containing a handwritten signature in black ink. The signature reads "Paul Emerson" in a cursive, slightly slanted script.

Paul Emerson  
Environmental Manager  
Boar's Head Provisions Co., Inc.  
804-833-7100 Ext. 3149  
Paul.Emerson@boarshead.com