

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY

IN THE MATTER OF:

City of Forrest City
303 North Rosser
Forrest City, AR 72336

LIS No. 17-085
Permit No. AR0020087
AFIN 62-00070

CONSENT ADMINISTRATIVE ORDER

This Consent Administrative Order (“Order”) is issued pursuant to the authority of the Arkansas Water and Air Pollution Control Act, Ark. Code Ann. § 8-4-101 *et seq.*, the Federal Water Pollution Control Act, 33 U.S.C. § 1311 *et seq.*, and the regulations issued thereunder by Arkansas Pollution Control and Ecology Commission (APC&EC).

The issues herein having been settled by the agreement of the City of Forrest City (“Respondent”) and the Arkansas Department of Environmental Quality (ADEQ or “Department”), it is hereby agreed and stipulated that the following FINDINGS OF FACT and ORDER AND AGREEMENT be entered.

FINDINGS OF FACT

1. Respondent operates a municipal wastewater treatment facility (“facility”) located at 320 SFC 209, Forrest City, St. Francis County, Arkansas.
2. Respondent discharges treated wastewater to an unnamed tributary, thence to the L’Anguille River, thence to the St. Francis River in Segment 5B of the St. Francis River Basin.
3. Respondent is regulated pursuant to the National Pollutant Discharge Elimination System (NPDES).

4. Pursuant to the federal Clean Water Act, 33 U.S.C. § 1311(a) *et seq.*, the NPDES program prohibits the discharge of pollutants except as in compliance with a permit issued under the NPDES program in accordance with 33 U.S.C. § 1342(a).

5. ADEQ is authorized under the Arkansas Water and Air Pollution Control Act (“the Act”) to issue NPDES permits in the state of Arkansas and to initiate an enforcement action for any violation of an NPDES permit.

6. Ark. Code Ann. § 8-4-217(a)(3) provides:

(a) It shall be unlawful for any person to:

...

(3) Violate any provisions of this chapter or of any rule, regulation, or order adopted by the [APC&EC] under this chapter or of a permit issued under this chapter by the [ADEQ].

7. Ark. Code Ann. § 8-4-103(c)(1)(A) authorizes ADEQ to assess an administrative civil penalty not to exceed ten thousand dollars (\$10,000) per violation for any violation of any provision of the Act and any regulation or permit issued pursuant to the Act.

8. Pursuant to Ark. Code Ann. § 8-4-103(c)(1)(B), “Each day of a continuing violation may be deemed a separate violation for purposes of penalty assessment.”

9. NPDES Permit Number AR0020087 (“Permit”) was issued to Respondent on July 26, 2012. The Permit became effective on August 1, 2012, and expires on July 31, 2017.

10. On May 8, 2015, the Department conducted a file review of Sanitary Sewer Overflow (SSO) Reports submitted by the facility in accordance with the Permit for the period of March 1, 2014, through May 8, 2015. The review revealed that Respondent reported forty-one (41) SSOs.

11. Each of the forty-one (41) SSOs constitutes an unpermitted discharge that violates Ark. Code Ann. § 8-4-217(a)(3).

12. On May 11, 2015, the Department sent a letter to Respondent requesting the submission of a Corrective Action Plan (CAP) to address the SSOs.

13. On June 13, 2015, a CAP addressing the SSOs was received from Respondent and subsequently approved by the Department on June 24, 2015.

14. On April 20, 2016, the Department conducted a routine compliance inspection of the facility and Collection System. The inspection revealed the following:

a. The Turner Pump Station Wet Well contained heavy amounts of grease, floating solids, and debris. This failure violated Part III, Section B, Item 1A of the Permit and therefore Ark. Code Ann. § 8-4-217(a)(3).

b. The Mallory Pump Station had only one pump that was operational. This violated Part III, Section B, Item 1A of the Permit and therefore Ark. Code Ann. § 8-4-217(a)(3).

c. The Prison Pump Station Grinder was not operational. This failure violated Part III, Section B, Item 1A of the Permit and therefore Ark. Code Ann. § 8-4-217(a)(3).

d. A significant amount of erosion was evident on the levees of the North equalization Basin. This condition violated Part III, Section B, Item 1A of the Permit and therefore Ark. Code Ann. § 8-4-217(a)(3). This violation was previously cited in inspections conducted on April 17, 2014, and August 20, 2014.

15. On May 16, 2016, the Department notified Respondent via letter of the results of the inspection. The inspection was referred to the Enforcement Branch for review.

16. On July 20, 2016, the Department conducted a supplementary file review of SSO Reports submitted by the facility in accordance with the Permit for the period of May 9, 2015, through July 20, 2016. The review revealed that Respondent reported twenty-seven (27) additional SSOs since approval of the CAP.

17. Each of the additional twenty-seven (27) SSOs constitutes an unpermitted discharge that violates Ark. Code Ann. § 8-4-217(a)(3).

18. On June 29, 2016, the Department received a response to the May 16, 2016 inspection report.

19. On November 22, 2016, the Department conducted a review of certified Discharge Monitoring Reports (DMRs) submitted by Respondent in accordance with the Permit.

20. That review revealed that Respondent reported the following violations of the permitted effluent discharge limits detailed in Part I Section A of the Permit from October 1, 2013, through October 31, 2016.

- a. Two (2) violations for Total Suspended Solids;
- b. One (1) violation for Fecal Coliform;
- c. Two (2) violations for Biological Oxygen Demand, Carbonaceous (5 day, 20C);
and
- d. One (1) violation for Ammonia Nitrogen.

21. Each of the six (6) discharge limitation violations listed in Paragraph 20 above constitutes a separate permit violation, for a total of six (6) separate violations of Ark. Code Ann. § 8-4-217(a)(3).

22. On November 23, 2016, the proposed CAO was sent via certified mail to Respondent.

23. On January 25, 2017, the Department met with Respondent to discuss the proposed CAO, the requirements of the CAP, and an extension of the due date for their renewal application.
24. On January 26, 2017, the Department received a 30 day permit renewal deadline extension request from Respondent via email.
25. On January 31, 2017, the Department notified Respondent via letter that the requested renewal deadline extension had been granted, with a new deadline of March 2, 2017.
26. On February 9, 2017, the Department received a memorandum of agreement between Respondent and the U.S. Department of Justice, Federal Bureau of Prisons, Federal Correction Institution, stating that Respondent will not be responsible for any service for the lift station at the Federal Correction Complex (FCC) Forrest City.
27. On February 17, 2017, the Department received documentation from FCC Forrest City stating that their agreement with Respondent for Respondent to service and maintain the lift station at FCC Forrest City was terminated. Future oversight of the lift station will be conducted by staff employed by the FCC Forrest City. FCC is now a satellite sewer system of Respondent.
28. On February 17, 2017, a complete renewal application was received by the Department from Respondent.
29. On February 28, 2017, the Department received a response to the proposed CAO.
30. On March 7, 2017, the Department held a teleconference with Respondent to discuss their response to the proposed CAO.
31. On March 7, 2017, the Department notified Respondent via certified mail that a complete renewal application had been received.
32. The Department conducted a review of certified DMRs submitted by the Facility in accordance with the Permit. The review revealed one violation for Fecal Coliform of the

permitted effluent discharge limits detailed in Part I, Section A of the Permit from November 1, 2016, through August 31, 2017.

33. Each discharge limitation violation listed in Paragraph 32 above constitutes a separate permit violation for a total of one violation of Ark. Code Ann. § 8-4-217(a)(3).

ORDER AND AGREEMENT

WHEREFORE, the parties stipulate and agree as follows:

1. Respondent shall, within thirty (30) calendar days of the effective date of this Order, submit to ADEQ, for review and approval a comprehensive CAP developed by a Professional Engineer (P.E.) licensed in the State of Arkansas. The CAP shall, at minimum, include a reasonable milestone schedule with a date of final compliance no later than December 31, 2018. The CAP shall detail the methods and best available technologies that will be used to correct the violations listed in Findings of Fact paragraphs 14, 20, and to prevent further erosion of the north equalization basin levees. Upon review and approval by ADEQ, Respondent shall comply with the terms, milestone schedule, and final compliance date contained in the CAP, and the approved CAP, milestone schedule, and final compliance date shall be fully enforceable as terms of this Order.

2. Within thirty (30) calendar days of the effective date of this Order, and each quarter thereafter for a period lasting until this Order is closed, the Respondent shall submit quarterly progress reports detailing the progress that has been made towards correcting the violations listed in the Findings of Fact Paragraphs 14 and 20. Respondent shall submit the final compliance report by December 31, 2018.

3. Within three (3) months of the effective date of this Order, with the overall goal of eliminating capacity and non-capacity related SSOs, the Respondent shall submit to ADEQ, for

review and approval, a Sewer System Evaluation Study (SSES) Plan developed by a P.E. licensed in the State of Arkansas for its sanitary sewer collection system.

- a. The SSES Plan shall at minimum have the following elements:
 - i. A schedule to perform smoke testing in all areas of the collection system, beginning with highest priority areas;
 - ii. A schedule to perform televising of lines in areas deemed necessary based on smoke testing in order to locate leaks and to determine method of repair;
 - iii. A plan to address deficiencies through rehabilitation, repair, or replacement;
 - iv. A manhole inspection program, beginning in highest priority area; Recommend a method of repair and develop a cost estimate for such; and
 - v. A milestone schedule to complete the SSES and submit a final SSES Report to ADEQ. The milestone schedule shall be incorporated into this Order by reference and fully enforceable as terms of this Order.

Based on the results of the above SSES, the Respondent will be able to identify areas requiring improvements and to prioritize those improvements. Short-term and long-term improvements shall be considered to remedy deficiencies.

- b. The SSES Report shall include an SSO Plan with a milestone schedule that details the steps the Respondent shall take to fully and expeditiously implement the corrective action. Upon approval by ADEQ, the SSO Plan and milestone schedule shall be incorporated

into this Order by reference and fully enforceable as terms of this Order. Failure to comply with the schedule, as approved by ADEQ, will result in the Respondent being subject to the stipulated penalties contained in Paragraph 7 below.

4. Within nine (9) months of the effective date of this Order, Respondent shall submit to ADEQ a progress report detailing the actions that have been made in the implementing the SSES Plan. Respondent shall continue to submit semi-annual progress reports thereafter until the Order is closed.

5. On or before the final compliance dates listed in the SSES and SSO Plans, Respondent shall submit a final report to the Department. This report must be certified by a P.E. licensed in the State of Arkansas.

6. In compromise and full settlement of the violations specified in the Findings of Fact, Respondent agrees to pay a civil penalty of Five Thousand Four Hundred Sixty Dollars (\$5,460.00). Payment is due within thirty (30) calendar days of the effective date of this Order. Such payment of the penalty shall be made payable to the Arkansas Department of Environmental Quality, and mailed to the attention of:

Arkansas Department of Environmental Quality
Fiscal Division
5301 Northshore Drive
North Little Rock, AR 72118

In the event that Respondent fails to pay the civil penalty within the prescribed time, ADEQ shall be entitled to attorneys' fees and costs of collection.

7. Failure to meet any requirement or deadline of this Order constitutes a violation of said Order. If Respondent should fail to meet any such requirements or deadlines, the Respondent

consents and agrees to pay on demand to ADEQ stipulated penalties according to the following schedule:

- a. First day through fourteenth day: \$100.00 per day
- b. Fifteenth day through the thirtieth day: \$500.00 per day
- c. Each day beyond the thirtieth day: \$1000.00 per day

These stipulated penalties for delay in performance shall be in addition to any other remedies or sanctions which may be available to ADEQ by reason of failure by Respondent to comply with the requirements of this Order.

8. If any event, including but not limited to an act of nature, occurs which causes or may cause a delay in the achievement of compliance by Respondent with the requirements or deadlines of this Order, Respondent shall so notify ADEQ, in writing, as soon as reasonably possible after it is apparent that a delay will result, but in no case after the due dates specified in this Order. The notification shall describe in detail the anticipated length of the delay, the precise cause of the delay, the measures being taken and to be taken to minimize the delay, and the timetable by which those measures will be implemented.

9. ADEQ may grant an extension of any provision of this Order, provided that Respondent requests such an extension in writing and provided that the delay or anticipated delay has or will be caused by circumstances beyond the control of and without the fault of Respondent. The time for performance may be extended for a reasonable period but in no event longer than the period of delay resulting from such circumstances. The burden of proving that any delay is caused by circumstances beyond the control of and without the fault of Respondent and the length of the delay attributable to such circumstances shall rest with Respondent. Failure to notify the ADEQ

promptly, as provided in the preceding paragraph of this Section, shall be grounds for a denial of an extension.

10. All requirements by the Order and Agreement are subject to approval by ADEQ. Unless otherwise specified herein, in the event of any deficiencies, Respondent shall, within the timeframe specified by ADEQ, submit any additional information or changes requested, or take additional actions specified by ADEQ to correct any such deficiencies. Failure to adequately respond to such Notice of Deficiency within the timeframe specified in writing by ADEQ constitutes a failure to meet the requirements established by this Order.

11. This Order is subject to public review and comment in accordance with Ark. Code Ann. § 8-4-103(d) and APC&EC Regulation No. 8 and shall not be effective until thirty (30) calendar days after public notice is given. ADEQ retains the right to rescind this Order based upon the comments received within the thirty-day public comment period. Notwithstanding the public notice requirements, the corrective actions necessary to achieve compliance shall be taken immediately. The publication of this Order shall occur on or about the 10th or 25th day of the month following the date this Order is executed. As provided by APC&EC Regulation No. 8, this matter is subject to being reopened upon Commission initiative or in the event a petition to set aside this Order is granted by the Commission.

12. Nothing in this Order shall be construed as a waiver by ADEQ of its enforcement authority over alleged violations not specifically addressed herein. Also, this Order does not exonerate Respondent from any past, present, or future conduct which is not expressly addressed herein, nor does it relieve Respondent of its responsibilities for obtaining any necessary permits.

13. This Order has been reviewed and approved by the City Council of Respondent in a duly convened meeting with a quorum present. See copy of [meeting minutes or resolution] attached as Exhibit A.

14. The City Council of Respondent has authorized the Mayor and City Clerk/Treasurer to sign this Order on behalf of Respondent. See Exhibit A.

15. The City Council of Respondent has authorized the Mayor and City Clerk/Treasurer to expend funds for compliance activities required by this Order including but not limited to the payment of a civil penalty in the amount of Five Thousand Four Hundred Sixty Dollars (\$5,460.00). See Exhibit A.

SO ORDERED THIS 23 DAY OF October, 2017.

Becky W. Keogh
BECKY W. KEOGH, DIRECTOR

APPROVED AS TO FORM AND CONTENT:

City of Forrest City

BY: [Signature] Dorene Cochran
(Signature) City Clerk - Treasurer

Larry S. Bryant
(Typed or printed name)

TITLE: MAYOR

DATE: 9/19/17

**MINUTES OF THE Special Called MEETING
FORREST CITY CITY COUNCIL
FORREST CITY, ARKANSAS
August 24, 2017**

The City Council of Forrest City, Arkansas met in a Special Called Meeting on August 24, 2017. Mayor Bryant called the meeting to order at 6:00 p.m. Alderman Williams offered prayer after which the Pledge of Allegiance was led by Alderman Echols. The following answered roll call: Mayor Bryant, Clerk Cochran, Attorney Cline, and City Council members: Williams, Metcalf, Echols, Fields, Capps, and Oswalt. Alderman Breeding and Reeves were absent.

Mayor Bryant stated the reason for the special called meeting is the city had a deadline in regards to Arkansas Department of Environmental Quality consent of administration order (each council member was given a copy of the CAO). He stated since there is no water commission, it was asked by ADEQ that the mayor and city clerk sign the consent. Page 10 item numbers #13, #14, and #15 explains in the document that the information be presented to the city council of respondent in a duly convened meeting with a quorum present. Once a quorum is present, the city council can authorize the mayor and city clerk/treasurer to sign the order on behalf of Respondent and a copy of the minutes can be attached as Exhibit A.

The council would also give the mayor and city clerk/treasurer the authority to expend funds for compliance activities by this order. The penalty as negotiated is \$5,460.00.


Alderman Capps made a motion that the Consent of Administrative order particularly page 10 item #13, #14, and #15 be accepted. The City Council reviewed and authorized the Mayor and City Clerk/Treasurer to sign the CAO and expend funds for compliance activities required by the consent administration order for civil penalty in the amount of \$5,460.00. The motion was second by Alderman Fields.


Alderman Williams questioned the order. Mayor Bryant stated there were findings that dated back to 2013 and beyond. This consent is to remedy all findings.

Alderman Capps questioned Page 3 item #14-b, the Mallory pump station had only one pump that was operational which violates Ark. Code Ann. 8-4-217. He asked if the city is required to have two pumps operating at all times. Mr. Murdock stated there are three pumps at that station and two pumps were working. Roll Call: All Ayes.

Mac Compton and Clay Thompson Engineers were recognized from RJN Engineering Firm who were hired to help city water with the I & I issues.

Alderman Echols made a motion to adjourn at 6:10 p.m. Alderman Fields second the motion.


Derene Cochran, Clerk-Treasurer


Larry S. Bryant, Mayor