



June 7, 2018

The Honorable Larry Bryant  
Mayor, City of Forrest City  
303 North Rosser  
Forrest City, AR 72336

Email: [larrysbryant@gmail.com](mailto:larrysbryant@gmail.com)

RE: NPDES Permit Number AR0020087, AFIN 62-00070  
NPDES Permit Effluent Violations

Dear Mayor Bryant:

The Department has conducted a file review of the above referenced permit and determined your facility reported the following violation of the effluent limitations in Part I, Section A of your Permit for the following reporting period:

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value
04/30/2018	001-A	Solids, total suspended, MO AVG, lb/d	353.6	409.8

Failure to remain in compliance with the effluent limitations set forth in your permit violates Part I, Section A of your permit, and may result in formal enforcement action that will include the assessment of a civil penalty.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0664 or via e-mail at [pemberton@adeq.state.ar.us](mailto:pemberton@adeq.state.ar.us).

Sincerely,

Layne Pemberton  
Enforcement Analyst  
Office of Water Quality, NPDES Enforcement Section

CC: Calvin Murdock [whcm2@aol.com](mailto:whcm2@aol.com)