## NON-COMPLIANCE REPORT

**Facility Name: Forrest City Wastewater Treatment Plant** 

NPDES Permit: AR0020087

REPORTING PERIOD 6/1/2021 TO 6/30/2021

VIOLATION Exceeded 7day Geo Fecal Coliform Permit Limit

PARAMETER	NUMERIC VALUE	PERMIT LIMIT
7day Fecal Coliform (Maximum Concentration)	2420 #/100mL	2000 #/100mL

## **REASON FOR VIOLATIONS:**

A unknown event, possibly electrical, caused damage to the U.V. Unit Controller.

## CORRECTIVE ACTION/PREVENTIATIVE MEASURES/OTHER NARRATIVE:

We have a new replacement U.V. unit sitting at our facility. We are currently wait on the control board. Control Board was due here 7/09/21. Contractor said it would take a couple of days to install. We hope to have installed by 7/20/21. We have had no other violations since the 2nd week of June.

Joel Thetford