



Forrest City Water Utility

303 NORTH ROSSER ST.
FORREST CITY, ARKANSAS 72335
870-633-2921

NON-COMPLIANCE REPORT

Facility Name: Forrest City Wastewater Treatment Plant

NPDES Permit: AR0020087

REPORTING PERIOD 10/1/2020 TO 10/31/2020

VIOLATION Exceeded 7day Geo Fecal Coliform Permit Limit

PARAMETER	NUMERIC VALUE	PERMIT LIMIT
7day Fecal Coliform (Maximum Concentration)	2196 #/100mL	2000 #/100mL

REASON FOR VIOLATIONS:

Clarifier #2 RAS piping clogged. Clarifier filled with sludge and none was being returned

CORRECTIVE ACTION/PREVENTIATIVE MEASURES/OTHER NARRATIVE:

On 10/28/20 we found sludge level was high in Clarifier #2. Shut Clarifier #3 off and started pulling sludge from Clarifier #2. Also started wasting to Ponds.

After draining Clarifier #2 we opened Clarifier #3 and started refilling process.

Currently, we have not received any test reports to verify if there are any non-compliance issues to date.

Calvin Murdock