



ARKANSAS

ENERGY & ENVIRONMENT

November 24, 2020

Honorable Larry Bryant
City of Forrest City
303 North Rosser Street
Forrest City, AR 72336

email: whcm2@aol.com

RE: NPDES Permit Number AR0020087, AFIN 62-00070
Permitted Effluent Limitation Violations

Dear Mayor Bryant,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

The facility has reported 10 violation of Part I, Section A of NPDES Permit No. AR0020087 during the review period. DEQ requires the City of Forrest City to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

The DMR effluent violations are included at the end of this letter and the NODI Code violations are included after the effluent violations.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at gavin.gray@adeq.state.ar.us.

Sincerely,

A handwritten signature in blue ink that reads "Gavin Gray".

Gavin Gray
Enforcement Analyst
Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio	Violation Code	Parameter Code
06/30/2020	001-A	Nitrogen, ammonia total [as N], MO AVG, lb/d	37	59	59%	E90	00610-1-0
06/30/2020	001-A	Nitrogen, ammonia total [as N], MO AVG, mg/L	2.1	3.91	86%	E90	00610-1-0
06/30/2020	001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	4.5	7.13	58%	E90	00610-1-0
05/31/2020	001-A	Coliform, fecal general, 30DA GEO, #/100mL	1000	1472	47%	E90	74055-1-0
05/31/2020	001-A	Coliform, fecal general, 7 DA GEO, #/100mL	2000	3226	61%	E90	74055-1-0
03/31/2020	001-Q	Copper, total recoverable, MO AVG, lb/d	0.52	1.96	277%	E90	01119-1-0

AR0020087 - FORREST CITY, CITY OF (62-00070)

DMR End Date	Disch-Desig	Parameter Desc	Reported DMR Value	Limit Value	Vio %	Vio Code	DMR Value Recd Date	Days Late	NO D I	NODI Desc	DMR Value Type Code	Parameter Code
05/31/2020	001-A	Nitrite + Nitrate total [as N] (MO AVG, mg/L)	E	Report		Mon-Only Ovrdu	6/24/20		E	Failed to Sample/Requ	C2	00630-1-
05/31/2020	001-A	Nitrite + Nitrate total [as N] (7 DA AVG, mg/L)	E	Report		Mon-Only Ovrdu	6/24/20		E	Failed to Sample/Requ	C3	00630-1-
05/31/2020	001-A	Phosphorus, total [as P] (MO AVG, mg/L)	E	Report		Mon-Only Ovrdu	6/24/20		E	Failed to Sample/Requ	C2	00665-1-
05/31/2020	001-A	Phosphorus, total [as P] (7 DA AVG, mg/L)	E	Report		Mon-Only Ovrdu	6/24/20		E	Failed to Sample/Requ	C3	00665-1-

