



ARKANSAS

ENERGY & ENVIRONMENT

February 1, 2021

Cedric Williams, Mayor
City of Forrest City
303 North Rosser Street
Forrest City, AR 72336

email: whcm2@aol.com

RE: NPDES Permit Number AR0020087, AFIN 62-00070
Permitted Effluent Limitation Violations

Dear Mayor Williams,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

The facility has reported 3 violations of Part I, Section A of NPDES Permit No. AR0020087 during the review period. DEQ requires the City of Forrest City to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at gavin.gray@adeq.state.ar.us.

Sincerely,

Gavin Gray
Enforcement Analyst
Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio	Violation Code	Parameter Code
11/30/2020	001-A	Solids, total suspended, 7 DA AVG, mg/L	30	35.9	20%	E90	00530-1-0
11/30/2020	001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	4.5	4.57	2%	E90	00610-1-1
10/31/2020	001-A	Coliform, fecal general, 7 DA GEO, #/100mL	2000	2196	10%	E90	74055-1-0