



Forrest City Water Utility
303 N. Rosser St
Forrest City, AR 72335

06/22/2016

Transmittal Letter

Arkansas Department of Environmental Quality
5301 North Shore Dr.
North Little Rock, AR 72118-5317
ATTN: Water Division- Enforcement Branch

Please find Enclosed for your distribution the following:

May 2016 - DMR

May 2016 – SSO

May 2016 – Non Compliance Report

Sincerely,

A handwritten signature in black ink, appearing to read "W.H. Calvin Murdock".

Forrest City Water Utility
W.H. Calvin Murdock, Manager
(870)633-2921 – Office
(870)261-2849 Cell
WHCM2@Forrestcitywater.com

FORREST CITY WATER UTILITY
 303 NORTH ROSSER STREET P.O.
 BOX 816 FORREST CITY,
 AR 72335 AFIN 62-00070

Sanitary Sewer Overflow (SSO) Monthly Report

NPDES Permit No.: AR0020087

Monitoring Period (Month/Year): May-2016


No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Description

Cause(s) of SSO		SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH - No Evidence of Adverse health/ Environmental Impact	MR-Machine Rodded	CR-Creek/Stream/Rever (specify)
E-Equipment Failure	G-Grease	OEHC - Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure	EFK - Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots/Grease	OEEI - Observed or Evidence of Environmental Impact	HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area
			PN-Public Notice	CB-Contained n Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location
1996 Dale Bumpers Rd (Federal Prison)		5/10/2016	5/10/2016	1000gals or less	Power Failure	NEAH	Other	GR

Signature of Principal Executive Office or Authorized Agent

 Date 6/22/16

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.



Forrest City Water Utility

303 NORTH ROSSER ST.
FORREST CITY, ARKANSAS 72335
870-633-2921

NON-COMPLIANCE REPORT

Facility Name: Forrest City Wastewater Treatment Plant

NPDES Permit: AR0020087

REPORTING PERIOD 5/1/2016 TO 5/31/16

VIOLATION 1 Exceeded Total Ammonia Nitrogen Permit Limit

PARAMETER	NUMERIC VALUE	PERMIT LIMIT
Nitrogen, ammonia 7 DA AVG. (QUANTITY)	4.82 mg/L	4.5 mg/L

REASON FOR VIOLATIONS:

Clarifier #1 suction pipe for the RAS was clogged which caused an imbalance in the sludge depth ratio. This imbalance caused a higher than normal Nitrogen ammonia level.

CORRECTIVE ACTION/PREVENTIATIVE MEASURES/OTHER NARRATIVE:

Drained and washed out Clarifier #1. Refilled now working normal.


Calvin Murdock

A handwritten signature in black ink, appearing to read 'Calvin Murdock', is written over the printed name.



Forrest City Water Utility
303 N. Rosser Street
P.O. Box 816
Forrest City, AR 72336
870.633.2921 Off. / 870.633.5921 Fax



UNITED STATES POSTAGE
PITNEY BOWES
02 1P \$ 001.15⁰
0000842980 JUN 22 2016
MAILED FROM ZIP CODE 72335



**Arkansas Department of
Environmental Quality**
5301 North Shore Drive
North Little Rock, AR 72118-5317

