



Forrest City Water Utility
303 N. Rosser St.
Forrest City, AR 72335

09/21/2014

Arkansas Department of Environmental Quality
Water Division-Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118-5317

Transmittal Letter

AUGUST- DISCHARGE MONITORING REPORT (DMR)

AUGUST- SANITARY SEWER OVERFLOW (SSO) MONTHLY REPORT

Sincerely,

W.H. Calvin Murdock

FORREST CITY WATER UTILITY
 303 NORTH ROSSER STREET P.O.
 BOX 816 FORREST CITY,
 AR 72335 AFIN 62-00070

Sanitary Sewer Overflow (SSO) Monthly Report

NPDES Permit No.: AR0020087

Monitoring Period (Month/Year): August-2014


No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Description

Cause(s) of SSO		SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH - No Evidence of Adverse health/ Environmental Impact	MR-Machine Rodded	CR-Creek/Stream/Rever (specify)
E-Equipment Failure	G-Grease	OEHC - Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure	EFK - Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots/Grease	OEEI - Observed or Evidence of Environmental Impact	HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area
			PN-Public Notice	CB-Contained n Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location
Empty lot N of Garland St		8/12/2014	8/13/2014	100 or less	D, LF	OEEI	HC	DI
Along Railroad Tracks		8/15/2014	8/15/2014	Over 500	V	NEAH	MR, Other	GR
Kittle and Broadway		8/25/2014	8/25/2014	100 or less	D	NEAH	MR	GR

Signature of Principal Executive Office or Authorized Agent



Date 9/19/14


I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Forrest City Water Utility

303 North Rosser St.

P.O. Box 816

Forrest City, AR 72335



UNITED STATES POSTAGE



PITNEY BOWES

02 1P

\$ 001.19⁰

0003108371

SEP 22 2014

MAILED FROM ZIP CODE 72335

**ARKANSAS DEPARTMENT OF
ENVIRONMENTAL QUALITY
WATER DIVISION – ENFORCEMENT BRANCH
5301 NORTSHORE DRIVE
NORTH LITTLE ROCK, AR 72118-5317**