



Forrest City Water Utility  
303 N. Rosser St./ P.O. Box 816  
Forrest City, AR 72336  
Phone: 870.633.2921/870.270.5017  
Fax: 870.633.5921

---

02/17/2015

Arkansas Department of Environmental Quality  
Water Division- Enforcement Branch  
5301 North Shore Drive  
North Little Rock, AR 72118-5317

Transmittal Letter

JANUARY-DISCHARGE MONITORING REPORT (DMR)

JANUARY-SANITARY SEWER OVERFLOW (SSO) MONTHLY REPORT

Sincerely,  
Forrest City Water Utility

A handwritten signature in black ink, appearing to read "W.H. Calvin Murdock".

W.H. Calvin Murdock,  
Utility Manager

FORREST CITY WATER UTILITY  
 303 NORTH ROSSER STREET P.O.  
 BOX 816 FORREST CITY,  
 AR 72335 AFIN 62-00070

Sanitary Sewer Overflow (SSO) Monthly Report

NPDES Permit No.: AR0020087

Monitoring Period (Month/Year): January-2015

No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Description

Cause(s) of SSO		SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH - No Evidence of Adverse health/ Environmental Impact	MR-Machine Rodded	CR-Creek/Stream/Rever (specify)
E-Equipment Failure	G-Grease	OEHC - Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure	EFK - Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots/Grease	OEEI - Observed or Evidence of Environmental Impact	HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area
			PN-Public Notice	CB-Contained n Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location
Laney Drive		1/1/2015	1/1/2015	500gals or less	D	NEAH	HC	GR
South at the end of A Street		1/15/2015	1/15/2015	500gals or less	D	NEAH	MR	GR
End of A Street by Railroad		1/28/2015	1/28/2015	500gals or less	D	NEAH	MR	GR
South of 604 of Buford		1/29/2015	1/29/2015	less than 50gals	LF	NEAH	Repaired Line	CR

Signature of Principal Executive Office or Authorized Agent:  Date: 2/17/15

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

**Forrest City Water Utility**

303 North Rosser St.

P.O. Box 816

Forrest City, AR 72335



UNITED STATES POSTAGE



02 1P

**\$ 000.98<sup>0</sup>**

0000842980

FEB 17 2015

MAILED FROM ZIP CODE 72335

Arkansas Department of Environmental Quality  
Water Division- Enforcement Branch  
5301 North Shore Drive  
North Little Rock, AR 72118-5317

