

Anderson, Alan

From: Fuller, Kim
Sent: Monday, September 17, 2012 3:38 PM
To: Anderson, Alan
Cc: Uyeda, Craig; Bailey, John
Subject: FW: Permit # AR0020273 Process Equipment Out of Service

Alan,

I received the following email from the City of Siloam Springs regarding some required maintenance. I was out of the office on Friday afternoon when he first called. I did not have a detailed message regarding the reason for the call. When I talked to him today, he told me about the equipment malfunction and that 1 of their BNR treatment trains had to be taken out of service. These treatment trains are in parallel, so all of the wastewater is being routed through either BNR Train #1 or Train #2. Based on the treatment process and the following email, I don't think that the wastewater is bypassing any treatment unit. Let me know if you need anything additional. Thanks!

Kimberly A. Fuller, P.E.
NPDES Engineer Supervisor
ADEQ, Water Division
Phone: (501) 682-0643

From: Tom Myers [<mailto:tmyers@siloamsprings.com>]
Sent: Monday, September 17, 2012 2:27 PM
To: Fuller, Kim
Cc: Justin Bland; Jack Harrison
Subject: RE: Permit # AR0020273 Process Equipment Out of Service

Fuller, Kimberly Engineer Supervisor	Water	(501) 682-0643 Email: fuller@adeq.state.ar.us
--	-----------------------	---

Dear Ms. Fuller

This email is a follow up to our phone call today at 1402 September 17, 2012. I call last Friday to discuss the work that we our conducting on BNR Train #3. You were not available at the time I called and requested you return my call. Currently BNR Train #3 of 3 units has been taken out of service to conduct repairs to the Axial Flow Pump. We are working with the contractor to have it repaired and returned to service soon as possible. Currently our plant is meeting all permit requirements and foresee no problems continually meeting them. I will follow up with you regarding this matter if a problem develops or when we place it back into service.

Sincerely,

Tom Myers
Environmental Compliance Manager
City of Siloam Springs
Ph: 479-524-5623
Cell: 479-228-0934
Fax: 479-524-4653
tmyers@siloamsprings.com

