

Exhibit "B"

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0020273 Discharge Number: 001

Facility: City of Siloam Springs Wastewater Facility

Address: 975 Anderson Avenue

City: Siloam Springs State: Arkansas Zip: 72761

Contact: Thomas A. Myers Phone: 479-524-5623

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
November 18, 2019	7-Day Max Phosphorus	1.64 mg/l		1.5 mg/l

We feel this problem was due to:

Higher than normal influent Phosphorus load to plant. Industrial reports were normal no known cause for higher loading.


We plan on correcting the problem in this manner:

Continue to monitor influent phosphorus loadings and monitor industrial dischargers and other possible sources.

Time estimated that it will take to correct problem:

Plant came back into compliance within a day.

Sincerely,



Submitted By:

Date

5/01/2020

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)