

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0020273 Discharge Number: 001

Facility: City of Siloam Springs Water Pollution Control Facility

Address: 975 Anderson Avenue

City: Siloam Springs State: AR Zip: 72761

Contact: Thomas Myers Phone: 479-524-5623

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
May 1, 2019	Ammonia Nitrogen 7-Day Maximum	154.6 lbs	5.98 mg/L	2.3 mg/L
May 17, 2019	Ammonia Nitrogen 7-Day Maximum	145.6 lbs	5.82 mg/L	2.3 mg/L
Month of May	Ammonia Nitrogen 30-Day Avg	83.54 lbs	2.94 mg/L	1.5 mg/L

We feel this problem was due to:

~~Blower problems and not able to supply sufficient oxygen needed in processes.~~


We plan on correcting the problem in this manner:

~~Problem corrected by installing new blower.~~

Time estimated that it will take to correct problem:

~~Replacement of blower with new one. Installed new blower May 18, 2019~~

Sincerely,


Submitted By:

June 24, 2019

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)