From: Anthony Brown
To: Allen-Daniel, Leslie
Subject: FW: Email from Water Enforcement Analysts Webpage
Date: Wednesday, May 13, 2020 2:23:37 PM
Attachments: image002.png

Please see below.

Respectfully,

Tony Brown
Wastewater Superintendent
975 Anderson Avenue, Siloam Springs, AR 72761
Plant: 479-524-5623
Cell: 479-228-2000
abrown@siloamsprings.com

From: Anthony Brown
Sent: Wednesday, May 13, 2020 2:04 PM
To: christina.brown@adeq.state.ar.us
Cc: Steven Gorszczyk <sgorszczyk@siloamsprings.com>
Subject: Email from Water Enforcement Analysts Webpage

Christina,

This email is to inform you that I was notified today by our contract lab Environmental Testing Group (ETG) that our weekly state testing for Phosphorous, Total as P was (7.9) for the week of 5-4 through 5-8-2020. This was a result of an Industry accidentally releasing approximately one to two thousand gallons of phosphoric acid to the POTW. I had caustic on-site to handle the pH adjustment, however, this phosphoric acid increased our phosphorous loading. I opened a secondary Biological Nutrient Removal (BNR) train to help precipitate the phosphorous loading. I closed BNR train 2 last week and had to reopen BNR 2 this week due to increased rainfall and as a result, phosphorous loading remained elevated. I shut BNR 2 down this morning and will monitor our effluent phosphorous to ensure we are within permit guidelines. Please, let me know if you need anything.

Respectfully,

Tony Brown
Wastewater Superintendent
975 Anderson Avenue, Siloam Springs, AR 72761
Plant: 479-524-5623
Cell: 479-228-2000
abrown@siloamsprings.com

CITY OF
Siloam Springs