

# Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: City of Siloam Springs NPDES Permit No.: AR0020273 Monitoring Period (Month/Year): 06 / 2019

No Sanitary Sewer Overflows This Monitoring Period

## REPORT CODE DESCRIPTIONS

Cause(s) of SSO	Environmental Impact	Action(s) Taken	Ultimate Discharge Location
<b>C</b> - Construction	<b>EFK</b> - Evidence of Fish Kill	<b>EC</b> - Environmental Cleanup	<b>GR</b> - Ground
<b>EF</b> - Equipment Failure	<b>OEHC</b> - Evidence of Human Contact	<b>HC</b> - Hydro Cleaned	<b>CR</b> - Creek / Stream / River (specify)
<b>LF</b> - Line Failure	<b>OEEI</b> - Evidence of Environmental Impact	<b>HR</b> - Hand Rodded	<b>DI</b> - Ditch
<b>PF</b> - Power Failure	<b>NEAH</b> - No Evidence of Adverse Health or Environmental Impact	<b>MR</b> - Machine Rodded	<b>DR</b> - Drop Inlet
<b>V</b> - Vandalism		<b>PN</b> - Public Notification	<b>PA</b> - Paved Area
		<b>EN</b> - Referred to Engineering	<b>CB</b> - Contained in Building
		<b>JV</b> - Jet Vac	
		<b>SL</b> - Spread Line	
		<b>DD</b> - Disinfected and Deodorized	
		<b>GP</b> - Used Generator to Power Equipment	

Starting Location (Address, Intersection, or Manhole #)	Start Date of SSO	End Date of SSO	Estim. Volume (in gallons)	Cause(s) of SSO	Environmental Impact	Action(s) Taken	Discharge Location
2000 Central Street Lift Station Western Hills	6/7/19	6/7/19	50	R	NEAH	SL	GR
Villa View Lift Station	6/7/19	6/7/19	35	R	NEAH	SL	DI
Villa View Lift Station	6/7/19	6/7/19	35	R	NEAH	SL	DI
Washington St Basin 6 manhole 136	6/7/19	6/7/19	600	R,G,D	NEAH	JV,HC,SL	CR
3600 Lincoln S. HWY 59 Lift Station Lower	6/23/2019	6/23/2019	125	PF	NEAH	SL	GR
			6/23/19	SL	GR		
975 Anderson Ave Wastewater Plant	6/23/19	6/23/19	35000	R	NEAH	SL	GR

Signature of Cognizant or Ranking Official \_\_\_\_\_  
Date **7-25-2019**

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Mail together with DMR submission **NO LATER THAN THE 25th OF THE MONTH FOLLOWING THE MONITORING PERIOD** to:  
ADEQ Office of Water Quality ❖ 5301 Northshore Drive ❖ North Little Rock, AR 72118