

04-00106

Sanitary Sewer Overflow (SSO) Monthly Report

POST
NOV 20 2012

Facility Name: Siloam Springs NPPDES Permit No.: AR0020273 Monitoring Period (Month/Year): 10 / 2012

No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions

Cause(s) of SSO	SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental.	CR-Creek/Stream/River (specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	DI-Ditch
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill	DR-Drop Inlet
R-Rainfall	RG-Roots / Grease	EC-Environmental Cleanup	GR-Ground Surface
RO-Roots	V-Vandalism	HC-Hydro Cleaned	PA-Paved Area
		HR-Hand Rodded	CB-Contained in Building
		EN-Referred to Engineering	
		PN-Public Notification	

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location
1951 HWY 412 Super 7 Hotel		10/5/2012	10/9/2012	250	D	OEEI	HC-EC	GR
107 Cherri Whitlock Basin 2 MH 47		10/16/2012	10/16/2012	20	G	NEAH	HC-EC	GR
519 S. Maple Street		10/29/2012	10/29/2012	50000	LF	NEAH	HC-EC	Dry Creek-Sager CR
Tahlequah-N. Washington Basing MH137		10/31/2012	10/31/2012	100	D	NEAH	HC-EC	GR

Signature of Cognizant or Ranking Official [Signature] Date 11/20/12

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."