

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020273 Discharge Number: 001

Facility: City of Siloam Springs

Address: P.O. Box

City: Siloam Springs State: Arkansas Zip: 72761

Contact: Thomas A. Myers Phone: 479-524-5623

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
04/13/2016	Ammonia Nitrogen	7-day Maximum	5.6 mg/l	3.9 mg/l
Monthly Avg April	Ammonia Nitrogen		3.4 mg/l	1.6 mg/l
Monthly Mass	Ammonia Nitrogen	98.8 lbs/day		59 lbs/day

We feel this problem was due to:

Within next 14 days.

We plan on correcting the problem in this manner:

Blower has been shipped to Gardner Denver at St. Peters Missouri authorized shop. The Lamson model 1268 blower has been dismantled and repair parts ordered. Repair and return is scheduled to be within next 14 days.

Time estimated that it will take to correct problem:

~~Within next 14 days.~~

Sincerely,



Authorized Signature

5/18/2016

Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)