

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020273 Discharge Number: 001

Facility: Siloam Springs Wastewater Plant

Address: 975 Anderson Avenue

City: Siloam Springs State: AR Zip: 72761

Contact: Tom Myers Phone: 479-524-5623

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
6-15-2016	NH3-N	7.45 mg/L	7-Day Maximum	2.3 mg/L
6-15-2016	B.O.D.	35.0 mg/L	7-Day Maximum	22.5 mg/L

We feel this problem was due to:

Centrifugal blowers off line due to mechanical failure. Installation and start up of repaired centrifugal blower took place Wednesday June 15, 2016 and will take a few days to re-establish compliance discharge.

We plan on correcting the problem in this manner:

Centrifugal repaired blower installed and running well. Plant will be able to recover in a few days now that need air requirements are being met.

Time estimated that it will take to correct problem:

Plant will begin to recover immediately and be back into compliance in a few days.

Sincerely,


Authorized Signature

6/28/2016
Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)