

Anderson, Alan

From: Tom Myers <tmyers@siloamsprings.com>
Sent: Thursday, June 16, 2016 9:55 AM
To: Anderson, Alan
Cc: Steven Gorszczyk; Jack Harrison
Subject: FW: Siloam Springs Wastewater Plant Update 6-16-16
Attachments: Phone Log June 16, 2016 Plant Update Notice to ADEQ..pdf

Follow Up Flag: Follow up
Flag Status: Flagged

Alan,

Here attached is a record of phone log that we discussed the installation and operation of the centrifugal blower. Blower is in operation and running as designed. Biological Nutrient Removal system is receiving needed dissolved oxygen. There has been initially more noticeable odors due to mixing action of dissolved oxygen. As system totally recovers odors will be reduced immensely. Effluent dissolved oxygen levels are above 7 ppm to receiving stream.

Sincerely,

Thomas A. Myers
Wastewater Superintendent
City of Siloam Springs
Ph:479-524-5623
Cell:479-228-0934
tmyers@siloamsprings.com



PHONE CONTACT LOG

Name of Caller: Tom Myers	Company: City of Siloam Springs
---------------------------	---------------------------------

Date/Time Call Made /Received: 6/16/2016	9:06 a.m.
---	-----------

Call Received By: Alan Anderson	Company: ADEQ
---------------------------------	---------------

Comments: Tom called to inform ADEQ that the repaired centrifugal blower has been received and installed and running properly June 15, 2016. Air is back to normal feed rate to the Biological Nutrient Removal Process (BNR).
 In addition Tom told Alan that ammonia nitrogen levels are dropping.
 The City of Siloam Springs has ordered a new larger centrifugal blower unit.

RE:	Wastewater Plant NPDES Permit No. AR0020273
-----	--

Name/Title	Division	Phone/E-Mail
Alan Anderson Enforcement Analysis	Water	(501) 682-0635 Email: anderson@adeq.state.ar.us