

Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: Siloam Springs NPDES Permit No.: AR0020273 Monitoring Period (Month/Year): 12 / 2012

No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions					
Cause(s) of SSO		SSO Impact		Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental Impact			CR-Creek/Stream/River (specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact		EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill		HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots / Grease			HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism			EN-Referred to Engineering	PA-Paved Area
				PN-Public Notification	CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location



01/17/2013


Signature of Cognizant or Ranking Official Date

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

CERTIFIED MAIL™



P.C.
Siloam Springs, AR 72761



7007 0710 0005 6184 1311

Hasler

FIRST CLASS MAIL

01/17/2013

US POSTAGE

\$06.80⁰



ZIP 72761
011D11628725

AR Department Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118-5317