

NON-COMPLIANCE LETTER

DATE: 09/21/2016

Arkansas Department of Environmental Quality
5301 North Shore Drive
North Little Rock, AR 72118-5317
ATTN: Enforcement Section

RE: NPDES Permit NO: AR0020605

Arkadelphia Water Utilities
700 Clay Street
PO Box 495
Arkadelphia, AR 71923
870-246-5863
Contact: David Thomason

Date(s) of Non-Compliance & Parameter(s) Exceeded:

Chlorine pump problem. Had to record TNTC for 6 Fecal Coliform sample dates.
August 3rd, 5th, 17th, 19th, 22nd, and 24th.

Corrective Measures:

Removed partial clog and tested.

Regards,



David Thomason, Wastewater Superintendent