

Lawrence, Myrl

From: Lawrence, Myrl
Sent: Tuesday, June 05, 2018 2:08 PM
To: 'cmfitzsimmmons@cityofarkadelphia.com'
Cc: 'dthomason@cityofarkadelphia.com'; 'gbrinkley@cityofarkadelphia.com'
Subject: NPDES Permit AR0020605 Compliance Review



June 5, 2018

James Calhoun, Mayor
City of Arkadelphia
700 Clay Street
Arkadelphia, AR 71923

RE: NPDES Permit Number AR0020605, AFIN 10-00463
Compliance Review

Dear Mayor Calhoun,

A review of the facility's file for the aforementioned Permit during the period March 2013 through May 2018 has revealed the following:

The facility has had no violations for non-receipt of discharge monitoring reports.

The facility is complying with the conditional monitoring requirement required by the Permit as related to whole effluent toxicity testing.

The facility has not had an effluent violation of the permit since March of 2017. Prior to March of 2017, there were 6 effluent limit violations outlined below:

DMR End Date	Discharge Number	Parameter Description	DMR Value Qualifier Code	Reported DMR Value	Permit Limit	Vio %	Violation Type	DMR Value Type Code	Parameter-Mon. Location-Season
01/31/2014	001-A	BOD, 5-day, 20 deg. C (MO AVG, mg/L)	=	33.3	30	11%	Numeric Vio	C2	00310-1-0
11/30/2014	001-A	BOD, 5-day, 20 deg. C (MO AVG, mg/L)	=	33.7	30	12%	Numeric Vio	C2	00310-1-0
12/31/2014	001-A	BOD, 5-day, 20 deg. C (MO AVG, mg/L)	=	34.5	30	15%	Numeric Vio	C2	00310-1-0
03/31/2015	001-A	BOD, 5-day, 20 deg. C (MO AVG, lb/d)	=	833.4	751	11%	Numeric Vio	Q1	00310-1-0
11/30/2015	001-A	BOD, 5-day, 20 deg. C (MO AVG, mg/L)	=	36.1	30	20%	Numeric Vio	C2	00310-1-0
03/31/2017	001-A	BOD, 5-day, 20 deg. C (MO AVG, mg/L)	=	34.5	30	15%	Numeric Vio	C2	00310-1-0

The commitment of you and your staff to monitoring and compliance improvement is to be commended. Thank you all for your continued protection of our waters and the environment.

Should you have questions or desire assistance please contact me directly.

Sincerely,

Handwritten signature of Myrl V. Lawrence Jr. in black ink.

Myrl V Lawrence Jr
Enforcement Analyst
ADEQ Office of Water Quality
Phone: 501-682-0699
Fax: 501-682-0880
myrl.lawrence@adeq.state.ar.us

cc: David Thomason, WW Superintendent, dthomason@cityofarkadelphia.com
Gary Brinkley, City Manager, gbrinkley@cityofarkadelphia.com

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
5301 NORTHSHORE DRIVE / NORTH LITTLE ROCK / ARKANSAS 72118-5317
TELEPHONE 501-682-0744 / FAX 501-682-0880 / www.adeq.state.ar.us