

NON-COMPLIANCE LETTER

DATE: 12/22/2023

Arkansas Department of Environmental Quality
5301 North Shore Drive
North Little Rock, AR 72118-5317
ATTN: Enforcement Section

RE: NPDES Permit NO: AR0020605

Arkadelphia Water Utilities
700 Clay Street
PO Box 495
Arkadelphia, AR 71923
870-246-5863
Contact: David Thomason or Christi Daniel

Date(s) of Non-Compliance & Parameter(s) Exceeded:

For the month of December we were over our 30 Day BOD Average. Our limit is 30.0mg/L and we reported 34.5mg/L. This was due to higher than normal depletion after the incubation period.

Corrective Measures:

Monitoring closely until the sample depletion range returned to normal.

Regards,



David Thomason, Wastewater Superintendent