

NON-COMPLIANCE LETTER

DATE: 10/20/2016

Arkansas Department of Environmental Quality
5301 North Shore Drive
North Little Rock, AR 72118-5317
ATTN: Enforcement Section

RE: NPDES Permit NO: AR0020605

Arkadelphia Water Utilities
700 Clay Street
PO Box 495
Arkadelphia, AR 71923
870-246-5863
Contact: David Thomason

Date(s) of Non-Compliance & Parameter(s) Exceeded:

The dilution in several BOD sample dates were out of range for the month of September.

Corrective Measures:

Ordered new dilution chemicals, sanitized all the equipment and issue seems to be fixed.

Regards,



David Thomason, Wastewater Superintendent