

NON-COMPLIANCE LETTER

DATE: 10/19/2023

Arkansas Department of Environmental Quality
5301 North Shore Drive
North Little Rock, AR 72118-5317
ATTN: Enforcement Section

RE: NPDES Permit NO: AR0020605

Arkadelphia Water Utilities
700 Clay Street
PO Box 495
Arkadelphia, AR 71923
870-246-5863
Contact: David Thomason or Christi Daniel

Date(s) of Non-Compliance & Parameter(s) Exceeded:

For the month of September we had several BOD tests where the dilution was out of range. After closely monitoring and sterilizing equipment numerous times we came to the conclusion the problem was contaminated equipment.

Corrective Measures:

Extensive sterilization on all equipment.

Regards,



David Thomason, Wastewater Superintendent