



700 Clay Street  
P. O. Box 495  
Arkadelphia, AR 71923  
Phone (870) 246-5863  
Fax (870) 246-9546

---

April 14, 2015

ADEQ  
5301 North Shore Drive  
North Little Rock, AR 72118-5317  
501-682-0744

RE: Permit # AR0020605 - March 2015 DMR

To whom it may concern;

For the month of March we are over our monthly average limit for BOD. The max being 751 and we are reporting 833.4. This is due to the above average rainfall we experienced throughout the month. All other calculations are within the designated limits and effluent flow is returning to normal. Please don't hesitate to call if you have any questions.

Regards,

David Thomason  
Wastewater Supt.  
Arkadelphia Water Utilities  
PO Box 495  
Arkadelphia, AR 71923  
870-246-0697  
[dthomason@cityofarkadelphia.com](mailto:dthomason@cityofarkadelphia.com)

cd

# Sanitary Sewer Overflow Monthly Report

Facility Name: Philadelphia Water Utilities      Permit Number: AR00201005      Reporting Period(Month/Year): 03/2015

No Sanitary Sewer Overflows This Monitoring Period

### Summary Report Code Descriptions

Cause(s) of SSO		SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact	WO-Work Order	CR-Creek/Stream/River (please specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure/Break	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots & Grease		HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Ultimate Discharge Location
<u>South pump station</u>		<u>03-24-2015</u>	<u>03-24-2015</u>	<u>10,000</u>	<u>Line Fail</u>	<u>NEAH</u>	<u>Repaired Line</u>	<u>Ditch</u>

Daniel Thomas  
Signature of Cognizant or Ranking Official

4-24-15  
Date

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.



**ARKADELPHIA  
WATER UTILITIES**

700 Clay Street • P. O. Box 495  
Arkadelphia, Arkansas 71923



02 1P

**\$ 000.69<sup>0</sup>**

0001609054 APR 29 2015

MAILED FROM ZIP CODE 71923

Arkansas Department of Environmental Quality

NPDES Enforcement Section

5301 Northshore Drive

North Little Rock, AR 72118-5317

721185317 0015

