



700 Clay Street  
P. O. Box 495  
Arkadelphia, AR 71923  
Phone (870) 246-5863  
Fax (870) 246-9546

---

December 22, 2015

ADEQ  
5301 North Shore Drive  
North Little Rock, AR 72118-5317  
ATTN: Enforcement Section

RE: NPDES Permit No. AR0020605

To Whom It May Concern;

This letter is to inform you that we are over the 30 day average for BOD during the month of November. We experienced higher than normal values this month in BOD and TSS that could possibly be attributed to temperature change and large amounts of rainfall.

We also experienced problems with out of range values for BOD dilution. New chemicals were ordered and values have returned to within range. Please do not hesitate to contact me with any concerns.


Regards,

A handwritten signature in cursive script that reads "David Thomason".

David Thomason  
Wastewater Superintendent  
Arkadelphia Water & Sewer Utilities  
700 Clay Street  
PO Box 495  
Arkadelphia, AR 71923  
870-246-0697  
dthomason@cityofarkadelphia.com



700 Clay Street • P. O. Box 495  
Arkadelphia, Arkansas 71923



02 1P  
0001609054 DEC 23, 2015  
MAILED FROM ZIP CODE 71923

**\$ 000.70<sup>5</sup>**

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

72118531799

