

### BYPASS/OVERFLOW REPORT

Send Overflow Report to: **Greg Hurley – ADEQ Enforcement Section**  
 Phone: 501-682-0638  
 FAX: 501-682-0880

Name of Facility: MOUNTAIN HOME WWTP Permit No : AR0021211

Date SSO Began: 8-12-15 Date SSO Ended: 8-12-15

Address of SSO: 1413 Hwy 62 E

Name of Person Reporting Overflow: JOHN E BEEBE Phone No.: 656 2238

Description of SSO:  Manhole Overflow Manhole # 108-060  
 Lift Station Overflow  
 Main Line Overflow  
 Service Line overflow  
 Other: Describe \_\_\_\_\_

Estimated Volume: 50 Gal

Ultimate Discharge Location: GROUND  
(Name or location of receiving stream/creek if applicable, ditch, pavement, ground, storm drain)

**Cause of SSO – Check all that apply**

- I and I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Other – Describe MANHOLE BUSH HOGGED ROCKED RING OFF DEBRIS FELL IN BLOCKED LINE

**Action Taken – Check all that apply**

- Machine rodded
- Jet-Vac
- Hydro Cleaned
- Hand rodded
- Disinfected and Deodorized
- Spread Lime on Affected Area
- Used Generator Too Power Pumps/Equipment
- Other – Describe VAC UP DEBRIS LET ROD LINE

**Environmental Impact**

- NEAH – No Evidence of Adverse Health/Environmental Impact
- OEHC – Observed or Evidence of Human Contact
- OEEI – Observed or Evidence of Environmental Impact
- EFK – Evidence of Fish Kill