

Sanitary Sewer Overflow (SSO) 24 Hr. Report

Name of Facility: Mountain Home Wastewater Phone: 870-425-5115
NPDES Permit # AR0021211

Date SSO Began: 12 10 17 Time SSO Began: 2700 1900

Date SSO Ended: 12 10 17 Time SSO Ended: 2000

Address or Manhole # of SSO: 122-310

Signature of person reporting: [Signature] Title VAL OP Phone: 870-426-2235

- Description of SSO:
- Manhole Overflow
 - Lift Station Overflow
 - Main Line Overflow
 - Service Line Overflow
 - Overflow: Describe WATER AND DEBRIS

Ultimate Discharge Location _____ (Ground, Ditch, Creek, Pavement. Etc)

Estimated Volume: 50 Gallons.

Cause of SSO - Check all that apply

- I and I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Other - Describe _____
- Power Failure
- Line Failure / Break

Action Taken - Check all that apply

- Machine rodded
- Jet-vac
- Root saw
- Hand rodded
- Disinfected and Deodorized
- Spread Lime on Affected Area
- Other - Describe RAKE UP RINSE DOWN GRASS
- Hydro Cleaned
- Public Notification
- Used Generator to power Pumps/Equip) etc

Environmental Impact

- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Contact
- OEHC - Observed or Evidence of Human Contact
- EFK - Evidence of Fish Kill

Send overflow Report to : ADEQ Enforcement Section - by Fax: 501-682-0880

Sanitary Sewer Overflow (SSO) 24 Hr. Report

Name of Facility: Mountain Home Wastewater Phone: 870-425-5115
NPDES Permit # AR0021211

Date SSO Began: 12-11-17 Time SSO Began: 0700

Date SSO Ended: 12-11-17 Time SSO Ended: 0800

Address or Manhole # of SSO: MH 137-012

Signature of person reporting: [Signature] Title VAC OF Phone: (870) 456 2238

Description of SSO: Manhole Overflow
 Lift Station Overflow
 Main Line Overflow
 Service Line Overflow
 Overflow: Describe WATER ONLY SOAKED INTO GRASS

Ultimate Discharge Location GROUND (Ground, Ditch, Creek, Pavement. Etc)

Estimated Volume: 200 Gallons.

Cause of SSO - Check all that apply

- I and I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Other - Describe _____
- Power Failure
- Line Failure / Break

Action Taken - Check all that apply

- Machine rodded
- Jet-vac
- Root saw
- Hand rodded
- Disinfected and Deodorized
- Spread Lime on Affected Area
- Other - Describe _____
- Hydro Cleaned
- Public Notification
- Used Generator to power Pumps/Equip) etc

Environmental Impact

- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Contact
- OEHC - Observed or Evidence of Human Contact
- EFK - Evidence of Fish Kill

Send overflow Report to : ADEQ Enforcement Section - by Fax: 501-682-0880