

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0021466 Discharge Number: 001- A

Facility: City of Alma

Address: 811 Fayetteville Ave

City: Alma State: AR Zip: 72921

Contact: Mark Yardley Phone: 479-632-2254

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
12-31-2021	BOD Monthly AV		42.9 mg/L	30 mg/L
12-21-2021	BOD 7 day AV		54.0 mg/L	45.00 mg/L
12-31-2021	BOD Loading		465.9 Lbs	437.9 Lbs

We feel this problem was due to:

Lagoon levels dropped below the normal level due to a disruption in the flow path.
We believe that the low levels caused short circuiting and led to inadequate treatment.

We plan on correcting the problem in this manner:

The lagoon levels have returned to normal and compliance was achieved.

Time estimated that it will take to correct problem:

Sincerely,



 Authorized Signature

01-24-2022

 Date