

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021466 Discharge Number: 001-A

Facility: City of Alma

Address: 811 Fayetteville Ave

City: Alma State: AR Zip: 72921

Contact: Mark Yardley Phone: 479-632-2254

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
08-30-18 08-15-18	FCB Monthly AV FCB 7 day AV		272 mg/L 430 mg/L	200 mg/L 400 mg/L

We feel this problem was due to:

Increases in Fecal Coliform Bacteria level in the lagoon without the benefit of chlorination

We plan on correcting the problem in this manner:

Beginning chlorination and dechlorination. Will continue chlorination and dechlorination until compliance is assured.

Time estimated that it will take to correct problem:

September should be in compliance

Sincerely,



Authorized Signature

09-21-18

Date