

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0021466 Discharge Number: 001-A

Facility: City of Alma

Address: 811 Fayetteville Ave

City: Alma State: AR Zip: 72921

Contact: Mark Yardley Phone: 479-632-2254

| Date of Non-Compliance | Parameter Exceeded | Quantity or Loading | Quality or Concentration | Permit Limits |
|------------------------|--------------------|---------------------|--------------------------|---------------|
| 04-31-17 | BOD Monthly AV | | 46.42 mg/L | 30 mg/L |
| 04-12-17 | BOD 7 day AV | | 94.33 mg/L | 45.00 mg/L |
| 04-31-17 | TSS Monthly AV | | 33.67 mg/L | 30 mg/L |
| 04-12-17 | TSS 7 Day AV | | 47.00 mg/L | 45.00 mg/L |
| 04-19-17 | TSS 7 Day AV | | 65.67 mg/L | 45.00 mg/L |
| | | | | |

We feel this problem was due to:

The proliferation of algae due to warm weather increasing the TSS and BOD.

We plan on correcting the problem in this manner:

We are feeding a product called BEF to help reduce BOD. We are also adding the algae control chemical called Earthtec.

Time estimated that it will take to correct problem:

The lagoons were out of balance. We are waiting for stablization before taking additional action. This process may require the next 30-60 days to complete. We do anticipate similar exceedances in May.

Sincerely,


 Authorized Signature

05-24-17
 Date