

Quarterly Report No. 3
CORRECTIVE ACTION PLAN for SANITARY SEWER OVERFLOWS
City of Alma, Crawford County, Arkansas
NPDES Permit No. AR0021466

REPORT DATE: December 12, 2023

SCOPE: Item 2 as identified in the approved Corrective Action Plan, Section 3.B. The action list and compliance schedule for resolution of this item (the SSO at Manhole 63-1 due to excessive I and I) is as follows:

Task No.	Action	Estimated Completion Date
1.	Smoke testing and CCTV inspection	September 2023
2.	Evaluation of data and project scoping	March 2024
3.	Development of budget and funding source	February 2025
4.	Design and bidding	June 2025
5.	Construction	December 2025

ACTIONS THIS REPORTING PERIOD:

Task 1: Smoke testing of the subject basin was completed with the assistance of ARWA on October 17, 2023. The following issues were revealed by the testing:

1. Five missing or broken cleanouts on private service lines were discovered.
2. Two manholes were identified that appeared to be leaking, which is probably a source of groundwater infiltration.

ENGINEER'S CERTIFICATION:

I hereby certify that this quarterly report was prepared under my supervision on behalf of the City of Alma, Arkansas.



Neal T. Morrison, P.E.
Neal Morrison Consulting, LLC



December 12, 2023